



National Library  
of Canada

Canadian Theses Service

Ottawa, Canada  
K1A 0N4

Bibliothèque nationale  
du Canada

Service des thèses canadiennes

## NOTICE

The quality of this microform is heavily dependent upon the quality of the original thesis submitted for microfilming. Every effort has been made to ensure the highest quality of reproduction possible.

If pages are missing, contact the university which granted the degree.

Some pages may have indistinct print especially if the original pages were typed with a poor typewriter ribbon or if the university sent us an inferior photocopy.

Reproduction in full or in part of this microform is governed by the Canadian Copyright Act, R.S.C. 1970, c. C-30, and subsequent amendments.

## AVIS

La qualité de cette microforme dépend grandement de la qualité de la thèse soumise au microfilmage. Nous avons tout fait pour assurer une qualité supérieure de reproduction.

S'il manque des pages, veuillez communiquer avec l'université qui a conféré le grade.

La qualité d'impression de certaines pages peut laisser à désirer, surtout si les pages originales ont été dactylographiées à l'aide d'un ruban usé ou si l'université nous a fait parvenir une photocopie de qualité inférieure.

La reproduction, même partielle, de cette microforme est soumise à la Loi canadienne sur le droit d'auteur, SRC 1970, c. C-30, et ses amendements subséquents.

UNIVERSITY OF ALBERTA

RE-DESIGN AND EVALUATION OF AN ON-LINE  
SPECIFIC OXYGEN UPTAKE RATE MONITORING  
APPARATUS AT THE GOLD BAR WWTP.

BY

W.K. (DAVE) WONG

A THESIS

SUBMITTED TO THE FACULTY OF GRADUATE STUDIES AND RESEARCH  
IN PARTIAL FULFILLMENT OF THE REQUIREMENTS FOR  
THE DEGREE OF MASTER OF SCIENCE

IN

ENVIRONMENTAL SCIENCE

DEPARTMENT OF CIVIL ENGINEERING

EDMONTON, ALBERTA

SPRING 1991



National Library  
of Canada

Canadian Theses Service

Ottawa, Canada  
K1A 0N4

Bibliothèque nationale  
du Canada

Service des thèses canadiennes

The author has granted an irrevocable non-exclusive licence allowing the National Library of Canada to reproduce, loan, distribute or sell copies of his/her thesis by any means and in any form or format, making this thesis available to interested persons.

The author retains ownership of the copyright in his/her thesis. Neither the thesis nor substantial extracts from it may be printed or otherwise reproduced without his/her permission.

L'auteur a accordé une licence irrévocable et non exclusive permettant à la Bibliothèque nationale du Canada de reproduire, prêter, distribuer ou vendre des copies de sa thèse de quelque manière et sous quelque forme que ce soit pour mettre des exemplaires de cette thèse à la disposition des personnes intéressées.

L'auteur conserve la propriété du droit d'auteur qui protège sa thèse. Ni la thèse ni des extraits substantiels de celle-ci ne doivent être imprimés ou autrement reproduits sans son autorisation.

ISBN 0-315-66607-2

Canada

To Whom It May Concern:

Permission is given by the undersigned to W.K.Wong to use the diagram " Schematic of OUR Apparatus " published in " Design and Evaluation of An Automated Oxygen Uptake Rate Measuring System " in the Canadian Journal of Civic Engineering, 15. pp 1015-1021, (1988) for his M.Sc. thesis titled " Re-design and Evaluation of an On-line Specific Oxygen Uptake Rate Monitoring Apparatus at Gold Bar WWTP ".

Dr. D. W. Smith

Dr. D. W. Smith

Bijan Aidun

Bijan Aidun

21st, February, 1991.

UNIVERSITY OF ALBERTA

RELEASE FORM

NAME OF AUTHOR: W.K. (DAVE) WONG

TITLE OF THESIS: RE-DESIGN AND EVALUATION OF AN ON-LINE  
SPECIFIC OXYGEN UPTAKE RATE MONITORING  
APPARATUS AT THE GOLD BAR WWTP.

DEGREE: MASTER OF SCIENCE

YEAR THIS DEGREE GRANTED: 1991

Permission is hereby granted to THE UNIVERSITY OF ALBERTA LIBRARY to reproduce single copies of the thesis and to lend or sell such copies for private, scholarly or scientific research purposes only.

The author reserves other publication rights, and neither the thesis nor extensive extracts from it may be printed or otherwise reproduced without the author's written permission.

.....  
.....

PERMANENT ADDRESS:

4310 47 Street

Edmonton, Alberta T6L 6J5


Date: 21 Feb, 91

UNIVERSITY OF ALBERTA  
FACULTY OF GRADUATE STUDIES AND RESEARCH

The undersigned certify that they have read, and  
recommend to the Faculty of Graduate Studies and Research  
for acceptance, a thesis entitled Re-Design and Evaluation  
of an On-line Specific Oxygen Uptake Rate Monitoring  
Apparatus at the Gold Bar WWTP, submitted by W.M. (Dave)  
Wong in partial fulfillment of the requirements for the  
degree of Master of Science in Environmental Science.

  
.....  
Supervisor, Daniel W. Smith

  
.....  
Steve E. Hrudey

  
.....  
Phillip M. Fedorak

Date: 2011-07-11

## **Abstract**

Due to the increasing demand for the environmental pollution abatement in wastewater treatment sector, a sensitive on-line monitoring device that can provide rapid and cost-effective information on the quality of the raw influent would be the most needed equipment.

According to many researchers and wastewater treatment plant reports, specific oxygen uptake rate (SpOUR) apparatus seems to be one of the ideal monitoring devices. SpOUR is defined as the rate of oxygen consumption per unit mass of microorganisms during the aerobic metabolism process. In monitoring the SpOUR of a sample seeded with returned activated sludge, important informations such as the toxicity and treatable organics of the sample can be obtained.

The SpOUR apparatus was re-designed and upgraded from an earlier developed prototype in order to meet today's stringent requirements. By using a more efficient programming language and an advanced micro-controller unit integrated with electronic and mechanical devices, the re-designed apparatus can automatically take a sample, mix it with the "seed", measure the SpOUR and plot data on a real-time basis.

The newly developed apparatus was test-run and debugged during the continuous round-the-clock trial periods of 60 days and was proven to be a reliable and useful device for

providing the SpOUR information of the raw influent.

Practical applications from the SpOUR values obtained were also examined. These include monitoring of toxicity, prediction of BOD<sub>5</sub>, tolerability of the activated sludge to liquid wastes and food to microorganisms ratio calculation. Finally a protocol for the management of unusual SpOUR results was also suggested.

### **Acknowledgements**

I would like to thank Dr. D. W. Smith for his expert advice, guidance and support throughout the project. Special thanks are also given to Roy Gitzel and Dale Lathe of the Department of Civil Engineering's Electronic Lab for their excellent work done on the computer hardware and software development.

In addition, I would like to acknowledge Mr. Gene Emanuel, Mr. Glen Brown and the staff of the Gold Bar Wastewater Treatment Plant for their help and encouragement to this project.

Finally, a special thanks is given to my son, Matthew, who did most of the typing for my thesis.

## Table of Contents

Chapter	Page
1. Introduction.....	1
1.1 Objectives.....	2
The Need for Monitoring Toxicity and Pollutants.....	3
2.1 United States Environmental Regulations.....	4
2.2 Canadian Federal Environmental Legislation.....	4
2.3 The Provincial Environmental Acts.....	5
2.4 City of Edmonton Sewage Bylaws.....	5
3. Methods of Monitoring.....	7
3.1 Enzymatic Response.....	7
3.2 Organic Pollutants Monitoring.....	7
3.3 Gas Chromatography (GC).....	8
3.4 Microscopic Examination.....	9
3.5 Bioassay.....	9
3.6 Others.....	12
4. Principle of Specific Oxygen Uptake Rate (SpOUR).....	12
5. Oxygen Uptake Rate (OUR) / Specific Oxygen Uptake Rate (SpOUR): Various Applications and Advantages.....	17
6. SpOUR Measurement.....	25
6.1 Respirometer.....	25
6.2 Dissolved Oxygen Probe.....	28
7. The Need to Re-design an On-line Automated Real-Time SpOUR Monitoring.....	30
8. Development of SpOUR Apparatus Prototype.....	31

8.1	Conceptualization.....	31
8.2	Collecting Relevant Information for the Design.....	32
8.2.1	Selection of Appropriate Sampling Point.....	33
8.2.2	Use of an Auto-Sampler to Obtain Raw Influent Sample.....	40
8.2.3	Selection of DO Probes.....	50
8.2.4	Temperature Measurement.....	56
8.2.5	Use of Mixed Liquor Volatile Suspended Solids (MLVSS) as Biomass Indicator.....	61
8.2.6	Order of Addition of SpOUR Samples.....	65
8.2.7	Effect of Mixing/Storage to RAS in Seed Tank.....	65
8.2.8	Aeration Rate and Time for SpOUR Apparatus and Seed Tank.....	66
8.2.9	Effect of Mixing.....	67
8.2.10	Development of More Efficient Computer Hardware and Software For the SpOUR Apparatus.....	68
8.2.10.1	Computer Hardware Development.....	69
	8.2.10.2 Software Development....	72
8.3	Construction Process.....	76
8.4	Start-up and Debugging During Trial Run.....	77
8.5	Final Testing Run for the Completed Unit.....	88
8.6	Development of Practical Applications for the Apparatus.....	89
8.6.1	Monitoring of Toxicity.....	92
8.6.2	Rapid BOD, Prediction.....	101

8.6.3 Tolerability Study.....	117
8.6.4 Food to Microorganism Monitoring Using SpOUR.....	120
9. Protocol for the Management of Unusual SpOUR Data.....	122
10 Discussion.....	124
11 Conclusion.....	132
BIBLIOGRAPHY.....	133
APPENDIX A. DO2CON46 Programme.....	139
APPENDIX B. DO2VER13.C Programme.....	152
APPENDIX C. Procedure for Changing Auto-Sampler Container.....	155
APPENDIX D. SpOUR Apparatus and 68HC11F1 Micro- Controller Unit (MCU) Software setup....	158
APPENDIX E. Down Loading Instructions.....	160
APPENDIX F. Example of Raw Data File for DO and Temperature.....	161
APPENDIX G. Example of Daily Summary File.....	162
APPENDIX H. Raw Data for Monitoring Period From June 28 to Sept. 1, 1990.....	163
APPENDIX I. SpOUR Monitoring from June 28 to Sept. 1, 1990.....	188

### List of Tables

Table	Page
1. Types of Current Biological Tests Conducted in Environment Canada's Environmental Protection Agency Toxicology Laboratories (adapted from Blaise et al., 1988).....	10
2. Biokinetic Constants Under Various Types of Wastewater and Different MCRT.....	18
3. Comparison of Oxygen Uptake Rates (OUR) Obtained by Standard Methods (APHA, et al., 1989) and SpOUR Apparatus.....	84
4. Effect of Nitrifying Bacteria in Samples.....	86
5. Comparison of EC50 Values for Cr(3+), Pb, Zn, 2,4 DCP, and 3,5 DCP.....	99
6. Summary of Unusual Trends or Results in SpOUR Due to RAW Influent Variability.....	123

## List of Figures

Figure	Page
1. An On-line Automated Microtox Suggested by Roesler (1986).....	11
2. Aerobic Degradation Pathways for Important Sewage Components in Respiration Chain.....	15
3. Arthur Automated Respirometer (Adapted from Martin 1988).....	26
4. Typical Respiration Curve for Seeded Sample.....	27
5. Schematic of the OUR Testing Arrangement as Suggested by OECD (1984).....	29
6. Gold Bar WWTP Process Flow Schematic.....	34
7. Gold Bar WWTP Layout.....	37
8. Raw Influent Sampling Point Location at the Headworks of GBWWTP.....	38
9. Schematic of OUR Apparatus (Adapted from Aidun and Smith 1988).....	41
10. Modification of Auto-sampler.....	43
11. Flowchart of the SpOUR Operation.....	45
12. Schematic Diagram of SpOUR Apparatus.....	46
13. Readout on Screen During SpOUR Testing.....	51
14. Comparison of YSI, L & N, and Capital DO Probes.....	57
15. Comparison of YSI and L & N DO Probes (After repair).....	58
16. Calibration of DO Meter.....	59
17. Calibration of RTD Using Certified Thermometer.....	62
18. Comparison of RTD and NBS Thermometers.....	63
19. Schematic Layout of SpOUR Units with Host Computer.....	70
20. Flowchart of SpOUR Apparatus Software.....	75

21. Picture of the Completed SpOUR Apparatus.....	79
22. Picture of the SpOUR Apparatus Sample Chamber.....	80
23. Typical OUR Using SpOUR Apparatus.....	90
24. Example of SpOUR Monitoring at Gold Bar WWTP....	91
25. EC50 of Pb Using SpOUR Apparatus and RAS+RAW.....	94
26. EC50 of Cr <sub>3+</sub> Using SpOUR Apparatus and RAS+RAW.....	95
27. EC50 of Zn Using SpOUR Apparatus and RAS+RAW.....	96
28. EC50 of 2,4 DCP Using SpOUR Apparatus and RAS+RAW.....	97
29. EC50 of 3,5 DCP Using SpOUR Apparatus and RAS+RAW.....	98
30. Picture of the RAS Before Toxicant was Added.....	102
31. Picture of the RAS After Toxicant was Added.....	102
32. SpOUR Versus BOD <sub>5</sub> (Significant Correlation Found) .....	105
33. RAS+BOD Reference Standard Versus SpOUR (Without Adjusting pH).....	107
34. RAS+BOD Reference Standard Versus SPOUR (With pH Adjustment to 7).....	109
35. Calibration of SpOUR with Synthetic Sewage.....	112
36. Linear Plot of 1/SpOUR Versus 1/BOD <sub>5</sub> .....	113
37. Prediction of BOD <sub>5</sub> of Raw Influent Samples by SpOUR Values.....	114
38. BOD <sub>5</sub> Versus SpOUR (Daily Raw Composite).....	116
39. Flowchart of Biological Upsets Management.....	125

### List of Abbreviations

ADP	= adenosine diphosphate
ATP	= adenosine triphosphate
BASIC	= beginner's all-purpose symbolic instruction code
BOD <sub>5</sub>	= biochemical oxygen demand (5 day incubation)
COD	= chemical oxygen demand
DCP	= dichlorophenol
DO	= dissolved oxygen
EC <sub>50</sub>	= effective toxicant concentration in mg/L that will decrease the SpOUR of the control by 50% under the specific testing conditions using the SpOUR apparatus
EEPROM	= electrically erasable programmable read-only memory
F : M	= food to microorganisms ratio
HCMOS	= high density complimentary metal oxide semi-conductor
MCRT	= mean cell retention time
MCU	= micro-controller unit
MLVSS	= mixed liquor volatile suspended solid
OECD	= Organization for Economic Cooperation and Development
OUR	= oxygen uptake rate
PE	= primary effluent
RAM	= random access memory
RAS	= returned activated sludge
RAW	= raw influent
RPM	= round per minute
RTD	= resistant temperature detector
SAT	= secondary aeration tank
SOP	= standard operation procedure
SpOUR	= specific oxygen uptake rate
WWTP	= wastewater treatment plant

## 1. Introduction

Various methods have been developed in recent years for determining toxicity and organic loadings into wastewater treatment plants. However, most of these methods require a skillful operator, take a long time for useful data production, are expensive, and relatively labour intensive. There is also a very difficult decision of which parameters to be chosen as the suitable surrogate for monitoring purposes.

For the wastewater treatment plant, the development of the microbial Oxygen Uptake Rate (OUR) monitoring is one of the most promising methods for helping the wastewater treatment plant personnel to deal with the increasing demand for environmental pollution abatement. OUR test provides an immediate indication on the materials in the wastewater that are or are not inhibitory to the microorganisms present. As such the test result reflects the tolerance of the microbial population to the wastewater that is to be treated. This "tolerability" test is often related to or used as a surrogate for the commonly called "treatability" test.

Two basic automatic models that utilize the monitoring of the respiratory activities of the microbial population are available. The commercially available automated respirometer developed by Arthur (1990) is a modified Warburg respirometer especially designed for wastewater treatment monitoring. A lot of research and development work has been done by Arthur Technology, the company which

markets the respirometer, to improve the unit.

Aidun and Smith (1988) have also designed and patented another automatic OUR apparatus in 1986 using a dissolved oxygen (DO) probe and a combination of electrical, mechanical and computer interfacing systems. This apparatus seems to be very promising but is still in its infancy stage, more development work is required to improve the apparatus. Moreover, advances in technologies, especially in the computer area, have made the unit somehow inadequate and less flexible in dealing with today's wastewater treatment plant's increasing demand for better treatment efficiency and pollution abatement.

The initial purpose of this project was to review the literature on the OUR methodology and to improve the hardware as well as the computer software of the OUR apparatus.

Once this was done, practical applications of the updated automatic OUR apparatus were to be established for the City of Edmonton's Gold Bar Wastewater Treatment Plant.

### **1.1 Objectives**

The objectives of this study were:

1.1.1 Based on a literature review of OUR methodology, revamp the hardware and software of the Automatic OUR apparatus developed by Aidun and Smith (1988) so that it could be used as an useful on-line monitoring

apparatus.

1.1.2 To do a trial run of the newly developed on-line apparatus.

1.1.3 To establish practical applications of the apparatus for the facility at the City of Edmonton's Gold Bar Wastewater Treatment Plant (WWTP).

## **2. The need for monitoring toxicity and pollutants**

In the recent years, private corporations and public regulatory agencies have been increasingly aware of the environmental concerns of the effects of the large number of toxicants and pollutants in the environment. Consequently many environmental protection policies and regulations have been implemented in an attempt to stop the improper dumping of toxic wastes. With the growing pressure from the environmentally conscious public sector and the need to protect the environment, the demand to develop an efficient, cost-effective, sensitive and rapid test for toxicity and pollutants is inevitable.

In particular, wastewater has been an area of concern because it has a direct and often immediate effect on open water sources and on the living organisms (including humans) that rely on them. In view of this concern, series of environmental regulations were imposed in the recent years.

## **2.1 United States Environmental Regulations.**

In 1976, the Resource Conservation and Recovery Act (RCRA) was enacted to ensure the accountability of toxic substances and pollutants. In 1977, the U.S. Environmental Protection Agency (USEPA) issued permits to industries through Section 402 of the Clean Water Act (CWA), governing the discharge of toxic effluents into navigable water. Furthermore, National Pollutant Discharge Elimination System (NPDES) permits are issued by the individual states to control and regulate pollutant discharge.

The revision of the Clean Water Act in 1987 as Water Quality Act (WQA) laid the foundation of biological monitoring as a way of toxicity control.

## **2.2 Canadian Federal Environmental Legislation.**

In 1988, Environment Canada had consolidated the various environmental legislations into a single Canadian Environmental Protection Act (CEPA). The CEPA takes a preventive approach to environmental protection. The main emphasis of this Act is on the management of toxic substances from their manufacture, transportation, distribution, storage, use, and eventually to their final disposal. The Act's "cradle to grave" approach attempts to deal with the increasingly important issue of toxic waste problem.

### **2.3 The Provincial Environmental Acts:**

The Province of Alberta's Clean Water Act deals with the legislative aspects of treatment and disposal of liquid wastes. Section 17 of the Act specifies that licensed wastewater facilities such as the Gold Bar WWTP could be held liable as generator for any non-licensed materials that they may receive and eventually discharge to a water body even though they are not the generator of these toxic wastes. In view of the CEPA, the Alberta government is undergoing a revision of the Environmental Law Enforcement so that tougher penalties will be imposed for any violation of the relevant pollution acts.

### **2.4 City of Edmonton Sewage Bylaws.**

Like many sewage treatment facilities in North America, the City of Edmonton allows certain categories of industrial / commercial wastes to be discharged to the sewer system. The obvious advantage of combining these industrial / commercial wastes with the domestic waste is cost effectiveness. Furthermore, the high dilution factor offered by the domestic sewage, also makes such options attractive. However, with the tightening of pollutant disposal requirements, industries may be tempted (and most often due to ignorance) to dispose of hazardous wastes to municipal sewer systems even though Sewer Bylaw #7118 (1983) of the City of Edmonton have set forth various pollutant

limits for liquid wastes that can be discharged into the sanitary sewage system. Such unwarranted toxic loadings could easily upset the normal treatment capability of wastewater treatment plant and cause effluent deterioration. Consequently, the WWTP is constantly under the threats of licence violation and treatment failure.

Unfortunately, the Gold Bar WWTP at the City of Edmonton has not been designed to treat toxic wastes. The biological secondary treatment is therefore very vulnerable to toxic shock loads either on an acute or chronic basis. The daily routine monitoring tests done by the wastewater treatment personnel are also unable to give advance warning of any unusual or toxic loadings. In order to deal with this problem, the City of Edmonton has set up a Sewer Bylaws Revision Committee to put forth a new Sewer Bylaw with more stringent limits.

Even without the inflow of toxic wastes, the wastewater treatment plant at Gold Bar is constantly experiencing the diurnal fluctuation of sewage coming into the plant (both in hydraulic and organic loadings). Such fluctuations have caused a requirement for higher level of skill for process control in order to obtain the maximum treatment efficiency and to stay within the provincial and federal governments pollution control regulations.

Consequently, a monitoring device that can provide real-time information on the quality of the influent as well

as the treatment process requirements would be the most needed device for the management as well as the operational staff at the wastewater treatment plant.

### **3. Methods of Monitoring**

In order to monitor such toxic and/or high organic loadings to prevent possible wastewater treatment facilities upset and to provide subsequent effective pollutant removal, the following methods of monitoring have been suggested:

#### **3.1 Enzymatic Response:**

This approach uses the response of certain types of enzymes or metabolites to toxic materials. Kennicutt (1980) reported that chemicals such as chloroform, mercuric chloride, and acrolein, when individually added to a standard solution of adenosine triphosphate (ATP), decreases significantly the luciferin - luciferase enzyme reaction.

By monitoring the changes in the amount of light emitted, an on-line enzymatic response system can be used for testing toxic materials. However, the author cautioned that this method was only in its development stage. This monitoring does not detect any unusual organic loading that can affect the normal operation of the wastewater plant.

#### **3.2 Organic Pollutants Monitoring:**

Automated on-line monitoring of Total Organic Carbon

(TOC), Total Carbon (TC), Total Oxygen Demand (TOD), Chemical Oxygen Demand (COD) chosen as indicators of organic pollutants for environment pollution control were described by Queeney & Hoek (1989).

Roesler (1986) had also suggested using of the organic halide as surrogate for toxicity. An on-line total organic halide (TOX) analyzer was used to oxidize TOX to halogen acids (HX) which were then measured by electrochemical or conductivity methods. However, due to the complexity of the raw influent sample matrix, manual sample preparation has to be done. Again, the detector cannot give any information on unusual organic load.

### **3.3 Gas Chromatography (GC):**

Computer-based gas chromatography has been successfully used to detect low molecular weight volatile organics (Dowty et al., 1976) that are toxic. The volatile organics are thermally desorbed from the liquid sample and displaced into the headspace by ultrapure helium purging. The displaced organics are then adsorbed on a special column which fits into the injection port of a gas chromatograph. On-line data collection is done by a microprocessor. However, this on-line gas chromatography is limited to certain specific compounds. It is also expensive to purchase, difficult to maintain and requires a high skill to operate.

### **3.4 Microscopic Examination**

Richard (1988) had reported using of microscopic examination of microorganisms for toxicity assessment in activated sludge. Basing on the report of Himebaugh (1981), the staff of the Gold Bar WWTP (Brown and Nowak, 1983) have developed a microscopic method of evaluating status and activities of the secondary sludge microorganisms via microscopic examination.

Davey (1988) had also documented a "simple but effective" qualitative laboratory bench-top viability test by microscopic examination of the physical and biological changes to ciliates. However, in order to get good interpretation of the result, excellent staff training and the development of an unbiased protocol for reporting observations are required for the success of such a programme.

### **3.5 Bioassay:**

Blaise et al. (1988) summarised the various types of current bioassays being tested by Environment Canada as shown in Table 1.

In this approach, micro- or macro-organisms are used to monitor their various physiological changes under different testing conditions. Among the tests listed, the photobacterial test marketed as the Beckman Microtox (Figure 1) which monitors the changes in light emission from the

TABLE 1.

Types of current biological tests conducted in Environment Canada's Environmental Protection Aquatic Toxicology Laboratories (adapted from Blaise et al., 1988)

Test Type	End Point
<b>Lethality</b>	
Trout-- <i>Salmo</i>	Mortality
Stickleback-- <i>Gasterosteus</i>	Mortality
Waterflea-- <i>Daphnia</i>	Mortality
Brine Shrimp-- <i>Artemia</i>	Mortality
<b>Sublethality</b>	
Trout-- <i>Salmo</i>	ATP Energy Stress
Waterflea-- <i>Daphnia/Ceriodaphnia</i>	Reproduction
Algae-- <i>Selenastrum</i>	Growth Inhibition
Bacteria-- <i>Photobacterium</i>	Light Inhibition
<b>Genotoxicity</b>	
Dark Mutant Test	Mutagenicity
SOS Chromotest	Genotoxic Potential
AMES test	Mutagenicity
<b>Bioavailability</b>	
Clam-- <i>Macoma</i>	Bioaccumulation
Freshwater and Marine Fish	Bioconcentration
<b>Biodegradability</b>	
Mixed Aerobic Bacterial Culture	Oxygen Uptake Rate
OECD (1984)	Inhibition




Figure 1. An on-line automated Microtox suggested by Roesler (1986).

luminescent bacteria and the mixed aerobic bacterial culture test (OECD 1984) that measures the bacterial respiration activity changes due to toxicity are the two tests that have gained increasing attention. This type of shifting from the use of fish and other macro-organisms to microbiotest which could be described as the "Second generation bioassay" is due to the ever increasing pressure for the need of effectiveness and economy in environmental protection assessments.

### **3.6 Others:**

Other suggestions such as a combination of dissolved organic carbon (DOC), pH, turbidity, colour, oxidation-reduction potential (ORP) and flow measurement be used at the headworks to monitor the incoming wastewater for early warning of toxicity or high organic loadings or both, as recommended by Flynn (1979) or uses of an on-line respirometer in conjunction with other complicated instrumentation as reported by Summers et al. (1982) are either too labour intensive or too complicated to implement.

## **4. Principle of Specific Oxygen Uptake Rate (SpOUR)**

OUR is defined as the rate of oxygen consumed by the microorganisms. It is expressed in formula as:

$$\text{OUR} = \frac{\text{Oxygen Uptake by microorganisms (mg O}_2\text{/L)}}{\text{Time (h)}} \quad (1)$$

The SpOUR of the activated sludge is expressed as the oxygen consumption of aerobic sludge or wastewater microorganisms per unit time per unit microbial mass. It is expressed as:

$$\text{SpOUR} = \frac{\text{Oxygen Uptake by microorganisms (mg O}_2/\text{L)}}{\text{Time (h)} * \text{MLVSS (g/L)}} \quad (2)$$

MLVSS = Mixed Liquor Volatile Suspended Solid, g/L

SpOUR is one of the most commonly used microbial bioassays. Generally speaking, the test measures the response of the physical property of the OUR of a fixed mass of microorganisms with respect to certain conditions such as presence of toxic material, excess or lack of metabolic substrates, changes in temperature etc.

The respiration activities of an aerobic sludge can be classified as:

1. Endogenous Respiration ( $R_E$ ) - oxygen is used by microorganisms for degradation of the internally stored reserve substrate due to a low or substrate-free activated sludge.  $R_E$  is relatively stable but there is a gradual decline in  $R_E$  value over time due to progressive reduction of all reserves.
2. Substrate Respiration ( $R_S$ ) - oxygen demand in the presence of readily available substrate. For long-term measurement, there is a general transition to

$R_E$  as the substrate diminishes.

3. Maximum Respiration Rate ( $R_M$ ) - oxygen demand under conditions of excess substrate. The respiration rate  $R_M$  is quite steady until excess substrate is depleted and  $R_M$  gradually decreases to  $R_s$  and eventually to  $R_E$ .

These different respiration rates give a quantifiable insight into the enzymatically controlled metabolism rate of the whole micro and macro faunae. They also provide valuable information on the substrate utilization rate, the presence of any toxic chemicals in a very short testing time.

A simple representation of the respiration process can be represented by (after Hanel, 1988):




Figure 2 shows a simplified aerobic metabolic pathway for the three most common substrates in wastewater. Acetyl groups derived from proteins, carbohydrates and fats enter the Krebs (citric acid) cycle to form  $\text{CO}_2$  and hydrogen atoms. The latter are then fed into the respiration chain where the energy contained in the hydrogen is transferred to adenosine diphosphate (ADP) by the coupled oxidative




Figure 2. Aerobic degradation pathways for important sewage components in respiration chain.

phosphorylation process to form the high energy adenosine triphosphate (ATP). Oxygen is the normal acceptor for the unenergized hydrogen to form water. That is why OUR can be used as an indicator of microbial activities.

Huang and Cheng (1984) had related mathematically the SpOUR with the substrate concentration by the Monod equation as:

$$\text{SpOUR} = \frac{U_M^0 S}{K^0 + S} \quad (3)$$

Where  $U_M^0$  = maximum SpOUR, mg O<sub>2</sub>/(gMLVSS.h).

S = substrate concentration, mg COD/L

$K^0$  = maximum SpOUR saturation constant, mg COD/L

By applying the Lineweaver - Burk (taking the reciprocal of both sides of the equation) relationship to equation (3) gives:

$$\frac{1}{\text{SpOUR}} = \frac{1}{U_M^0} + \frac{K^0}{U_M^0 S} \quad (4)$$

Because only active microorganisms would use oxygen during the metabolism of substrate and other microbial activities, the use of SpCUR would be more appropriate for indicating active biomass than other indicators such as ATP, cell count. Moreover, the biokinetic constants  $U_M^0$  and  $K^0$ ,

reflect the specific characteristics of a particular activated sludge under a given condition. Such information obtained from SpOUR is very useful for other operational control decisions.

Table 2 (adapted from Vargas-Lopez 1989, and Huang and Cheng 1984) shows the values of biokinetic constants obtained from various types of activated sludge at different mean cell retention times (MCRT).

## 5. Oxygen Uptake Rate (OUR)/Specific Oxygen Uptake Rate (SpOUR): Various Applications and Advantages

While some methods of monitoring are too specific (i.e monitoring only one specific parameter such as pH, TOC, cyanide), others require expensive equipment (e.g. gas chromatography) or trained technicians (e.g. microscopic examination).

Advantages of using Oxygen Uptake Rate (OUR) and more explicitly Specific Oxygen Uptake Rate (SpOUR) as biomonitoring or process control tool have been cited as early as 1956. Wuhrman (1956) had already observed that OUR has a close relationship with loading rates and past history of the sludge under aeration. Eckenfelder (1961) illustrated that SpOUR could be used for monitoring sludge stability. Benefield et al. (1975), and Mona et al. (1979) reported that any increases in the influent substrate concentration resulted in a corresponding increases in OUR. Based on the

TABLE 2.

**Biokinetic Constants Under Various Types of Wastewater  
and Different MCRT**

Source and Type of Activated Sludge	$U_m^0$ mg O <sub>2</sub> /(g.h) (mean)	K <sup>0</sup> mg O <sub>2</sub> /L (mean)
Synthetic (Dextrose- Nutrient Broth) <sup>a</sup> MCRT = 8 days.	55 to 115(90)	34 to 154(95)
Synthetic (Nutrient Broth) <sup>a</sup> MCRT = 25 days.	52 to 60(56)	175 to 350(235)
Synthetic (Dextrose) <sup>a</sup> MCRT = 25 days.	36 to 40(39)	100 to 150(117)
Municipal Wastewater <sup>a</sup> MCRT = 5 days.	35 to 42(39)	100 to 125(110)
Laboratory Scale Activated Sludge <sup>b</sup> MCRT = 48 days.	43	81

<sup>a</sup> adapted from Huang and Cheng, 1984.

<sup>b</sup> adapted from Vargas-Lopez, 1989.

continuous measurement of ambient dissolved oxygen (DO) level as a function of oxygen uptake by microorganisms, Clarke et al. (1977) and Solyom et al. (1976) had both developed a "Biomonitor" to provide early warning to shock loading. Arthur and Hursta (1968), and Therien and Ilhan (1983) had correlated biochemical oxygen demand (BOD) with OUR and suggested using a respirometer as an automatic monitoring device of the biodegradable organics entering the wastewater treatment plant.

Haas (1979) developed a relationship among the influent, effluent strengths and OUR which may be considered as analogous to direct control of Food to Microorganisms (F : M) ratio.

In his many publications about activated sludge process control, Arthur (1982a, 1982b, 1983, 1984, 1986, 1988, 1990) has suggested many uses of OUR in plant process control. These included "toxicity testing of influent, anticipatory control of microorganisms viability, control of return sludge, short term BOD determination such as prediction of BOD, in final effluent .....etc." Successful results were claimed by Nelsen (1987) and Miller (1985) in their wastewater treatment plants in Richland, Wash. and Syracuse, N.Y. respectively. Both plants reported using OUR as a monitoring device and recommended that it was an invaluable tool in predicting process performance changes or failures.

Huang and Cheng (1984) observed that OUR reflected the

extent of microbial activity and specific oxygen uptake rate (SpOUR) could be related to the final effluent settleable chemical oxygen demand (SCOD) concentration. Mueller et al. (1985) further indicated the potential and usefulness of the OUR of an activated sludge in determining the microbial activity and viability. Suschka and Ferrira (1986) demonstrated that the respirometer measurement technique for OUR could be of great help in evaluation of the activated sludge characteristics, the sewage concentration fluctuation and the biodegradability. Roesler (1986) recommended that respirometer was one of the most promising on-line analyzers for early warning of a variety of toxic materials. Aidun and Smith (1988) were able to collect OUR data automatically on a continuous basis with the aid of a micro-computer. They felt such information was important for detection of toxic compounds entering the wastewater treatment plant and for general process control monitoring.

Colvin and Rozich (1989) have shown that OUR testing results could be used to calculate important process control information such as the biokinetic constants. Dutka and Kwan (1984) compared four different microbial toxicity testing procedures and found that the OUR testing is one of the best for testing contaminated samples because factors such as pH, turbidity, and colour do not seem to affect the outcome of the toxicity tests as compared to the other methods.

Vargas-Lopez et al. (1989), in their discussion of

using SpOUR as an activated sludge process control parameter, had strongly recommended SpOUR be used in aeration and return sludge rate control and for early warning of shock loads and toxicity. However, they also specified that standardization and improvement in procedure should be investigated to improve the accuracy and precision of the measurement.

In their comparison of the three rapid toxicity test procedures, Elnabarawy et al. (1988) also concluded that the method of measuring respiratory activity can detect adverse effects on heterotrophic microorganisms but cautioned the lack of reproducibility if measurements are not done carefully.

Uses of OUR is not limited to the research laboratory only, it is also presently used and favoured by many wastewater treatment plants as one of the most valuable tools for plant process control. Fitzgibbons (1989) indicated that OUR is an useful tool for predicting changes in activated sludge operating conditions at an early stage at the City of Cranston, Rhode Island Wastewater Treatment Facility, but commented that manual testing is cumbersome.

Nelsen (1987) of the City of Richland Wastewater Treatment Plant, Washington, reported the routine uses of OUR for evaluation of the relative activity level of the biomass and prediction of the plant's BOD removal effectiveness. The City of Union, Ohio, (Miklos, 1990) also

uses the OUR as a tool for rapid determination of treatability or toxicity. By using a YSI DO probe, a comparison of the wastewater treatment plant's activated sludge OUR before and after contact with the wastewater is utilized as a measurement of treatability/toxicity.

Miller (1985) of Onondaga County in Syracuse, N.Y., used the OUR as a "real time" control parameter for settleability, F:M ratio, mean cell retention time (MCRT) and the quantity of oxygen needed to maintain a healthy activated sludge.

The Patapsco Wastewater Treatment Plant on the Chesapeake Bay in Baltimore, Md., utilized OUR instrument to investigate the high CO<sub>2</sub> inhibition on activated sludge (Martin 1988). In the same facility, Whitney (1989) further used the OUR to continuously monitor presence of toxicity not only from the Patapsco Plant but also from any other suspected sites of possible toxic pollution in Baltimore. The City of Calgary's Bonnybrook Wastewater Treatment Plant also applies the OUR monitoring technique via a respirometer to test treatability and toxicity of wastewater. In Georgia, the Ellijay Water Pollution Control Plant uses OUR daily to monitor any inhibition in the secondary aeration tanks due to toxic chemicals (Bundy 1989).

Another advantage of using OUR or SpOUR as a monitoring method is that no chemical reagents are used for the test. Other monitoring procedures such as COD require some

hazardous reagents and consequently will require additional waste disposal management.

The real advantage of using SpOUR is no surrogate is used, so there is no guessing or interpretation of the outcomes of the monitoring. Samples being examined are tested using the microorganisms taken from the treatment plant itself. The results give the direct indication of the impact of the sample to the treatment system.

Furthermore, from the point of view of process control, the SpOUR testing is superior to other methods of monitoring. The activated sludge used for SpOUR tests is site specific, while many other tests may give false positive or negative results. One example is the use of Microtox for testing toxicity of a sample. A positive toxicity sample identified by Microtox may not be toxic to a particular treatment plant due to activated sludge acclimatization and vice versa.

In spite of all these recommendations, negative feedbacks are also reported. Benefield et al. (1975) commented that OUR would increase lab workload, required a much higher degree of operator's attention and more complicated mathematical manipulation. Duggan and Cleasby (1976) illustrated that no relationship existed between OUR and effluent quality but concluded that OUR reflected influent concentration fluctuation. Sherrard (1980) reported that the OUR had limited use for process control purpose. He

concluded that the more reliable information could be obtained by directly measurement of the aeration tank DO concentration and effluent quality. Khararjian (1980) believed that the use of OUR would tend to confuse plant operators and engineers. Edwards and Sherrard (1982), Godrej and Sherrard (1988), Chandra et al. (1987) further indicated that OUR or SpOUR would vary widely with very little change in effluent quality and was of little use as a plant process control parameter for both steady state and shock-loading conditions.

Miklos (1990) also pointed out the limitation of the OUR/SpOUR result as it can not differentiate between low organic loading and toxicity. The OUR or SpOUR result will only tell toxicity for that particular population of microorganisms. Consequently, no comparison or standard reading can be referenced as it can be done in the Microtox method.

Furthermore, the OUR/SpOUR tests results do not tell the effects of toxicity on the anaerobic digester and the effluent to the aquatic life.

With the above alleged advantages and limitations recognised, the microbial bioassay method of OUR/SpOUR is one of the most compelling and applicable methods for monitoring wastewater process control. It is far more desirable to have a small scale activated sludge upset such as registered in the SpOUR apparatus than to have an actual

major upset in the plant's secondary that could result in a plant shut down or a licence violation.

## **6. SpOUR Measurement**

The SpOUR measurement can be done by two principal methods of evaluation, both of which are acknowledged by the Standard Methods (APHA, et al., 1989) as acceptable.

### **6.1 Respirometer**

The first method uses the principle of the Warburg Respirometer that was developed in the early 1900's. Through years of improvement, automated respirometers mainly designed for wastewater monitoring purposes have been developed. The Arthur Automatic Respirometer (Figure 3) utilizes a combination of sample chamber carbon dioxide scrubber, a sensitive gas volume transducer, air pump and automatic vent - all immersed in a temperature controlled water bath. When a sample (1 to 4 litres) is introduced into the sample chamber, its respiratory activity uses oxygen and generates carbon dioxide which is immediately removed by the scrubber. The net loss of gas volume is detected by the transducer and recorded on a strip chart as oxygen uptake as shown in Figure 4. The rate of oxygen uptake is then calculated from the strip chart.




Figure 3. Arthur automated respirometer (adapted from Martin 1988).

## Typical Respiration Curve for Seeded Sample





Figure 4. Typical respiration curve for seeded sample.

## 6.2 Dissolved Oxygen Probe

The second method uses an oxygen sensitive electrode to monitor the rate of decrease of oxygen (Standard Methods, APHA, et al., 1989. Method #2710.B). This method is also adapted by the Organization for Economic Cooperation and Development (OECD 1984) for testing respiration inhibition on activated sludge. Basically, an oxygen sensing probe is used to measure the changes in oxygen concentration of a sample in a suitable container like a BOD bottle over a fixed period of time. Figure 5 shows the schematic of the testing arrangement.

In this project, the method of using the oxygen sensitive electrode for SpOUR measurement was chosen because of the following reasons:

- (i) The oxygen sensitive electrode (dissolved oxygen probe) was readily available from the Gold Bar Wastewater Treatment Facility.
- (ii) Dissolved Oxygen (DO) probe measures oxygen directly rather than indirectly as in the case of respirometer.
- (iii) No complicated equipment such as the transducer or scrubber are required.
- (iv) Successful development of an automated on-line OUR measurement system by Aidun and Smith (1988).



**Figure 5.** Schematic of the OUR testing arrangement as suggested by OECD (1984).

## **7. The Need To Redesign An On-line Automated Real-Time SpOUR Monitoring Apparatus**

From the previous discussion of all the benefits of SpOUR monitoring, it is obviously desirable to have an automated on-line SpOUR monitoring device that is capable of giving real-time information on the activated sludge treatment process.

Aidun and Smith (1988) developed an automated OUR measurement system using a DO probe. However, the initial design could only test samples taken from the secondary aeration tank. Due to the limitation of the initial apparatus design, the equipment cannot test raw sewage influent at the raw influent headworks at the Gold Bar WWTP. Such a restriction has limited the advance warning ability of the apparatus. An update of the mechanical part of the OUR measurement system is inevitably necessary if an advanced warning is required.

Computer technology has also advanced so much since Aidun and Smith (1988) developed the first prototype that better software and hardware are available nowadays to make the apparatus more "real-time" and efficient. The micro-computer system used previously is a Commodore 2001 Series (PET) with only 32K memory. Both the floppy disk drive and printer were slow and inadequate. Moreover, Commodore computer and its "Basic" software programme are not commonly used nowadays. The more commonly used computer in the

industrial or laboratory environment is the IBM or IBM compatible. Therefore, computer software and hardware revamps were required to keep up with the new development and to provide real-time data handling ability.

## **8. Development of SpOUR Apparatus Prototype**

The stages of development of the automated on-line SpOUR apparatus were set as follows:

- 8.1 conceptualization of the design;
- 8.2 collecting relevant information for the designing;
- 8.3 construction process;
- 8.4 start-up and debugging during trial run;
- 8.5 final testing run for the completed unit;
- 8.6 development of practical applications for the apparatus; and
- 8.7 turning the completed unit into a process control operation.

### **8.1 Conceptualization**

The initial design was originated from Aidun and Smith (1988). Using the principle from the Standard Methods (APHA, et al., 1980), they had developed an apparatus to monitor the OUR of the activated sludge in the secondary aeration tank.

In order to get a better lead time for monitoring toxic

and organic loading so that plant operator can have some advance warning, monitoring of the raw or primary sewage is necessary. In this case any toxic or extraordinary loads of raw sewage coming to the plant can be detected. The control operators can have at least the length of time equivalent to the retention time of the primary to decide what to do before the slug reaches the secondary aeration tank. At the Gold Bar WWTP, this retention time is equivalent to 0.7 hour to 2.3 hours (UMA 1976) depending on the flow rate. This average 1.5 hours of advance warning is very valuable for process control management to make a decision and carry out corrective measures. Such an advance alarm enables the operator to be "proactive" rather than "reactive".

It would also be desirable to save the sample that has been tested by the SpOUR unit so that any abnormality in the SpOUR test can be further investigated. A protocol for the control operator to decide what steps to follow if a toxic or heavy loading is suspected from the SpOUR result would also be developed.

## **8.2 Collecting Relevant Information For The Design**

Having identified the above requirements, the following changes and specifications were perceived:

1. The sampling location must be relocated to obtain representative influent sample.

2. The unit must be able to obtain and test the SpOUR of a raw influent sample.
3. A portion of the sample must be stored for later analysis if needed.
4. The result should be automatically recorded and a trend reading plotted out on the computer screen on real-time.
5. The practical application of SpOUR data for the purpose of operational control should be developed.
6. A protocol for action should be developed if the SpOUR measurements reached some pre-set warning limit or showed a special trend.

#### **8.2.1 Selection of Appropriate Sampling Point**

In order to get a representative sample from the process stream, choosing a proper sampling location is very important. Figure 6 shows a schematic process flow diagram of the Gold Bar WWTP.

The 420 ML/d plant consists of primary and an air activated sludge biological treatment system. The plant not only treats domestic and industrial sewage from the City of Edmonton but also from the Strathcona Industrial and the residential Leduc - Beaumont areas due to a SWAP agreement with the smaller 90 ML/d Capital Regional Sewage Treatment Plant (CRSTP) located in the Clover Bar area.




Figure 6. Gold Bar WWTP process flow schematic.

The major sources of wastewater flow to the treatment plant can be classified as:

1. Domestic Wastewater: Wastewater discharged from residential source. According to Yee and Hettiaratchi (1989), 71.5% of the sewage comes from domestic source during the dry weather flow (DWF).
2. Industrial Wastewater: 24.8% of the DWF enters the Gold Bar WWTP in the form of industrial and commercial origin. Under the Sewer Bylaw #7118, the City of Edmonton allows certain types of industrial and commercial wastes to be discharged into the sanitary sewage system and the wastes are treated at the Gold Bar WWTP. Many of these discharges may contain pollutants that could have adverse effects on the normal operation of the wastewater treatment system.
3. Inflow and Infiltration: The dry weather flow (DWF) inflow and infiltration come from discharge from manholes, weeping tiles, cross connection from storm and combined sewers, surface runoff, defective pipes, and pipe joints.
4. Storm Water: Some of the storm water in the summer and snow melt in the spring go to the combined sewer and flow to the GBWWTP for treatment. The inflow and infiltration due to storm water can cause a major upset problem for the WWTP. During major storms, the

amount of water going into the WWTP increases significantly so that the activated sludge process may be upset due to the drastic decreases in organic loading but increases in hydraulic loading.

Initially, the same sampling location used by Aidun and Smith (1988) was selected (Figure 7, Legend 7-Aeration Tank) because the returned activated sludge (RAS), plumbing facilities and power were readily available. However, a 200m raw sewage pipe was required to deliver influent to that test location. Such a long sample line is expensive to construct. It can also give rise to plugging, excessive lag time and other maintenance problem. The sampling point had been later selected at the headworks building at the front gate of the plant due to the convenience of existing power and plumbing facilities. Figure 8 shows the detailed sampling location at the headworks of the Gold Bar WWTP. The headworks building is a temperature controlled building with a permanent auto-sampler inside collecting 24-hour composite plant influent on a flow proportional basis.

The building is located on top of the distribution chamber which mixes the raw influents coming from the two inlet conduits. The older conduit is a 2.29m x 1.98m concrete conduit while the newer one is 2.45m x 2.43m. The raw influents coming into the WWTP via the conduits mix in




Figure 7. Gold Bar WWTP layout.

## Raw Influent Sampling Point Location at the Headworks of GBWWTP




Figure 8. Raw influent sampling point location  
at the Headworks of GBWWTP.

a small distribution chamber. The mixed wastewater then branches into two channels each of which is equipped with a venturi flume to automatically measure and split flow proportional to the treatment capacity of the eight primary sections.

KMnO<sub>4</sub> is added at this point to control odour. There is also an eductor truck dumping station where all the non-hazardous liquid wastes that meet the City of Edmonton's Sewer Bylaw #7118 can be dumped at the location.

The waste activated sludge from the secondary sections and the digester supernatant are also discharged into the influent right after the sample building. The sample point selected was an existing piping adjacent to the plant's influent composite sampling point. This is the best location because:

1. It is located in the distribution chamber where influents are properly mixed.
2. The building's temperature is maintained at room temperature.
3. All electrical and plumbing fixtures are ready for use.
4. It can also pick up eductor truck's dumping if a sample is taken during the truck's unloading.

Together with the existing closed-circuit TV monitoring system, a better monitoring programme of

the Eductor truck dumping can be administered.

5. The sampling building can be locked so that unauthorized tampering of instrument and data is minimized.
6. It is the same building where the plant's regular influent composite samples are taken so that operator does not have to make a special trip to check and maintain apparatus if it is installed permanently.
7. It will give an average advance warning time of 1.5 hours depending on flow.

#### **8.2.2 Use of an Auto-Sampler to Obtain Raw Influent Sample**

Basically, Aidun and Smith's (1988) OUR apparatus (Figure 9) was used as an initial design protocol. In order to enable the unit to obtain the raw influent, a dependable commercial auto-sampler was used. The City of Edmonton Environmental Services Industrial Wastewater sampling group has been using auto-samplers since 1988 for monitoring wastewater samples. The unit used was a Streamline portable sampler manufactured by the American Sigma, Inc. (American Sigma, 1988). After careful consideration, the above sampler was selected for this project because of the following reasons:

1. Sampler was available for loan from the Wastewater Sampling Crew of the Gold Bar WWTP.
2. The ruggedness and dependability of the instrument




Figure 9. Schematic of OUR apparatus of Aidun and Smith (1988).

have been proven through years of usage.

3. Instrument could be easily adapted to suit this project's purpose. Interfacing with computer was simple and could be easily done.
4. It can automatically collect a desired amount of discrete sample in 24 individual bottles upon the command sent by the micro-controller unit (MCU) in the SpOUR apparatus.

The auto-sampler had been modified as shown in Figure 10. A sample splitter was added so that sample could be delivered evenly to both sampler and the OUR apparatus. A solenoid was also installed at the OUR sample line so that when the sample in the OUR apparatus reached a pre-designed volume, the solenoid would be closed and the rest of the raw influent would be directed to the sampler until the sampler stopped. In this way, an accurate amount of sample delivery to the OUR apparatus would be ensured.

The accuracy and precision of the sample volume being delivered to the SpOUR apparatus through this design were tested. The results for seven tests are as follows:

Design Volume (mL)	Actual Volume (mL)	Standard Deviation
400	405	5.2
600	599	3.9




Figure 10. Modification of auto-sampler.

Figure 11 shows the flowchart of the SpOUR operation. The whole concept of the test was to do a series of 25-minute cycles of aerating and mixing of the RAS to obtain the endogenous respiration rate ( $R_E$ ) and then using the same RAS repeat the process with the raw influent sample obtained on a real-time basis from an auto-sampler. Each test was run with a fresh sample of RAS and raw influent.

Figure 12 shows the schematic diagram of the complete SpOUR apparatus. At the start of the test, the SpOUR apparatus is in a ready mode with solenoids #1,2,3, and 4 closed, DC motor #1 on and #2 off. A command to start is keyed in by the operator as:

C:\HC11\DO2CON46

The computer will call up the software DO2CON version 4.6 in the subdirectory HC11 which will start off with programme to ask for operation instruction input from the operator as follows:

DO2 Data System

Version 4.6 Date June, 10/90

Enter Data File Name: (6 char., max.)?

900628

Enter Drive to Store Data (A,B,or C)?

C

Enter Run Number (0-99)?

0

Enter MLVSS in gm?




Figure 11. Flowchart of the SpOUR operation.




Figure 12. Schematic diagram of SpOUR apparatus.

2.2

Enter the Hour of the Day (24 hour clock)?

08

Enter the Minutes of the Day (24 hour clock)?

12

Enter the Day?

28

Enter the Month?

06

Enter the Year (90)?

90

Is This Time Correct (Y/N)?

Y

Enter COM Port (1 or 2)?

1

The message : "Sending STARTT command to DO2 System" will show up on the screen while the programme in the SpOUR micro-controller is initialized by the STARTT command from the host computer. All the operational commands of the SpOUR apparatus come from the software DO2VER13.S19 (which is a compiled version of the DO2VER13.C program developed by the Electronic Lab of the Department of Civil Engineering, University of Alberta) in the micro-controller while the host computer just waits to receive the dissolved oxygen and the temperature data.

At the command of STARTT, the micro-controller's DO2VER13.S19 program is initialized. Drain solenoid #3 (Figure 12) is turned on temporary for 10 seconds to drain any liquid that may still remain in the apparatus. Now RAS solenoid #1 is then turned on when solenoid #3 has closed. Returned activated sludge from RAS seed tank then flows into the testing chamber until the level sensor #1 has been reached. The level sensor can be calibrated to allow a predetermined amount of liquid entering the testing chamber. In this project 400 mL was the desired volume for the endogenous respiration rate determination. When 400 mL of RAS has been delivered to the mixing chamber, stirrer DC motor B as well as air supply solenoid #4 are turned on by the level sensor so that the activated sludge in the mixing chamber will be aerated and mixed for 4 minutes.

The mixing and aeration are to ensure the sample will have enough supply of oxygen level for later SpOUR testing. After the 4 minutes of aeration, air supply is shut off but the mixing still continues. The micro-controller then starts to collect DO and temperature data every 20 seconds for 30 readings (total reading time = 10 minutes). This length of time is needed to ensure the DO depletion is more than 2 mg/L during the endogenous respiration rate ( $R_E$ ) measurement.

After the  $R_E$  information has been obtained, the micro-controller unit sends a sampling signal to the auto-sampler.

Upon receiving the "wake-up" call, the auto-sampler is activated and carries out the pre-programmed functions of:

1. Purging the hose.
2. Sample a pre-calibrated amount of influent.
3. Purging the hose again when finished so that it is ready for the next sampling call.
4. Stores a portion of each raw influent in a discrete sample bottle.

When the auto-sampler is activated, solenoid #2 also opens simultaneously so that the influent is delivered equally to the sampler's sample bottle as well as the SpOUR apparatus. Level sensor #2 location has been pre-calibrated so that after 600 mL of influent has entered the apparatus, solenoid #2 will then close and the rest of the sample (approximately 600 mL also) goes to the sample bottle until the sampler goes off. This arrangement ensures that there is always exactly 600 mL of influent for testing while the sample container can collect the balance of the sample volume.

The mixture of RAS and influent is again aerated with continuous mixing for 4 minutes for optimum DO level. Recording of DO and temperature are then done every 10 seconds for 30 readings (total reading time = 5 minutes). These readings will all be stored in the appropriate temporary DO and temperature arrays and then dumped to the host computer via RS232 connection. The host computer then

assigns a file number to the arrays and calculates the slopes (by least square method) and the corresponding correlation coefficients with the SpOUR value. The SpOUR value is then plotted on the screen in real-time in the form of a strip chart (Figure 13). As a new SpOUR value is plotted, the previous 19 values will also be shown in a graph for comparison purposes so that any unusual trend can be detected easily.

Details of the DO2CON46.PMS and DO2VER13.C programmes are listed in the appendices A and B respectively.

When the sampler has finished taking 24 samples (in about 10 hours) the auto-sampler will then stop functioning until a new sample container is installed. The procedure for changing the sample container is listed in Appendix C.

### **8.2.3 Selection of DO probes**

Three types of good quality DO probes were available at the Gold Bar WWTP. They are:

1. YSI model #5750;
2. Leeds & Northrup (L & N) model #7931; and
3. Capital Controls Series 1865.

The YSI DO probe used by Aidun & Smith (1988) had the problem of easily tarnished anode electrode and a very fragile membrane that had to be replaced and maintained frequently.

## DO2 CONTROL SYSTEM

Present Time:17:41:51  
Start Time :17:25:33  
Run Time :00:16:38

Data will be stored in drive C:\90111020.PRN

Press [Esc] to Stop/Continue test after this run.

Slope1 = 1.0129991E-0.2  
Correlation Coefficient 1 = .9996148  
Slope2 = 2.726355E-0.2  
Correlation Coefficient 2 = .9996196

(SpOUR)

120

47.5

-25

SpOUR = 68.47

(Time)


Note: Items in ( ) do not appear on screen.

Figure 13. Readout on Screen During SpOUR Testing

A more reliable and durable DO probe was therefore needed for long-term automated monitoring. Upon investigation, it was found that there were two types of DO probes used for industrial application with which the Gold Bar WWTP had experience. One of these DO probes had been used to monitor the DO level of the mixed liquors at the secondary tanks for quite a long time. According to the service record, only minimal services were required through months of continuous usage even in the very hostile environment such as the activated sludge aeration tank.

The first DO probe is manufactured by Leeds & Northrup. This unit is specially designed for monitoring DO concentration in wastewater treatment. Basically the probe contains three sealed electrodes and a thermistor in a permanent electrolyte. Two electrodes are anode and cathode. The third one is a reference electrode whose primary function is to maintain the correct electro-chemical potential. Because the probe measures partial pressure of oxygen which changes with temperature, a thermistor is used to compensate such difference in feedback loop.

The principle of operation of the probe can be best described by the following reactions





---

Net result: Flow of electrons

When the probe is placed in the sample, oxygen diffuses through the membrane due to the tension created from the differences in oxygen concentration. This diffusion process continues until the oxygen tension on both sides of the membrane is equal and an equilibrium exists. The oxygen is reduced at the cathode as shown in equation (5). At the same time, an equal amount of oxygen is generated at the anode. The net result is a flow of electron current that is needed to maintain the equilibrium. The current flow will be directly proportional to the dissolved oxygen that is in the sample being tested.

The advantage of this probe is its sealed membrane and relatively free of fouling. Minimal maintenance has been experienced during the past years of usage by the Gold Bar WWTP. The only drawback is the turn-around time is extremely long if service is required.

The second DO probe that is now being evaluated by the staff of Gold Bar WWTP is a galvanic type with a lead anode and a perforated silver cylindrical cathode as manufactured by Capital Controls Company. The electrodes are surrounded with a gel bicarbonate electrolyte sealed by a polyethylene membrane. The physical design of oxygen diffusion is similar to the Leeds and Northrup probe but the electrochemical reaction at the anode is different.





#### Flow of electrons

At the anode, the reaction is a continuous consumption of the lead electrode and a continuous supply of oxygen is needed. Consequently, the cell will be "exhausted" between 18 to 20 months and the plug-in cartridge has to be replaced.

The YSI 5750 probe uses polarographic sensor with a gold cathode and a silver anode. A thin permeable membrane stretched over the sensor isolates the electrodes from outside.

The means of measurement is similar to L and N but YSI uses a thin permeable 0.025mm Teflon membrane. Such a membrane gives the probe an improved sensitivity but also renders the electrodes easier to be fouled and tarnished especially in the hostile environment like the activated sludge or raw sewage.

The simplified descriptions for the reactions at the electrodes are:



#### Flow of electrons

The final result is also a depletion of oxygen, the silver electrode and the chloride concentration of the electrolyte filling solution. The silver anode is also very sensitive to the sulphide that is present in the sewage sample. Periodic cleaning and refilling of the electrode are required in addition to the membrane fouling problem.

In order to select the most suitable probes, the factors of cost, sensitivity, durability, maintenance requirement, service, availability, and user's experience should be equally evaluated.

Based on past experience from Aidun and Smith (1988), the VSI probe had the problems of frequent membrane replacement and an easily tarnished electrode. According to the Gold Bar WWTP staff, Capital Control was only used on an experimental basis and its physical size was too big for the SpOUR unit. Leeds and Northrup probes had been used in the activated sludge tanks for years and had little maintenance problems except servicing was not very efficient.

A comparison test on the response time was done on the three probes (all probes were provided by Gold Bar WWTP).

YSI and L & N probes had been used but properly maintained, whereas the Capital Control probe was new. Figure 14 shows the comparison of the response time of the three types of DO probes. Both the Capital and YSI probes responded very quickly to the decrease of DO while L & N was slower. Even after cleaning and calibrating the probe, the response was still very sluggish. It was later found that the L & N probe was defective. Repair by L & N took about four months.

Test results after repair showed that the L and N probe was quite comparable to the YSI (Figure 15).

In order to calibrate the L and N DO meter output with the micro-controller unit (MCU) output, a calibration test was done by reading the DO values of the DO analog meter and recording the corresponding voltage outputs by the MCU. The calibration curve indicated that the DO values of the sample and the outputs were linear within the range of the experimental values as shown in Figure 16.

#### **8.2.4 Temperature Measurement:**

Temperature plays a key role in the oxygen uptake rate of the activated sludge. In accordance with the Arrhenius equation, the reaction velocity is increased by 2 to 3 times for every 10°C rise in temperature. Streeter and Phelps (1925) also suggested an empirical relationship of

## Comparison of YSI, L&N and Capital DO Probes




Figure 14. Comparison of YSI, L & N, and Capital DO probes.

## Comparison of YSI and L&N DO Probes (After repair)




Figure 15. Comparison of YSI and L & N DO probes (after repair).

## Calibration of DO Meter




Figure 16. Calibration of DO meter.

$$\frac{K_2}{K_1} = e^{C(T_2-T_1)} \quad (11)$$

Where:  $K_1$ ,  $K_2$  = reaction rate at  $T_1$  and  $T_2$  mg/(g.h)

$T_1$ ,  $T_2$  = temperature °C

C = constant (for activated sludge - 2.6

to 13.5% per °C)

It is obvious that a relatively constant temperature during the experiment is important for the precision of the OUR results. One solution to this is to blanket the testing apparatus with a constant temperature water bath. However, from the experimental data, the maximum temperature difference as measured by the built-in resistance temperature detector (RTD) was less than 1°C. This was much lower than the limits set by the OECD (1984) guideline of 2°C variance. A water bath was therefore not required in this particular design.

In order to ensure the temperature did not vary significantly during the course of testing, a RTD was used to monitor the temperature of the sample. RTD was chosen because of its stability and repeatability over a long period of time. The high signal output makes it ideal for interfacing with computer and reduces effect of interferences.

RTD is made up of a platinum resistor with a temperature coefficient of 0.00385 ohms/ohm/°C. It operates under the principle that the electrical resistance of platinum

increases or decreases in a repeatable and predictable manner with temperature changes. At 0°C temperature, the resistance is 100 ohms. By using an electronic system to keep the current at 1mA throughout the resistor, changes in resistance due to temperature change will cause a proportional increase or decrease in voltage output. The computer will record the voltage output as bits. By using various known temperature samples and recorded the corresponding voltage readings in bits, a calibration curve was constructed. Figure 17 shows the calibration of the RTD temperature probe. The relationship was linear over the temperature ranges of 5 to 35°C which were the normal ranges of the temperature of the samples during testing. Figure 18 shows the comparison result of the calibrated RTD readings versus a NBS (National Bureau of Standards, now known as National Institute of Standards and Technology) traceable certified thermometer's readings. This test showed the accuracy of the temperature measurements.

#### **8.2.5 Use of Mixed Liquor Volatile Suspended Solids (MLVSS) as Biomass Indicator**

A lot of experiments done by other researchers have reported OUR as mg O<sub>2</sub>/(L.h). No consideration is given to the amount of viable biomass in the sample. Such a measurement of relating microbiological activity with the substrate concentration may be misleading. A sludge with

## Calibration of RTD Using Certified thermometer




Figure 17. Calibration of RTD using certified thermometer.

# Comparison of RTD and NBS Thermometers




Figure 18. Comparison of RTD and NBS thermometers.

5,000 mg MLVSS/L and 1,000 mg MLVSS/L will have different OUR when tested with same substrate. This type of discrepancy can be eliminated by using specific SpOUR instead. Furthermore, use of SpOUR "standardizes" the measurement criteria and hence makes comparison easier and more meaningful. Advantages of using SpOUR were also cited by Duggan and Cleasby (1976).

The use of MLVSS to indicate active biomass is not without its shortcoming. A significant fraction of the volatile suspended solids are from inactive organics. Factors such as raw waste qualities, temperature, mean cell retention time can all affect the ratio of active to inactive solids. Weddle et al. (1974) and Patterson et al. (1970) suggested that only 10 to 20% of the conventional activated sludge was viable while McKinney (1962) estimated the ratio to be as high as 25 to 50%.

Other methods of enumerating viable mass such as plate counts, ATP or other enzymatic activities measurements had been investigated but none were as simple and easy to determine as MLVSS. Furthermore, MLVSS is a daily routine test done by the Gold Bar WWTP staff as a process control measurement. In this project, the determination of MLVSS was carried out in accordance to the Standard Methods (APHA, et al., 1989) Method #2540E. A slight modification in the filter paper was made to facilitate filtering the heavy sludge sample. The modified method had been tested and used

regularly at the Gold Bar WWTP for monitoring MLVSS.

#### **8.2.6 Order of Addition of SpOUR Samples**

The Paptapsco WWTP of Baltimore (Martin, 1988) had conducted a series of experiments to study the effect of various order of addition of sludge, food and toxicants on the outcome of the OUR results. Respirometers were used to test the effects of various combination of order of addition of solutions. The conclusion was the order of addition should make no difference in the OUR reading.

In this project, RAS was always tested first to measure the endogenous respiration rate before the sample of raw influent was introduced. In doing the toxicant test, the toxicant had been mixed with the raw influent first before the mixture was introduced to the testing chamber. In doing the calibration test, the synthetic standard reference was always mixed with the appropriate amount of deionized distilled water to the desired concentration before being tested.

#### **8.2.7 Effect of Mixing/Storage to RAS in Seed Tank**

A 25-L plastic container was used as a RAS seed tank to provide a uniform source of activated biomass for use in the SpOUR apparatus. This sludge was taken from the returned activated sludge line at the secondary tanks and was kept mixed, aerated and ready for use any time during the testing

period. The tank was covered to prevent any excessive loss of moisture. Since the activated sludge was pre-aerated for more than 12 hours before being used, the variability of the MLVSS was questioned. Five sets of duplicate analyses done on five different days were examined to investigate the effects of aeration on MLVSS values. Experiments done on the sludge taken from the tank outlet showed that after 12 to 19 hours of aeration, the range between the initial and the final MLVSS values was 4.3% with a standard deviation of 2.2%. This is well within the range of experiment error.

Microscopic examinations suggested by Brown and Nowak (1983) were also done on these sludge samples to monitor if there were any changes during the aeration and storage. No significant differences had been observed in both the speciation and percent population of the micro/macro faunae. The endogenous respiration rates of these stored sludge samples were in the range of 12 to 36 mg O<sub>2</sub>/(L.h) with an average value of 18 mg O<sub>2</sub>/(L.h). This is slightly higher than the value obtained by Hanel (1988) of 7 to 22 mg O<sub>2</sub>/(L.h), but agrees with the value of 18.4 mg O<sub>2</sub>/(L.h) given by Sollfrank and Gujer (1990).

#### **8.2.8 Aeration Rate and Time For SpOUR Apparatus and Seed Tank**

According to Aidun and Smith (1988) the optimum aeration time for the SpOUR apparatus was 4 minutes. Since the basic

physical design of this apparatus was very similar to that of Aidun and Smith (1988), no optimum aeration time testing was done. However, basing on experimental observation, the 4 minutes aeration time was adequate.

The aeration rate can also have effect on the physical properties of the sludge (Hanel, 1988). Vigorous aeration can cause shear and damage to the floc and hence affect the SpOUR reading. On the other hand, lower aeration rate will not provide enough oxygen to the sample within the 4 minutes aeration time.

An experiment was conducted to investigate the optimum rate of aeration by using different air flow rates and observing the time required for the sludge to attain a certain level of DO. Microscopic examination of the sludge was also done to observe if any significant physical damage to the floc was done.

The aeration air was provided by a 746 watt capacity portable air compressor which could provide a tank pressure of 552 kPa and had a regulator to adjust air supply. It was found that setting the regulator to provide the final air flow of 1 to 2 L/min at 138 kPa pressure gave the best aeration rate.

#### **8.2.9 Effect of Mixing**

During the testing of the SpOUR a stirrer was used to keep the sample constantly mixed. The main purpose of this

was to maintain a homogenous sample for the DO probe. The other benefit was to keep the solids from sinking to the bottom of the apparatus.

The speed of the stirrer was carefully controlled so that it would not overstir and cause any damage to the floc or re-introduce any air into the sample during testing.

An experiment was done to decide the best mixing rate for the stirrer. A stroboscope was not available to measure the exact RPM of the stirrer. However, by installing a speed control potentiometer on the stir motor, the mixing speed could be manually adjusted to set at the lowest speed at which no sedimentation of sludge and introduction of air were physically visible. Sludge was examined microscopically before and after 24 minutes of stirring. No significant difference in floc composition and microscopic count were observed.

#### **8.2.10 Development of More Efficient Computer Hardware and Software for the SpOUR apparatus**

At the Gold Bar WWTP, most of the computer usage was primarily in the area of process control and data acquisition. The plant's process control operation section and the laboratory section used computers independently. There was only a few process control units that could be linked with laboratory results via micro-computer to give the operational staff a real-time monitoring device.

After the successful development of an automated OUR apparatus by Aidun and Smith (1988), the beneficial combination of on-line laboratory microbial bioassay and computer to process control was clearly demonstrated. However, it was also immediately realized that such information would be more useful if obtained by monitoring SpOUR at various stages of the wastewater treatment process. In order to do so, several SpOUR units, each with a computer of its own, would be required.

It is very impractical and uneconomical to have so many individual computers each working on its own. The best solution is to have a host computer connected to each individual SpOUR unit strategically located at selected control points. Figure 19 shows the schematical layout of the connection. Each individual SpOUR unit will have a micro-controller unit (MCU) programmed to do just the required operations and sends back the collected data to the host computer via a RS-232 connection. In this way, only one computer is needed to do the controlling and data handling job.

#### **8.2.10.1 Computer Hardware Development**

Because of the limited memory of the Commodore PET computer that was used by Aidun and Smith's OUR Apparatus, the BASIC programme that the computer can process has become "primitive" compared to what is available nowadays. The




Figure 19. Schematic layout of SpOUR units with host computer.

Commodore PET computer is therefore not suitable for fulfilling the increasing requirement of the new SpOUR apparatus.

Since the 1980's, IBM-PC has become very common in the laboratory instrumentation and commercial fields. An inexpensive IBM-XT compatible computer had been chosen to demonstrate that only a minimal investment was required for this switch-over. The specification of the IBM-XT compatible computer is as follows :

- 100% IBM-XT compatible
- 640K Random Access Memory (RAM)
- 5 1/4" 360K External floppy drive
- 10 MByte Hard Drive
- Microsoft Disk Operation System (MS-DOS<sup>TM</sup>) V.3.3
- Monochrome graphic monitor

A computer of similar or better capacity is inexpensive and common in the laboratory or business world. At the Gold Bar WWTP, there were more than 10 computers of similar or better capacity being used in different areas of the plant.

Besides the computer switch, the most important part of the hardware revamp was the addition of a high density complimentary metal oxide semiconductor (HCMOS) micro-controller unit (MCU) model MC68HC11F1 manufactured by Motorola Inc. This MCU has 512 bytes of electrically erasable programmable read-only memory (EEPROM) and 8K of

RAM. This tiny chip of 25 mm x 25 mm has the memory capacity of storing the file needed for the operation of the SpOUR apparatus, temporary holding the data collected and sending them over to the host computer when the test has finished. One of the ways to enable this separation of duty from the host computer with the MCU is to have an efficient programming language which is the next stage of the SpOUR apparatus development.

#### **8.2.10.2 Software Development**

Once the computer had been chosen, the next stage was to select an appropriate computer language. Since BASIC (Beginners' All-Purpose Symbolic Instructional Code) is still one of the most commonly used languages for laboratory environment, the rewriting of the programme had been still centered on BASIC. BASIC was favoured because of its simplicity, wide acceptance, ease of use, and long history of user experience. The drawback of the older version of Commodore BASIC is its lack of speed and cumbersome commanding programme. Because of its usage of an interpreter, the micro-processor of the Commodore computer cannot directly execute the BASIC statement. Instead, the computer has to interpret each statement as it is executed. This line-by-line translation takes place every time the programme is used. Consequently, the speed of execution

suffers.

Alternatively, a compiler can be used to convert the whole BASIC programme in machine language before use. The disadvantage of using such compilation is a lot of time is required in creating an error-free programme. Every time a bug is found in the programme, a correction has to be made on the original file and recompiled. Such an experience has been the nightmare of many programmers.

In this project, a new version of BASIC was used to deal with this programming problem. The programme is called MicroSoft QuickBASIC™ (Version 4) which is specifically designed for IBM-PC and PC-compatible computers. It combines the immediate interactive strength of the interpretive BASIC and the efficiency and speed of the compiler BASIC.

The simplicity of the programme can be seen from the few lines of codes required compared to otherwise written in other types of BASIC languages. Furthermore, the programme is very user-friendly so that people without much programming knowledge can easily make the necessary correctional changes on the programme.

Programme DO2CON46 was written in QUICKBASIC to start the apparatus, open new files for raw data, collect data, calculate slopes with statistical results, plot SpOUR in real-time and store the final results in a summary file.

For the operation of the apparatus itself another efficient and powerful high-level language called C was

used. C is the shorthand version of the assembly language. The number of statements and functions required in C is very small but the execution speed is very fast. After compilation the entire compiled programme for carrying out the required SpOUR operation can be stored in the MCU in less than 2K memory space. The simplicity of the programme can also be seen from the ease of making changes such as the delay on/off time of the solenoids and motors, the length and number of the DO readings etc.

The programme DO2VER13.C was written in C language for the operation of the SpOUR unit by the MCU. A small C compiler programme SMC11.EXE and HC11 optimizer were used to compile and optimize DO2VER13.C to a DO2VER13.S19 compiled file which was then sent to the MCU memory via EELOAD3.EXE and E1PROGIX.BIN programmes. Once the DO2VER13.S19 has been downloaded to the MCU memory, the programme can be retained up to 10 years. Programmes DO2CON46 and DO2VER13.C are listed in the Appendix A and Appendix B respectively. All the other relevant programmes are listed in the Appendix D.

All these downloadings are done through the serial RS-232 interface. The proper downloading procedure is shown in Appendix E. It is important that the exact downloading procedure is followed in order to assure the proper operation of the apparatus.

The general flowchart of the SpOUR apparatus software is listed in Figure 20. When the host computer is turned on and




Figure 20. Flowchart of SpOUR apparatus software.

the file DO2CON46 is loaded, the dimensions of the various data arrays are set and memory storage location allocated. A series of vital information are required from the operator to input before the apparatus will begin operation through the sub-routines STARTT, PORT.

Once the hand-shaking of the host computer and the MCU has completed the SpOUR apparatus will start operation according to the programme DO2VER13.C.

### **8.3 Construction Process**

The apparatus was built with the idea of providing a dependable and easy to use on-line monitoring equipment for the wastewater treatment plants. Due to the possible harsh environment that could happen at the sampling site, the following special requirements and precautions were made:

- Heavy industrial grade framework for the apparatus was used so that it could withstand the rough wastewater treatment plant environment.
- Industrial standards for electrical wiring was used for added safety.
- Optical isolators were used for the MCU to prevent electrical spiking and interferences to the computer unit.
- Use of a heavy duty industrial auto-sampler to ensure a dependable source of samples.
- Use of the L & N DO probe which had been proven to

require only minimal maintenance.

77

-Water and moisture-proof for the entire electronic portion of the apparatus.

-RTD and liquid level sensors were all made of stainless steel and coated with plastic except the necessary portions to prevent rusting and short-circuiting.

-Industrial-type solenoid valves were used for long lasting operation.

-Stirrer coupler bearing was sealed with O-ring to prevent moisture entering the bearing.

-Use of a very long RS232 line so that host computer could be separated from the harsh environment in which the SpOUR apparatus was located.

-Apparatus was put on a sliding trolley for easy movement during maintenance.

-DO probe, liquor level indicators, mixing motor and stirrer were designed so that they could be replaced easily.

#### **8.4 Start-up and Debugging During Trial Run**

Series of changes were done on the software during the debugging period. The apparatus software had changed from version 1.0 to version 1.3 while the data handling software for the host computer had been altered from version 1.0 to version 4.6. All these changes were performed to improve the apparatus to a real turn-key instrument for the operators.

Figure 21 shows the set-up of the completed SpOUR apparatus at the headworks of the Gold Bar WWTP. Figure 22 shows the SpOUR apparatus sample chamber.

During the startup of the apparatus, several mechanical problems were noticed :

-The stirrer motor overheated during the test run and burned the 1 Amp fuse. It was found that wastewater had splashed into the bearing and eventually seized the shaft of the motor. A rubber ring with sealing cream was added together with a sealed bearing to prevent such a seizure. Aluminum heat sink was also added to the transistor to help dissipate the heat generated. A variable resistor was also installed to control motor speed so that motor would not overheat but still maintained a satisfactory mixing.

-The solenoid for the drain pipe was clogged with debris for many times causing some missing data. Several attempts were made to solve the problem. These included using an on-line strainer to prevent clogging, flushing the container after each test run, and change new solenoid. No perfect solution was found. However, when the solenoid was installed vertically instead of horizontally, the debris tended to be flushed away easier and faster. Similar solenoids installed in GBWWTP at the returned activated sludge outlets are all installed in a



Figure 21. Picture of the completed SpOUR apparatus



Figure 22. Picture of the SpOUR apparatus sample chamber

vertical position and have no serious clogging problems. Nevertheless, routine checking and maintaining of the solenoid are strongly recommended even if the solenoids are installed vertically.

-Although the DO meter had been performing satisfactorily, the accuracy of the data had been affected by the occasional coating of the sensor by the oil and grease or sometimes the sticky organic scum formed from aeration. Such coating caused the oxygen sensor slow to respond to DO changes and thus produced erroneous results. The solution to this was to check the probe more frequently and to set up a good preventive maintenance program. A spare DO probe should always be ready to replace one that malfunctions. The apparatus may also require a slight modification to allow a quick changeover of the new probe. At Gold Bar WWTP, the SpOUR apparatus is located next to the plant's raw influent composite sampler. Since the operators do routinely check the composite sampler, this extra monitoring of the SpOUR DO probe will not be a burden if it was installed as a permanent monitoring apparatus.

Although the OUR of the activated sludge process is proven to be of a predictable diurnal nature, the inhibitory or toxic characteristics of the raw influent are expected to

be sporadic.

In order to develop some relationship of the inhibitory action of the toxicants on the SpOUR data, various known concentrations of the selected toxicants were added as spike with the regular samples. Percent reductions in SpOUR versus concentrations of toxicants added were recorded together with the derived EC<sub>50</sub> values. Such information will become the database for future reference. This experiment also showed that the apparatus is sensitive to various levels of toxicants on a single chemical basis. The effects of mixture of toxicants were not investigated in this particular test. Details and results of the tests are discussed in Section 8.6.1.

Another preliminary test that had been done before the start-up was to confirm that the SpOUR obtained was due to the metabolic activities of the microorganisms only. Several blank runs (ie, deionized distilled water was used instead of raw influent) were done and the average SpOUR value obtained was 3.0 mg O<sub>2</sub>/ (g.h). To further show that SpOUR was not due to any other physical or chemical demand, a test with only tap water (ie, tap water was used instead of RAS and raw influent) was done, and a SpOUR reading of 0.15 mg O<sub>2</sub>/ (g.h) was obtained.

To check the accuracy and precision of the apparatus, parallel runs were done with the same source of raw influent and RAS using both the SpOUR apparatus and Standard Methods

(APHA, et al., 1989). Results obtained from these different methods were done in two separate days as shown in Table 3.

According to OECD (1984), the two control runs should be within fifteen percent of each other for a valid comparison. Also, using the modified statistical t-test (NBS Handbook 91, 1966) at a confident level of 99.0%, there is no reason to believe that the two sets of data listed in Table 3 are different. Furthermore, using L and N DO probe on the SpOUR apparatus also gave lower standard deviation because data collected are done by computer and is therefore more precise.

From the above comparison results, the SpOUR apparatus data are therefore equivalent to those obtained by using the Standard Methods (APHA, et al., 1989).

Another possible factor that could affect the data is nitrification. Activated sludge contains a mixture of microfauna with heterotrophic and autotrophic microorganisms. The aerobic heterotrophs obtain their energy from the oxidation of organic compounds using oxygen as their terminal electron acceptor.

Some autotrophs, on the other hand, utilize CO<sub>2</sub> as the C source and NH<sub>4</sub><sup>+</sup> as the overall electron donor. The bacteria involved are





TABLE 3.

Comparison of OUR obtained by Standard Methods (APHA, et al., 1989) and SpOUR apparatus.

	OUR mg O <sub>2</sub> /h Method Used	No. of replicates	
Sample A	Std. Methods	SpOUR apparatus	
RAS	27.6 SD = 0.3	28.0 SD = 0.4	3
RAS + RAW	47.5 SD = 1.0	43.3 SD = 0.7	3
Calculated SpOUR mg O <sub>2</sub> /(g.h)	46.3 SD = 1.3	40.9 SD = 1.1	3
Sample B			
RAS	26.4 SD = 2.4	28.0 SD = 0.9	10
RAS + RAW	122.4 SD = 6.7	126.4 SD = 4.5	10
Calculated SpOUR mg O <sub>2</sub> /(g.h)	107.5 SD = 7.0	110.8 SD = 4.4	10

RAS = Returned Activated Sludge

RAW = Raw Influent

SpOUR = Specific Oxygen Uptake Rate, mg O<sub>2</sub>/(g.h)

SD = Standard Deviation

The amount of oxygen required by these nitrifiers was clearly demonstrated by Sollfrank and Gujer (1990). In their study, a laboratory-scale WWTP was at endogenous respiration of 0.6 mg O<sub>2</sub>/(L.min.). A dose of ammonium (28 mg NH<sub>4</sub><sup>+</sup>-N) was spiked into the aeration basin. The OUR rose immediately to 1 mg O<sub>2</sub>/(L.min.) indicating extra oxygen was needed to convert the ammonium to oxidized nitrogen.

In Aidun's experiments (Aidun, 1986), he also noticed that OUR reading was higher during the hot summer months than the colder spring period. One of the reasons may be due to the greater activity of nitrifying bacteria during the hot summer months. Duggan & Cleasby (1976) had also indicated the effect of nitrification and other variations in oxygen uptake measurement. A safety factor of 1.2 to 1.5 was suggested to compensate such effects.

A concern was therefore raised during the initial design of the SpOUR apparatus in regard to the effect of the nitrifying bacteria to the accuracy of SpOUR measurement.

A laboratory test was done to investigate this problem. NO<sub>2</sub><sup>-</sup>-N, NO<sub>3</sub><sup>-</sup>-N, and NH<sub>4</sub><sup>+</sup>-N values were determined on the following samples: RAS, RAS (after aerated for 20 h), RAW, and RAS + RAW (after aerated for 4 min).

The results are shown in Table 4 and indicate that after 20 h of aeration, a significant amount of NO<sub>2</sub><sup>-</sup>-N and NO<sub>3</sub><sup>-</sup>-N were formed. However, since the aerated RAS already

TABLE 4.

**Effect of Nitrifying Bacteria on Various Types of  
Wasterwater Samples**

Sample	NO <sub>2</sub> <sup>-</sup> -N (mg/L)	NO <sub>3</sub> <sup>-</sup> -N (mg/L)	NH <sub>4</sub> <sup>+</sup> -N (mg/L)
RAS	0.060	1.135	24.28
RAS (after 24 h Aeration)	11.63	14.18	17.30
RAW	0.007	0.109	17.40
RAS + RAW (after 4 min aeration)	4.431	7.702	16.99
RAS + RAW + N-inhibitor	4.092	6.171	24.28

had quite a high  $\text{NH}_4^+ \text{-N}$  content after aeration, the addition of raw sewage would not produce such a profound effect on SpOUR as was demonstrated by Sollfrank and Gujer (1990). A similar experiment done by Huang et al. (1985) indicated that the OUR by nitrification was "relatively insignificant".

In summary, the results showed that:

-RAS contained high level of  $\text{NH}_4^+ \text{-N}$  by itself and considerable amount of  $\text{NO}_2^- \text{-N}$  and  $\text{NO}_3^- \text{-N}$  were produced during the 20 hours of aeration indicating high level of nitrification activity already existed before the SpOUR determination.

-When RAS and raw influent were mixed, no significant amount of extra oxidized nitrogen occurred indicating the extra nitrification reaction in this SpOUR test was not as profound and instantaneous as reported by Sollfrank and Gujer (1990). This can be partially explained by the long generation time for *Nitrosomonas* (31.6 h) and *Nitrobacter* (23.1 h) respectively.

-When N-inhibitor was added, a slight curbing of nitrification was suspected.

Hence, extra nitrification oxygen demand due to nitrifying bacteria was not as significant as had been suspected.

### **8.5 Final Testing Run For The Completed Unit**

A final test run was done during the period of June 28 to Sept. 1, 1990 . During the 9 weeks continuous of testing, a total of 2998 individual tests were done with a total of 2.2 megabytes of raw data collected.

The apparatus ran and recorded data continuously and automatically except during data retrieval and scheduled and unscheduled maintenance. During the close to three thousand tests performed, there were 29 incidents of malfunctioning and thus some data were missing. The summary of the malfunctions is as follow:

- 9 incidents of solenoid leakage due to debris blocking valve.
- 5 incidents of DO probe malfunctioning due to oil and grease or scum coating the oxygen sensor.
- 5 incidents of auto-sampler malfunction.
- 3 incidents of raw influent level too low.
- 1 incident of computer problem.
- 6 incidents of miscellaneous problems.

The ratio of successful runs versus malfunctioning is 99:1. With the implementation of the new vertical arrangement of solenoid and regular maintenance programme on the DO probe, the frequency of malfunctioning is expected to be even lower.

An example of the raw data file (called the PRN file)

obtained from each individual test is shown in Appendix F. The daily summary file (called the COF file) is shown in Appendix G.

A typical plot of DO readings versus time for both endogenous and sample mixture runs is shown in Figure 23. The slopes obtained were then used for calculating the SpOUR. Appendix H shows the summary of the 3000 tests done during June 28 to Sept. 1, 1990. The SpOUR versus time were also plotted as shown in Appendix I to monitor trends.

Judging from the diagrams of the daily SpOUR versus time plots, the raw influent entering the wastewater treatment plant is constantly changing in strength as indicated by the fluctuating SpOUR values (Figure 24). However, a slight daily diurnal pattern can still be observed. SpOUR values increase from noon to midnight and reach their lowest values in the morning. The weekly patterns of low SpOUR during Saturday and Sunday, and high SpOUR values during weekdays are also apparent. Application of these observations will be discussed in the section 8.6.

#### **8.6 Development of Practical Applications For The Apparatus**

In order to develop some practical applications for the SpOUR apparatus, experiments were conducted to investigate the various possible uses of the apparatus. Some of the more interesting possible applications of the SpOUR apparatus are

## Typical Oxygen Uptake Rate Using SpOUR Apparatus




Figure 23. Typical OUR using SpOUR apparatus.

# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




Figure 24. Example of SpOUR monitoring at Gold Bar WWTP.

the monitoring of the toxicity of the influent, rapid BOD, prediction, tolerability studying, and F : M ratio etc.

#### **8.6.1 Monitoring of Toxicity**

Tests were done to determine the sensitivity of the SpOUR apparatus and its relationship with other types of toxicity testing procedures. The testing method used was a modified synthetic activated sludge technique from Kwan (1988). All tests were conducted in triplicates except otherwise specified. The toxicants selected were chromium ( $K_2CrO_4$ ), lead ( $Pb(NO_3)_2$ ), zinc ( $ZnSO_4 \cdot 7H_2O$ ), 2,4-Dichlorophenol(2,4-DCP), and 3,5-Dichlorophenol(3,5-DCP). Each toxicant was examined at a minimum of 3 different concentrations, each one logarithm apart, i.e. 0.1 mg/L, 1 mg/L, 10 mg/L, 100 mg/L. Preparation of the metal solutions was done by first dissolving the proper amount of metal salt in distilled water to make a 10,000 mg/L stock solution. Appropriate amount of metal stock solution was then added to the sample to make the desired metal concentration. Preparation of the chlorinated phenol solutions was made as described by OECD (1984).

To test each toxicant, 400 mL of RAS had first been run for endogenous respiration rate (OUR1), 600 mL of reference raw influent plus toxicant was then added to test the OUR (OUR2). SpOUR was then calculated according to the formula:

$$\text{SpOUR} = \frac{2.5(\text{OUR2}) - (\text{OUR1})}{\text{MLVSS}} \quad (12)$$

2.5 = Dilution factor

The percent ratio of the SpOUR with toxicant and the regular uninhibited sample as control can be expressed as:

$$\%R = \frac{\text{SpOUR}_T}{\text{SpOUR}_B} \times 100\% \quad (13)$$

$\%R$  = Percent SpOUR when under a specific amount of toxicant

$\text{SpOUR}_T$  = Specific oxygen uptake rate of control + toxicant, mg O<sub>2</sub>/(g.h).

$\text{SpOUR}_B$  = Specific oxygen uptake rate of control, mg O<sub>2</sub>/(g.h.).

By plotting the corresponding  $\%R$  versus the different concentrations of the toxicant in a semi-log graph paper, the EC<sub>50</sub> (i.e. the inhibition concentration of a toxicant that will decrease the SpOUR by 50% under the specific testing conditions using the SpOUR apparatus) value can be obtained.

Figures 25 to 29 show the EC<sub>50</sub> graphs for Pb, Cr, Zn, 2,4-DCP, and 3,5-DCP respectively. When a comparison of the EC<sub>50</sub> values obtained from the SpOUR apparatus was done with the other literature values, a slightly higher EC<sub>50</sub> values were obtained from the SpOUR apparatus (Table 5). This was

# EC50 of Pb Using SpOUR Apparatus and RAS+RAW




Figure 25. EC50 of Pb using SpOUR apparatus and RAS+RAW.

# EC50 of Cr<sup>3+</sup> Using SpOUR Apparatus and RAS+RAW




Figure 26. EC50 of Cr<sup>3+</sup> using SpOUR apparatus and RAS+RAW.

# EC<sub>50</sub> of Zn Using SpOUR Apparatus and RAS+RAW




Figure 27. EC<sub>50</sub> of Zn using SpOUR apparatus and RAS+RAW.

## EC50 of 2,4-Dichlorophenol Using SpOUR Apparatus and RAS+RAW




Figure 28. EC50 of 2,4 DCP using SpOUR apparatus and RAS+RAW.

# EC50 of 3,5 Dichlorophenol (3,5-DCP) Using SpOUR Apparatus and RAS+RAW

RAS=Returned Activated Sludge  
RAW=Raw Influent




Figure 29. EC50 of 3,5 DCP using SpOUR apparatus and RAS+RAW.

TABLE 5

Comparison of EC50 Values for Cr (3+), Pb, Zn, 2,4-DCP, 3,5-DCP.

Toxicant	Literature Value (mg/L)	Experimental Value (mg/L)
Cr (3+)	N/A	N/A
Pb	350 <sup>a</sup>	200
Zn	1.2 <sup>a</sup> 6.1 <sup>c</sup>	30
2,4-DCP	N/A	10
3,5-DCP	30.2 <sup>a</sup> 6-20 <sup>b</sup> 38 <sup>c</sup>	40

<sup>a</sup> Dutka and Kwan (1984)

<sup>b</sup> Volskay and Grady (1989)

<sup>c</sup> Dutka et al. (1983)

N/A = Not Available

probably due to the shorter time used for testing compared to the 3 hours standard time recommended by the OECD (1984), and the mixed activated sludge was used instead of a pure cultivated culture. Another possible cause was the use of a real raw sewage as a background reference rather than synthetic sewage. In spite of that, the sensitivity of the SpOUR apparatus for toxicant is still very comparable to other methods of microbial-bioassay.

The conditions for the validity of the test have been set by OECD (1984) as:

- The 2 control respiration rates are within 15% of each other.
- The EC<sub>50</sub> (3 h) of 3,5-DCP is in the range of 5 to 30 mg/L.

These two conditions set by OECD (1984) were also very closely monitored during the testing period. The "15%" criterion was followed but the 3,5-DCP value obtained was slightly higher than specified due to the reasons explained above.

A microscopic examination using the activated sludge analysis method presently used by the Gold Bar WWTP laboratory was also done after each toxicity test to confirm the SpOUR reading. The examination was a modified method used by Himebaugh (1981) for a microscopic evaluation of the

activated sludge. According to the Gold Bar WWTP data, for a healthy activated sludge, the percentage of the following four groups of microorganisms should be as follow:

- (a) amoebic < 10% ;
- (b) flagellates < 10% ;
- (c) free swimming ciliates 40 to 60% ;and
- (d) stalked ciliates & rotifers 20 to 50% .

Any abrupt changes in composition or number indicate changes in sludge conditions such as toxic material present, lack of oxygen or food supply. A very close relationship was observed between the EC<sub>50</sub> and the result of the microscopic examination during the experiment. Figure 30 shows the photographic picture of the sludge before toxicant was added. Figure 31 shows the breaking up of the floc after the addition of toxicant at concentration above the EC<sub>50</sub> value.

Together with the microscopic examination (as effects identification tool) and other appropriate supplementary chemical tests (as cause identification tool), the SpOUR is a very promising method for toxicity monitoring in the wastewater treatment plant environment.

#### 8.6.2. Rapid BOD<sub>5</sub> prediction

The BOD<sub>5</sub> test is one of the most important treatment



Figure 30. Picture of the RAS before toxicant was added.  
(eye piece x objective power = 125).




Figure 31. Picture of the RAS after toxicant was added.  
(eye piece x objective power = 125).

plant performance indicators used by the various regulatory agencies to determine compliance with pollutant discharge elimination system licence requirement. However, since the test requires a five-day incubation period, a wastewater treatment plant can conceivably be in a poor performance period without the management knowing for five days. Also, if there is any change in the raw influent property in terms of  $BOD_5$ , it would be ideal for the operator to know in advance so that appropriate actions can be implemented to obtain the maximum treatment efficiency.

There are many reports of experiments done to predict  $BOD_5$  value by the use of the OUR. As early as 1928, respirometer was used to predict  $BOD$  values (Sierp, 1928). Through years of subsequent studies, improved methods have been developed. More recently, Nichols (1982) had demonstrated that influent  $BOD_5$  could be predicted with an accuracy index of 5% by using the OUR method.

Therien and Ilhan (1983) had proposed a Michaelis-Menten relationship of

$$R_i^* = \frac{C_3 * BOD_5^*}{C_4 + BOD_5^*} \quad (14)$$

$R_i^*$  = OUR/Biomass related parameter, eg. MLVSS

$BOD_5^*$  =  $BOD_5$ /Biomass related parameter, eg. MLVSS

$C_3$ ,  $C_4$  = constants

In addition, they had shown that a linear relationship

is observed when biomass is not limiting the assimilation process. The relationship could be expressed as:

$$R_i^* = C_1 * BOD_s^* + C_2 \quad (15)$$

$C_1, C_2$  = constants

Values of  $C_1 = 0.19865 \text{ l/h}$

$C_2 = 0.00053 \text{ mg O}_2 / (\text{g.h})$

$C_3 = 0.06038 \text{ mg O}_2 / (\text{g.h})$

$C_4 = 0.2357 \text{ mg O}_2 / \text{g}$

were reported for the specific wastewater treatment plant that they had tested.

By using the SpOUR apparatus, an attempt was done to investigate the possibility of predicting the  $BOD_s$  of the raw influent. Split raw influent samples that had been saved by the auto-sampler during the trial run period were randomly tested for  $BOD_s$  using the Standard Methods (APHA, et al., 1989). The corresponding SpOUR values were recorded and studied for any correlation with the  $BOD_s$  values. After 170 individual comparisons using linear, polynomial, logarithmic, and exponent plots were done, low but significant values of correlation coefficients were obtained. Figure 32 shows an example of such linear plot, a  $R$  value of 0.455 was obtained indicating significant linear relationship between the  $BOD_s$  and SpOUR values as indicated by equation (15).

## SpOUR Versus BOD<sub>5</sub> ( significant correlation found)




Figure 32. Linear plot of SpOUR versus BOD<sub>5</sub> ( Significant correlation found )

An attempt was also tried to study the response of the microbial population in the returned activated sludge to the synthetic substrate during the SpOUR measurement. BOD, reference solution was prepared as follow (Standard Methods, APHA, et al., 1989. Method #5210.B):

150 mg glucose

150 mg glutamic acid

1 mL Phosphate buffer (8.5 g KH<sub>2</sub>PO<sub>4</sub> + 21.75 g K<sub>2</sub>HPO<sub>4</sub>, + 33.4 g Na<sub>2</sub>HPO<sub>4</sub>.7H<sub>2</sub>O + 1.7 g NH<sub>4</sub>Cl dissolved in 1L of deionized distilled water.)

27.5 mg CaCl<sub>2</sub>

0.25 mg FeCl<sub>3</sub>.6H<sub>2</sub>O

22.5 mg MgSO<sub>4</sub>.7H<sub>2</sub>O

dissolved in 1 L of deionized distilled water. For higher substrate concentrations, larger amounts of glucose, glutamic acid and other trace nutrients were added accordingly but the phosphate buffer was not. The SpOUR apparatus was then run with different concentrations of the BOD, reference solutions added as raw influent.

The SpOUR values versus various concentrations of BOD, references obtained are shown in Figure 33. A negative SpOUR was obtained with increasing value of the references i.e. sample added was inhibitory. The reasons for this phenomenon are due to:

## RAS+BOD Ref Std Vs SpOUR Without adjusting pH




Figure 33. RAS+BOD reference standard versus SpOUR (without adjusting pH).

-pH of the sample added was inhibitory due to the glutamic acid added. Slight buffering capability of the RAS was able to handle the acidity due to small dose of glutamic acid such as 150 mg/L. However, higher concentrations of glutamic acid started to lower the pH of the sample down to 3.5 so that the respiratory activities of the microorganisms were affected. This test shows the sensitivity of the SpOUR test to low pH samples. The low pH was probably due to the inadequate amount of the phosphate buffer solution being added to the test sample.

-When the pH of the reference had been adjusted to 7, the tests were repeated. The results of the tests are shown in Figure 34. The SpOUR increased slowly but linearly with increases in reference concentrations up to 600 mg/L and then declined. Duggan and Cleasby (1976) had also investigated this effect and explained that if a microbial population was in endogenous respiration for an extended period of time, they used substrate reserve such as glycogen and protein for metabolism. A sudden injection of large quantity of glucose could inhibit the enzyme of the citric acid cycle and caused an inhibition of respiration according to the Haldane relationship of:

## RAS+BOD Ref Std Vs SpOUR (With pH Adjustment to 7)




Figure 34. RAS+BOD reference standard versus SpOUR (with pH adjustment to 7).

$$U = \frac{U_{\max} S}{K_s + S + S^2/K_i} \quad (16)$$

$U$  = SpOUR, mg O<sub>2</sub>/ (g.h).

$U_{\max}$  = Maximum SpOUR, mg O<sub>2</sub>/ (g.h).

$S$  = Substrate concentration, mg BOD/L

$K_s$  = Maximum saturation constant, mg BOD/L

$K_i$  = Inhibition constant, mg BOD/L

A small numerical value for the  $K_i$  indicates greater inhibition or toxic effect. With a toxic or inhibitory substance, an increase in substrate concentration results in increased SpOUR activity over a limited range. After the critical substrate concentration, the inhibitory effect of the substrate causes a decrease in SpOUR. This effect was also described by Hanel (1988) as the "Crabtree Effect".

A second experiment was then done with the synthetic reference sewage recommended by OECD (1984) and Kwan (1988). The following amounts of substances were dissolved in 1 L of deionized distilled water:

16.0 g Peptone

11.0 g Beef Extract

3.0 g Urea

0.7 g NaCl

0.4 g CaCl<sub>2</sub>.2H<sub>2</sub>O

0.2 g MgSO<sub>4</sub>.7H<sub>2</sub>O

2.8 g K<sub>2</sub>HPO<sub>4</sub>

pH = 7.5

Various concentrations of the synthetic reference sewage were used for SpOUR testing with the RAS from activated sludge seed tank. The strength of the synthetic reference sewage added was measured separately by COD and BOD.

Results of the experiment (Figure 35) show the responses of SpOUR versus various synthetic sewage strengths follow the classical Michaelis-Menten relationship shown in equation (3) for both BOD and COD. This relationship has been demonstrated by many other reports (Vargas-Lopez 1989; Therien and Ilhan 1983; Huang and Cheng 1984). By applying the Lineweaver - Burk relationship, a linear plot of 1/SpOUR versus 1/BOD, was obtained with R = 0.999 (Figure 36). From equation (4), the U<sub>m</sub><sup>0</sup> obtained was 710 mg O<sub>2</sub>/(g.h) and K<sup>0</sup> = 113 mg BOD/L. When this relationship is used to relate some of the raw influent samples using the same testing condition, a good prediction of influent's BOD is obtained (Figure 37). However, when the above results are used to compare other batches of SpOUR results using different source of RAS, poor correlation occurs. This phenomenon may be due to the many variables that can affect the SpOUR data. Some of these variables are the physiological state of the RAS, the amount of mixing, pH, concentration of solids, temperature, presence of nitrifying bacteria, wastes

## Calibration of SpOUR With synthetic sewage




Figure 35. Calibration of SpOUR with synthetic sewage.




Figure 36. Linear plot of  $1/\text{SpOUR}$  versus  $1/\text{BOD}_5$ .

## Prediction of BOD<sub>5</sub> of Raw Influent Samples by SpOUR Values




Figure 37. Prediction of BOD<sub>5</sub> of raw influent samples by SpOUR values.

composition, presence of toxic materials, etc.

The lack of a standardized method that would take account of all the variables mentioned is probably the major reason for the highly fluctuating data obtained when a correlation of the individual BOD and SpOUR is attempted.

It is therefore advisable to run a calibration run with various concentrations of synthetic reference solutions before using each batch of the RAS from the seed tank. Once the relationship of the SpOUR versus BOD of a particular batch of RAS has been determined, the subsequent SpOUR data using the same RAS can be used for prediction of the BOD of the raw influent more accurately. Figure 38 shows that when the daily average SpOUR value of a particular batch of a RAS seed is plotted against the BOD of the same day's composite raw influent sample, a very close relationship is observed. The weekly diurnal fluctuation of the BOD values matched closely with the corresponding SpOUR data. Such a relationship can also be used to obtain a more realistic prediction of the BOD of the daily raw influent composite sample. A computer programme can also be added to calculate such predicted BOD values on a real-time basis with a certain degree of confidence when enough data-base has been developed.

Use of an automated instrument and a much larger sample size also help reduce the data variability and cut down labour requirement. The other advantage that can be seen is

# BOD Vs SpOUR

## Daily Raw Composite




Figure 38.  $BOD_5$  versus SpOUR (daily raw composite).

the more accurate prediction of the oxygen requirement in the aeration treatment process because nitrification oxygen demand can also be calculated from the data obtained.

Together with a good maintenance program to ensure other important areas such as DO probes, solenoid valves are all functioning properly, the SpO<sub>2</sub> monitoring can be a great tool for WWTP process control.

#### **8.6.3 Tolerability Study**

According to Yee and Hettiaratchi (1989), eductor truck dumping has been one of the areas where more screening and monitoring are required. Every day 375,000 L or more of the industrial and commercial liquid wastes are disposed at the Gold Bar WWTP. Due to the increasing tightening of the effluent quality requirement, Gold Bar WWTP has initiated an eductor truck monitoring programme. Wastewater transported by the eductor truck has to obtain permit and manifest before being allowed to discharge the load at the two selected sites in Edmonton. At the present, only pH screen and periodic monthly spot-checks are done on selected samples as a monitoring measure. Such testings are inadequate to prevent any toxic loadings entering the treatment system. Upsets can easily occur if these liquid wastes contain any mixtures that are toxic or inhibitory to the activated sludge.

Many screening tests have been developed by the

laboratory staff of the Gold Bar WWTP to provide a quick, on-the-spot checking on the liquid wastes delivered by the haulers. However, these tests are either too specific or too time consuming. Most of the time, due to the complex nature of the matrix, interferences mask the determination of the desired constituents. The advantage of using SpOUR for checking the toxicity or the tolerability of the activated sludge to such liquid wastes over the other methods are:

- it is generally not affected by any colour, turbidity or other physical properties that would usually mask the results of other chemical screening tests;
- it takes only five to ten minutes to test if the endogenous respiration rate is predetermined;
- its result tells the direct impact of the wastes to the microbial population in the secondary tanks;
- it does not require any special skills for performing the screening test;
- it is "reagentless" and costs very little to test.

The only thing that has to be cautioned is the waste should not contain any chemicals that will use up oxygen chemically or physically.

The on-line SpOUR can be used as bench top equipment for monitoring tolerability of the activated sludge on an individual basis. The on-line sampler can be detached from the apparatus so that RAS and the sample to be tested can be

introduced manually in the tolerability test. To start the test, 400 mL of RAS is first manually introduced into the apparatus for the determination of the endogenous respiration rate. Basing on the report from Nichols (1982), a stock synthetic reference sewage made from peptone and beef extract as recommended by OECD (1984) is used to improve the sensitivity of the test. A standard reference solution (Std. Ref. Soln.) with 16 mL of the stock synthetic reference sewage + 584 mL deionized distilled water (with a resulting BOD value of 460 mg/L) is prepared. This is then mixed with the RAS to obtain the basal SpOUR. The test is then repeated with a fresh RAS but the composition of the standard reference solution is changed to a mixture of 16 mL of stock synthetic reference sewage + 484 mL deionized distilled water + 100 mL of the sample to be tested for tolerability. The SpOUR of the combined solution is then obtained. The tolerability criteria is then determined by the following guidelines:

$$\text{Relative SpOUR} = \frac{\text{SpOUR(RAS+Mixture)}}{\text{SpOUR(RAS+Std.Ref.Sol.)}} \times 100\% \quad (17)$$

Relative SpOUR > 100% = Acceptable wastewater.

90% < Relative SpOUR < 100% = Inhibitory wastewater.

Relative SpOUR < 90% = Toxic Wastewater.

Successful results were reported by Patapsco WWTP (Martin 1989) by using the similar "10%" rule and a respirometer to examine the treatability of the liquid wastes entering the treatment facility.

Sometimes it is difficult to differentiate between a sample that is slightly toxic and one that is not easily treated. Such a sample can produce insufficient metabolism in the activated sludge system causing high BOD in the final effluent. Further laboratory testing may be required for such sample so that appropriate treatment can be applied.

Together with a manifest programme and close-circuit TV supervision, the SpOUR apparatus is an excellent complimentary tool for eductor truck liquid wastes monitoring.

#### **8.6.4 Food to Microorganisms Monitoring Using SpOUR**

The traditional strategy to control return sludge is to use a fixed percentage of the plant flow. The percentage used varies according to different operation conditions in an attempt to match the quantities of "food" entering the aeration tank with adequate microorganisms. The rule of thumb generally used is to mix 40% returned activated sludge with 60% of primary effluent.

However, due to industrial flow, infiltration/inflow or storm water contribution, a change in flow does not

necessarily means a change in the amount of "food" entering the aeration tank. A more realistic way of determining F : M relationship is to determine the volatile suspended solids of the returned activated sludge as M and the primary effluent BOD<sub>5</sub> entering the aeration tank as F. Nevertheless, determination time is lengthy and results may not be indicative of the actual viable microbial population or the proper amount of "food".

In an attempt to develop better methods of determining the rate of sludge return, Arthur (1983) suggested using the respiration rate of the microorganisms in the returned sludge and the mixed liquor at the inlet to the aeration tank. The F:M ratio is expressed as:

$$\frac{F}{M} = \frac{\text{SpOUR}_{ML} (Q + Q_{RAS}) - \text{SpOUR}_{RAS} Q_{RAS}}{\text{SpOUR}_{RAS} Q_{RAS}} \quad (18)$$

Whereas SpOUR<sub>ML</sub> = Specific oxygen uptake rate of mixed liquor at inlet, mg O<sub>2</sub>/(g.h)

SpOUR<sub>RAS</sub> = Specific oxygen uptake rate of returned sludge, mg O<sub>2</sub>/(g.h)

Q = Plant flow, ML/h

Q<sub>RAS</sub> = Returned activated sludge flow, ML/h

NOTE: It is not necessary to determine MLVSS for SpOUR since it cancels out.

Thus basing on the real-time information provided by the SpOUR apparatus, F:M ratio can be updated every half an hour. This is much quicker and better than using the conventional BOD and MLVSS because both do not tell much about the biological conditions of the microorganisms in the aeration tanks and require a much longer time to obtain data.

Furthermore, by rearranging equation (18)  $Q_{RAS}$  can also be updated once F:M ratio is obtained. Thus

$$Q_{RAS} = \frac{SpOUR_{ML} * Q}{(1 + F/M) SpOUR_{RAS} - SpOUR_{ML}} \quad (19)$$

Further investigation of the above application should be done once the SpOUR monitoring has become a routine practice.

#### **9. Protocol for the Management of Unusual SpOUR data:**

Since it has been developed from previous experiments that SpOUR can give an imminent warning of any unusual raw influent, an effective management protocol must be developed to deal with any unusual SpOUR data for proper treatment plant operation.

The causes for unusual trends or results in SpOUR coming from the raw influent can be generalized as shown in Table 6. Such trends or results usually indicate a warning for biological upsets to the secondary treatment system. A

TABLE 6.

**Summary of unusual trends or results in SpOUR due  
to raw influent variability**

Sample Origin	Possible SpOUR Response	Proposed Corrective Solutions
Organic loading of		
(a) Highly biodegradable materials	+	Increase number of microorganisms
(b) Toxic origins	-	Divert flow to holding tank after primary treatment
(c) Inhibitory or difficult to treat materials	-	Check for possible acclimatization or treatment
Extreme acid or basic condition	-	Neutralization before primary
Temperature		
(a) High	-	Diversion after primary
(b) Low	-	Diversion after primary
Heavy metals	-	Diversion or precipitation after primary
Excessive oil or grease	-	Separation or diversion after primary

+ = increase

- = decrease

flowchart of the steps for managing such possible biological upsets is shown in Figure 39.

Basically, the capacities of the various process streams should be identified. The purpose is to find out the retention time that is available once a toxic or unusual slug is detected. Knowledge of actual sizes of various treatment facilities such as the sizes of the primary setting tanks can allow management to make quick decisions on reactive measurement.

A spare tank for raw influent or primary effluent diversion should be available because toxic slug can then be diverted temporarily until proper analyses have been done to identify problems and decision on best treatment has been made.

Once the cause of unusual SpOUR readings has been identified, corrective actions should be implemented. Adequate time should be allowed for the biological system to adjust to the new corrective condition.

#### **10. Discussion**

During the two months of continuous round-the-clock trial run periods, the SpOUR apparatus performed satisfactorily in both hardware and software areas. Appendix H shows the summary of all the testing information while Appendix I shows the plots of SpOUR versus time during the entire testing period. Several interesting observations we




Figure 39. Flowchart of biological upsets management.

made from the daily SpOUR versus time plots:

- (1) The raw influent entering Gold Bar WWTP varied greatly in strength even within very short periods of time during the testing period. This can be seen from data on July 9 to 12, August 10 to 12, and August 17. Such a big fluctuation can cause treatment problems if not properly taken into consideration.
- (2) The daily diurnal pattern of highest sewage strength around midnight and lowest around noon, the weekly pattern of higher sewer strength during weekdays and lower during weekends were also noticeable during the entire testing period.
- (3) During rain or thunderstorm, the SpOUR readings were low and also smoothed out as indicated by the rain or thunderstorm during July 19 to 20, July 25 to 26, and August 31 to September 1.
- (4) There are many incidents of SpOUR readings that were significantly higher than normal (greater than 50% of the previous value). A good example can be seen from July 5 to 8 and August 10 to 11 SpOUR monitoring plots from Appendix I.
- (5) There are incidents of SpOUR readings that were significantly lower than normal (lower than 50% of the previous value). Examples can be seen from July

12, July 29, and August 16 SpOUR monitoring plots from Appendix I.

Two important areas have to be addressed before the apparatus can be put into on-stream monitoring. The first one is oil and grease in the raw influent.

Due to the nature of the sample, DO probe was constantly interfered by the oil and grease in the raw influent. This could be seen from the prominent continuous downward trends of the SpOUR as indicated by the daily SpOUR monitoring versus time plot shown in the Appendix I during the period of July 23-26. Immediately after the DO probe had been cleaned, the SpOUR values increased significantly to a higher sets of readings as indicated by the footnote "g = DO probe cleaned" shown in various places in the Appendix I. Such a jump in SpOUR values could give a false positive indication of higher organic loading entering the treatment facilities. Or conversely, the previous lower SpOUR reading could be underestimated readings so that incorrect operational measurements were done causing deterioration of the effluent quality.

Daily routine cleaning of the DO probe seems to be the easiest solution to the above problem. A clean spare DO probe can be put into use while the used DO probe is taken out from the apparatus for cleaning. Such a changeover takes only a few minutes. A calibration should also be done using

standard reference solution to update the correlation of the SpOUR and BOD values. Standard reference toxicant such as 3,5-DCP should be used regularly to ensure the sensitivity of the sludge is normal. This procedure is recommended by the OECD (1984) and should be included in the Standard Operation Procedure (SOP) as part of the quality assurance programme.

If the SpOUR apparatus is put into other locations such as primary effluent (PE) outlet, secondary aeration tanks (SAT), such problems would not be as serious due to the removal of oil and grease in the primary treatment.

Another serious problem encountered during the trial period was the constant blockage of solenoid by debris from the raw influent. Due to the nature of the sample, particles of various types were included in the sample. Although a strainer was used to prevent larger particles entering the apparatus, substances that were small enough to pass through the strainer could sometimes block the solenoid's sealing membrane and caused blockage and malfunctioning of the apparatus.

Experience from Gold Bar WWTP on the solenoids was to put them on vertical drain instead of horizontal. This would help flush out the debris. Such redesigning of the drainage solenoid is strongly recommended.

Again, this problem seems to be inherent with the nature of the raw influent. Samples taken from PE and SAT

will not expected to have such problems.

Except for the two problems discussed above, the hardware and software of the SpOUR apparatus worked very well and proven to be very reliable. The use of MCU enables multi-points monitoring to be done by one host computer and hence cuts down significantly on the cost.

Althought EC<sub>50</sub> values were developed in this project, the assessment of toxicity by this method only shows the impact of the specific compound on the ability of the activated sludge microorganisms to remove normal biogenic compounds from the wastewater. Furthermore, in this test there is no indication of the toxicity effect of the toxicant to the anaerobic digestor or other ecosystem that the effluent is to be discharged.

Moreover, the toxicity identified is only shown as acute toxicity under the specified conditions of testing, bacterial population in the secondary aeration tanks may acclimatize during the treatment process and reduces the toxicity effect. Some toxicants may also be precipitated or settled as sludge before reaching the secondary treatment. More specific toxicity testing should be done to address these issues.

Busch (1982) suggested that in the OUR test, the major variable is the bacterial seeds used and felt that it could be controlled by the use of laboratory pure culture. Many other studies (Dutka et al. 1983, Dutka and Kwan 1984) also

showed that each bacterial species and test procedure has its own level of sensitivity pattern to various toxicants. They eventually suggested using a mixture of several species made up from the laboratory pure cultures to give a more reproductive result. However, the merits of using the bacterial culture taken from the secondary aeration tank of the treatment facility are obvious. These advantages include:

- It is readily available and cost nothing to obtain.
- The parameters required (MLVSS, microscopic examination) are routinely done by the operational staff at Gold Bar WWTP, hence no extra burden of workload would be required.
- The reaction of the seed sludge to the raw influent will tell exactly the direct impact of the influent to the secondary treatment system. Such in situ testing could save a lot of time in correlating test data with impact to the treatment system.
- The SpOUR tells directly the oxygen requirement in the aeration tank including the nitrification requirement.

One disadvantage associated with the use of MLVSS as an indicator of microbial mass is the variability in data. This could cause a lot of difficulties when interpretation of the results is required. In order to assure accuracy and

precision of the data generated, a routine calibration procedure should be included in the SOP of the instruction. Such calibration procedure would include the following steps:

- A daily change of a clean calibrated DO probe or whenever it is required.
- When a new RAS is used, the system should be calibrated with a standard reference solution for updating the correlation of SpOUR and BOD.
- A standard reference toxicant such as 3,5-DCP should be used on a weekly basis to ensure the sensitivity of the apparatus.

In our experiment, a close relationship was also observed for the BOD<sub>5</sub> (24 h composite sample) and the SpOUR (24 h average) readings. Such relationship has been shown previously to be linear. However, when individual data were compared, no linear relationship was found. This could be due to various factors such as biomass limiting the assimilation process, toxicity present in the raw influent or variability in the DO probe.

In order to improve the working range of this linear relationship, higher biomass should be used by (a) using more RAS i.e. instead of 400 mL of RAS use 600 or 700 mL, or (b) by centrifuge RAS and resuspend in a phosphate buffer

solution as reported by Vargas-Lopez et al.(1989).

More work should also be done to validate the above relationship although many other researchers had already reported such correlation.

### **11. Conclusion**

Except for a few incidents of oil and grease or debris in the raw influent interfering with the testing, the hardware and software of the SpOUR apparatus worked very well during the two months of continuous testing and proven to be very reliable. The use of a MCU and efficient programming languages enabled multi-point monitoring to be done by one host computer and hence cuts down significantly on the cost.

The monitoring of SpOUR is not only a useful on-line tool for screening unusual organic or toxic loadings, but is also useful in providing information such as prediction of BOD<sub>5</sub>. Further investigations of using the SpOUR data for F : M ratio control and activated sludge aeration requirement F:M ratio and aeration requirement are recommended.

The SpOUR apparatus can also be used as an individual laboratory bench-top device for individual sample testing on toxicity of liquid wastes and tolerability of the activated sludge to such wastes.

Aidun, B. 1986. Design and Evaluation of an Automated Oxygen Uptake Rate Measurement System at the Edmonton Sewage Treatment Plant. M.Sc. Thesis. University of Alberta, Edmonton. 337 p.

Aidun, B., and Smith, D.W. 1988. Design and Evaluation of an Automated Oxygen Uptake Rate Measurement System. Can. Journ. of Civ. Eng., 15, pp.1015-1021.

Am. Public Health Assoc., Am. Water Works Assoc., and Water Poll. Control Fed. 1989. Standard Methods for the Examination of Water & Wastewater. 17th Ed. Washington, D.C. 1587 p.

Am. Public Health Assoc., Am. Water Works Assoc., and Water Poll. Control Fed. 1980. Standard Methods for the Examination of Water & Wastewater. 15th Ed. Washington, D.C. 1134 p.

American Sigma. 1988. Operation and Maintenance Manual- Streamline Portable Sampler. Middleport, New York. 51 p.

Arthur, R.M., and Hursta, W.N. 1968. Short Term BOD Using the Automatic Respirometer. Proceedings of the 23rd Purdue Industrial Waste Conference. West Lafayette, Indiana, Purdue Univ. pp.242-250.

Arthur, R.M. 1982a. New Concepts and Practices in Activated Sludge Process Control. Ann Arbor Science, Michigan. pp.55-113.

Arthur, R.M. Editor. 1982b. Application of On-Line Analytical Instrumentation to Process Control. Butterworth, Maine. pp.48-50.

Arthur, R.M. Editor. 1983. Procedures and Practices in Activated Sludge Process Control. Butterworth, Maine. pp.38-45.

Arthur, R.M. 1984. Discussion of Measurement and Validity of Oxygen Uptake Rate as an Activated Sludge Process Control Parameter. Journ. Water Poll. Control Fed., 56, 111-112.

Arthur, R.M. Editor. 1986. Treatment Efficiency and Energy Use in Activated Sludge Process Control. Butterworth, Maine. pp.115-117.

- Arthur, R.M. 1988. Troubleshooting Activated Sludge Wastewater Treatment Plants. Tech-line Instruments, Fond du Lac, Wisconsin. 7 p.
- Arthur, R.M. 1990. Here's What You Can Do With Respirometry. Arthur Technology, Wisconsin. 13 p.
- Benefield, L.D., Randall, C.W., and King, P.H. 1975. Process Control by Oxygen Uptake and Solids Analysis. Journ. Water Poll. Control Fed., 47, 2498-2503.
- Blaise, C., Sergy, G., Wells, P. Birmingham, N., and Van Coillie, R. 1988. Biological Testing - Development, Application, and Trends in Canadian Environmental Protection. Tox. Assessment. 3, 385-406.
- Brown, G.B., and Nowak, G. 1983. Activated Sludge Process Control. Proc. of the 31st Western Canada Water and Sewage Conference, Edmonton, Alberta. pp.35.
- Bundy, R.S. 1989. Upgrading Ellijay. Operations Forum, 6, 3, pp.20-21.
- Busch, A.W. 1982. Bioassay Technique for Relative Toxicity in Water Pollution Control. Journ. Water Poll. Control Fed., 54, 1152-1154
- Certificate of Calibration for Thermometer. 1987. NBS Monograph 150 & ASTM E77-84. W.H. Kessler Co. New York.
- Chandra, S., Mines, R.O., and Sherrard, J.H. 1987. Evaluation of Oxygen Uptake Rate as an Activated Sludge Process Control Parameter. Journ. Water Poll. Control Fed., 59, 1009-1016.
- City of Edmonton. 1983. Bylaw No. 7118, The Sewers Bylaw. City of Edmonton, Alberta. 28p.
- Clarke, A.N., Eckenfelder, Jr. W.W., and Roth, J.A. 1977. The Development of an Influent Monitor for Biological Treatment System. Frog. Water Tech., 9, 103-107.
- Colvin, R.J., and Rozich, A.F. 1989. Using Respirometry to Operate Activated Sludge Plants Treating Toxic Influentes. The Bench Sheet. WPCF/AWWA 11, 5, pp.8-11.
- Davey, B. 1988. Municipal Operators Help Solve Industrial Wastewater Problem. Environmental Science and Engineering, 8, pp.22.
- Dowty, B., Green, L., and Laster, J.L. 1976. Application of a Computer-Based Chromatograph for Automated Water Pollution Analysis, J. Chromatograph. Sci., 14, pp.187.

- Duggan, J.B., and Cleasby, J.L. 1976. Effect of Variable Loading on Oxygen Uptake. Journ. Water Poll. Control Fed., 48, 540-550.
- Dutka, B.J., and Kwan, K.K. 1984. Studies on a Synthetic Activated Sludge Toxicity Screening Procedure with Comparison to Three Microbial Toxicity Tests. In Toxicity Screening Procedures Using Bacterial Systems, Lui, D., and Dutka, B.J. (Eds.). Marcel Dekker, New York. pp.125-138.
- Dutka, B.J., Nyholm, N. and Petersen, J. 1983. Comparison of Several Microbiological Toxicity Screening Tests. Water Res., 17, 1363-1368.
- Eckenfelder, W.W. 1961. Application of Kinetics of Activated Sludge to Process Design. In Advances in Biological Waste Treatment, Eckenfelder, W.W. and McCabe, M. (Eds.). The MacMillan Co., N.Y. pp.277-289.
- Edwards, G.L., and Sherrard, J.H. 1982. Measurement and Validity of Oxygen Uptake Rate as an Activated Sludge Process Control Parameter. Journ. Water Poll. Control Fed., 54, 1546-1552.
- Elnabarawy, M.T., Robideau, R.R., and Beach, S.A., 1988. Comparison of Three Rapid Toxicity Test Procedures: Microtox, Polytox, and Activated Sludge Respiration Inhibition. Tox. Assessment., 3, 361-370.
- Fitzgibbons P.E. 1989. Streamlining Oxygen Consumption Rate Tests. Operations Forum. 6, 1, pp.32.
- Flynn, B.P. 1979. Management of Biological Treatment Plant Upsets: Avoidance, Detection and Minimization. Proceedings of the 34th Purdue Industrial Waste Conference. West Lafayette, Indiana, Purdue Univ. pp. 760-770.
- Godrej, A.N., and Sherrard, J.H. 1988. Kinetics and Stoichiometry of Activated Sludge Treatment of a Toxic Organic Wastewater. Journ. Water Poll. Control Fed., 60, 221-226.
- Haas, C.N. 1979. Oxygen Uptake Rate as an Activated Sludge Control Parameter. Journ. Water Poll. Control Fed., 51, 938-943.
- Hanel, K. 1988. Biological Treatment of Sewage by the Activated Sludge Process. John Wiley & Sons, New York. 229 p.

Himebaugh, R.R. 1981. Microorganism Inventory in Activated Sludge Control. Water Engineering and Management., 2, pp.26-30.

Huang, J.Y.C., and Cheng, M.D. 1984. Measuring and New Applications of Oxygen Uptake Rate in Activated Sludge Processes. Journ. Water Poll. Control Fed., 56, 259-265.

Huang, J.Y.C., Cheng, M.D., and Mueller, J.T. 1985. Oxygen Uptake Rates For Determining Microbial Activity and Application. Water Res., 19, 373-381.

Kennicutt, M.C. 1980. ATP as an Indicator of Toxicity. Water Res. 14, 325-328.

Khararjian, H.A. 1980. Communication : Oxygen Uptake as a Control Parameter. Journ. Water Poll. Control Fed., 52, pp.823.

King, E.F. 1984. A Comparative Study of Methods for Assessing the Toxicity to Bacteria of Single Chemicals and Mixtures. In Toxicity Screening Procedures Using Bacterial Systems, Lui, D., and Dutka, B.J.,(Eds.), Marcel Dekker, New York. pp.175-194.

Kwan, K.K. 1988. Synthetic Activated Sludge Technique for Toxicity Assessment of Chemicals and Environmental Samples. Tox. Assessment. 3, 93, 98.

Martin, J.V. 1988. Inhibition of Respiration in Activated Sludge by High Carbon Dioxide Concentration, A Laboratory Study. City of Baltimore, Maryland. 33 p.

McKinney, R.E. 1962. Microbiology for Sanitary Engineers. McGraw-Hill, New York. 220 p.

Miklos, D. 1990. A Rapid Technique For Evaluation Of Sewage For Toxicity And Treatability. WO Monitor, Yellow Spring Instruments, Ohio. pp.4-5.

Miller, D.L. 1985. Respiration Rate: Use It For A Quick & Reliable Status Report. Operation Forums, 2, 3, pp.14-17.

Mona, R., Dunn, I. J., and Bourne, J. R. 1979. Activated Sludge Process Dynamics with Continuous Total Organic Carbon and Oxygen Uptake Measurements. Biotechnol. Bioeng., 21, 1561-1577.

Mudrack, K., and Kunst, S. 1985. Biology of Sewage Treatment and Water Pollution Control. John Wiley & Son, New York. 190 p.

- Nelsen, D.P. 1987. Automatic Respirometer - A Process Control Diagnostic Tool. Operations Forum, 4, 9, pp.26.
- Nichols, W.E. 1982. On-line Instrumentation for Prediction of Plant Operation. In Application of On-line Analytical Instrumentation to Process Control. Arthur, R.M. (Ed.) Ann Arbor Science, Ann Arbor, Michigan. pp.115-132.
- OECD, 1984. "Method 209, Activated Sludge, Respiration Inhibition Test. Adopted April 4, 1984." OECD Guidelines for Testing of Chemicals, Organization for Economic Cooperation and Development (OECD), Paris, France. 10 p.
- Patterson, J.W., Brezonik, P.L., and Putnam, H.D. 1970. Measurement and Significance of Adenosine Triphosphate in Activated Sludge. Environ. Sci. Technol., 4, 569-575.
- Queeney, K.M., and Hoek, F.B. 1989. On-line Determination of Organic Pollutants Using TOC, TC, TOD, and COD. American Laboratory, 10, pp.26-32.
- Richard, M. 1988. Protozoa and Activated Sludge Operation. The Bench Sheet. WPCF/AWWA. 10, 2, pp.3-5.
- Roesler, J.F. 1986. Potential Analyzers of Toxic Materials for On-Line Use. In Treatment Efficiency and Energy Use in Activated Sludge Process. Arthur, R.M.,(Ed.). Butterworth, Woburn, Maine. pp.49-66.
- Russell, L.L., Cain, C.B., and Jenkins, D.I. 1982. Impact of Priority Pollutants on Publicly Owned Treated Works Processes : A Literature Review. Purdue Univ., West Indiana, Ann Arbor Science Publisher. pp.871-883.
- Sierp, F. 1928. A New Method for Determining BOD. Journ. Ind. Eng. Chem., 20, 247. Chem. Abs., 22, 1204.
- Sherrard, J.H. 1980. Communication : Oxygen Uptake Rate as an Activated Sludge Control Parameter. Journ. Water Poll. Control Fed., 52, 2033-2036.
- Sollfrank, U., and Gujer, W. 1990. Simultaneous Determination of Oxygen Transfer Coefficient in Activated Sludge Systems by an on-line Method. Wat. Res., 24, 725-732.
- Solyom, P. 1977. Industrial Experiences with Toxicguard, A Toxicity Monitoring System. Prog. Water Tech., 9, 193-198.

- Solyom, P., Bengt, B., and Bjorndal, H. 1976. Continuous Monitoring of Acute-Toxic Substances in Wastewater. Prog. Water Tech., 8, 417-422.
- Streater, H.W., and Phelps, E.B. 1925. U.S. Pub. Health Bull. 146. Cited by Hanel, K. Biological Treatment of Sewage By The Activated Sludge Process. John Wiley & Sons, New York. 1988. pp.129.
- Summers, S.M., Slon, R.A., and Gomperts, R.P. 1982. Real-Time monitoring of Biomass Respiration. In Application of On-Line Analytical Instrumentation to Process Control. Arthur, R.M., (Ed.), Ann Arbor Science, Michigan. pp.133-148.
- Suschka, J., and Ferreira, E. 1986. Activated Sludge Respirometer Measurements. Water Res. 20, 137-144.
- Therien, N., and Ilhan, F. 1983. Relating BOD With On-Line Oxygen Uptake Rate Measurements Using Automatic Respirometer in View of Process Monitoring Control. In Procedure and Practices in Activated Sludge Process Control. Arthur, R.M.,(Ed.), Butterworth, Woburn, Maine. pp.113-129.
- UMA. 1976. Design Brief and General Arrangement Drawings for Recommended Improvements to the Gold Bar Wastewater Treatment Plant. Underwood McLellan Associates Engineering Ltd., Edmonton. pp. A-5.
- Vargas-Lopez, C.E., Stentiford, E.I., and Mara, D.D. 1989. Discussion of : Evaluation of Oxygen Uptake Rate as an Activated Sludge Process Control Parameter. Journ. Water Poll. Control Fed., 61, 99-102.
- Weddle, C.L., and Jenkins, D. 1971. The Viability and Activity of Activated Sludge. Water Res. 5, 621-640.
- Wuhrman, K. 1956. Factors Affecting Efficiency and Solids Production in the Activated Sludge Process. Edited by Eckenfelder, W.W. and McCabe, J. Reinhold Publishing, N.Y. pp.49.
- Whitney, E. 1989. Toxicity Testing at Patapsco. Operations Forum, 6, 3, pp.18-19.
- Yee A., and Hettiaratchi. P. 1989. The Management of Liquid Wastes in Edmonton. City of Edmonton, Alberta. pp.5-12.

## Appendix A : DO2CON46 programme.

```

DO2CON46 - Dissolved Oxygen Control Program
Version 4.6
Written By: Dale Lathe
Date: June 27 / 90

This program starts the DO2 Controller and then waits for the
data to be returned to the PC. These data are stored and a linear
regression of the data is performed to find the Oxygen uptake
rate. The Oxygen uptake rate is then also stored to the disk.

Version 4 plots the value of SpOUR of the wastewater sample
in the form of a strip chart. This means that the plot moves from
right to left across the screen showing the last 20 values of the
SpOUR.

All Control of the DO2 is done from the software in the Controller

```

```

DIM do$(120)
DIM do2%(60)
DIM temp%(60)
DIM SpOUR(20)
DIM shdat2(60)
DIM dat2(60)

START:
ON ERROR GOTO erlist

CLS
SCREEN 2
GOSUB Title
LOCATE 5, 1
INPUT "Enter Data File Name: (6 char. max.) "; DFN$
```

```

IF LEN(DFNS$) > 6 THEN GOTO START

'-----
DO

LOCATE 7, 1

INPUT "Enter Drive to Store Date (A,B, or C)"; DN$
DN$ = UCASE$(DN$)

LOOP UNTIL DN$ = "A" OR DN$ = "B" OR DN$ = "C"
DN$ = DN$ + ":\"

LOCATE 9, 1

INPUT "Enter Run Number (0-99) "; lopconts

CLS

GOSUB Title

'-----
OPEN "FCLC.set" FOR INPUT AS #1

INPUT #1, fdp%           'First data point of slope
INPUT #1, ldp%           'Last data point of slope
INPUT #1, ymin%          'Y axis minimum value
INPUT #1, ymax%          'Y axis maximum value
CLOSE 1

IF ymin% >= 0 THEN ymid = (ymax% - ymin%) / 2
IF ymin% < 0 THEN ymid = (ymax% + ymin%) / 2

LOCATE 9, 1
INPUT "Enter MLVSS in gm. "; MLVSS

DO

LOCATE 11, 40
PRINT "
LOCATE 12, 49
PRINT "
LOCATE 13, 1
PRINT "
LOCATE 14, 1
PRINT "

LOCATE 11, 1
INPUT "Enter the Hour of the day (24 hour clock). "; hh$
```

```

IF LEN(DFN$) > 6 THEN GOTO START

'-----'

DO

    LOCATE 7, 1
    INPUT "Enter Drive to Store Date (A,B, or C)"; DN$
    DN$ = UCASE$(DN$)
    LOOP UNTIL DN$ = "A" OR DN$ = "B" OR DN$ = "C"
    DN$ = DN$ + ":\"

    LOCATE 9, 1
    INPUT "Enter Run Number (0-99) "; lopcont$

    CLS
    GOSUB Title
    '-----'

    OPEN "FCLC.set" FOR INPUT AS #1
        INPUT #1, fdp$           'First data point of slope
        INPUT #1, ldp$           'Last data point of slope
        INPUT #1, ymin%          'Y axis minimum value
        INPUT #1, ymax%          'Y axis maximum value
    CLOSE 1

    IF ymin% >= 0 THEN ymid = (ymax% - ymin%) / 2
    IF ymin% < 0 THEN ymid = (ymax% + ymin%) / 2

    LOCATE 9, 1
    INPUT "Enter MLVSS in gm. "; MLVSS

DO

    LOCATE 11, 40
    PRINT "
    LOCATE 12, 49
    PRINT "
    LOCATE 13, 1
    PRINT "
    LOCATE 14, 1
    PRINT "

    LOCATE 11, 1
    INPUT "Enter the Hour of the day (24 hour clock). "; hh$
```

```

LOCATE 12, 1
INPUT "Enter the Minutes of the day (24 hour clock). "; mm$
TIME$ = hh$ + ":" + mm$ + ":00"

LOCATE 16, 40
PRINT "
LOCATE 17, 49
PRINT "
LOCATE 18, 1
PRINT "
LOCATE 19, 1
PRINT "
LOCATE 20, 1
PRINT "
LOCATE 21, 1
PRINT "
LOCATE 22, 1
PRINT "
LOCATE 23, 1
PRINT "

LOCATE 16, 1
INPUT "Enter the Day "; DD$
LOCATE 17, 1
INPUT "Enter the Month "; MO$
LOCATE 18, 1
INPUT "Enter the Year (90) "; YY$

TIMES = hh$ + ":" + mm$ + ":00"
DATE$ = MO$ + "/" + DD$ + "/" + YY$

DO
  LOCATE 20, 1
  PRINT "Time = "; TIME$
  PRINT "Date = "; DATE$

  LOCATE 23, 1
  PRINT "Is this time correct (Y/N) ?"
  yn$ = INKEY$

  yn$ = UCASE$(yn$)

  LOOP UNTIL yn$ = "N" OR yn$ = "Y"
  LOOP UNTIL yn$ = "Y"

-----
PORT: LOCATE 19, 1
      INPUT "Enter COM PORT (1 or 2) "; cp$
      cp$ = LEFT$(cp$, 1)

```

```

IF (cp$ = "1" OR cp$ = "2") THEN GOTO OP
GOTO PORT

OP:   OP$ = "COM" + cp$ + ":1200,n,8,1,CS,DS,CD"
      OPEN OP$ FOR RANDOM AS #1
      lopcont% = 0
      CLS
      ck% = 0
      -----
      LOCATE 3, 1
      PRINT "Sending STARTT command to DO2 System"
      GOSUB SENTSTART
      -----
      GOSUB empty           'Clear Serial Buffer
      CLS
      runcount% = 0
nextloop:
      st$ = TIME$
      IF runcount% = 0 THEN GOSUB GRAPH
      runcount% = 1
      HOURS% = VAL(MID$(TIME$, 1, 2))
      MINS% = VAL(MID$(TIME$, 4, 2))
      SECS% = VAL(MID$(TIME$, 7, 2))
      lopcont$ = STR$(lopcont%)
      lopcont$ = RIGHT$(lopcont$, LEN(lopcont$) - 1)
      LOCATE 1, 30
      PRINT "DO2 CONTROL SYSTEM"
      LOCATE 3, 59
      PRINT "START TIME "; st$
      LOCATE 3, 1
      PRINT "Data will be Stored on drive - " + DN$ + DFN$ + lopcont$ + ".PRN"
      LOCATE 5, 1
      PRINT "Press [Esc] to STOP/CONTINUE Test after this run. "
      -----
      Main Loop
      -----

```

```

'-----  

' IF lopcont% > 0 THEN GOSUB slope  

DO  

  GOSUB TMCAL      'Calulate run time  

  GOSUB ptime       'Print present, run, start, time.  

LOOP UNTIL LOC(1) > 100  

  GOSUB retrieve      'Retrieve data and store to disk  

  GOSUB slope         'CALULATE THE SLOPE OF GRAPH  

  GOSUB SENTSTART  

  GOTO nextloop  

'-----  

empty:  

  DO WHILE LOC(1) > 0  

    INPUT #1, garbage$  

  LOOP  

  RETURN  

'-----  

delay:  

  t = TIMER + .5  

delay1: IF TIMER > t THEN RETURN  

  GOTO delay1  

getdo:  

  GOSUB getdata  

  do2% = VAL(do$)  

  RETURN  

'-----  

gettemp:  

  GOSUB getdata  

  d$ = (MID$(do$, 4, 1))  

  GOSUB getdec  

  fd% = rd%  

  d$ = (MID$(do$, 3, 1))  

  GOSUB getdec  

  sd% = rd% * 16  

  temp% = fd% + sd%  

  RETURN  

'-----  

getdec:

```

```

IF d$ = "A" THEN rd% = 1
IF d$ = "B" THEN rd% = 11
IF d$ = "C" THEN rd% = 12
IF d$ = "D" THEN rd% = 13
IF d$ = "E" THEN rd% = 14
IF d$ = "F" THEN rd% = 15
IF d$ = "9" THEN rd% = 9
IF d$ = "8" THEN rd% = 8
IF d$ = "7" THEN rd% = 7
IF d$ = "6" THEN rd% = 6
IF d$ = "5" THEN rd% = 5
IF d$ = "4" THEN rd% = 4
IF d$ = "3" THEN rd% = 3
IF d$ = "2" THEN rd% = 2
IF d$ = "1" THEN rd% = 1
IF d$ = "0" THEN rd% = 0

```

RETURN

-----

getdata:

```

do$ = ""
DO
    dat$ = INPUT$(1, 1)
    do$ = do$ + dat$
LOOP UNTIL dat$ = CHR$(13)
lf$ = INPUT$(1, 1)

```

RETURN

-----

quit: END

slope:

n% = (ldp% - fdp%)

FOR sl% = 1 TO 2

```

s3 = 0
s4 = 0
s7 = 0
s8 = 0
s9 = 0
t2 = 0
t3 = 0
t4 = 0

```

```

XTIME = 0
YTIME = 0

```

IF sl% = 2 THEN

```

        fdp% = fdp% + 30
        ldp% = ldp% + 30

    END IF
    -----
    Shift Data Into New Array
    -----
    FOR MOVEARRAY% = fdp% TO ldp%
        shdat2(MOVEARRAY% - fdp%) = dat2(MOVEARRAY%)
        'LPRINT MOVEARRAY% - fdp%; shdat2(MOVEARRAY% - fdp%)
    NEXT MOVEARRAY%
    -----
    FOR i% = 0 TO n% - 1
        IF s1% = 1 THEN XTIME = i% * 20
        IF s1% = 2 THEN XTIME = (i% - 30) * 10
        YTIME = shdat2(i%)
        s3 = s3 + XTIME
        s4 = s4 + (XTIME ^ 2)
        s7 = s7 + YTIME
        s8 = s8 + (YTIME ^ 2)
        s9 = s9 + (XTIME * YTIME)

    NEXT i%

    IF s1% = 2 THEN
        fdp% = fdp% - 30
        ldp% = ldp% - 30

    END IF
    t2 = ABS(s4 - (s3 ^ 2) / n%)
    t3 = ABS(s9 - (s3 * s7) / n%)
    t4 = ABS(s8 - (s7 ^ 2) / n%)

    IF s1% = 1 THEN
        SLOPE1 = t3 / t2
        CORRCOFF1 = t3 / (SQR(t2 * t4))

    END IF
    IF s1% = 2 THEN
        SLOPE2 = t3 / t2
        CORRCOFF2 = t3 / (SQR(t2 * t4))

```

```

END IF

NEXT s1%
SpOUR = (((SLOPE2 * 2.5) - SLOPE1) * 3600) / MLVSS
tt$ = MID$(TIME$, 1, 2) + MID$(TIME$, 4, 2) + MID$(TIME$, 7, 2)
dt$ = MID$(DATE$, 1, 2) + MID$(DATE$, 4, 2) + MID$(DATE$, 9, 2)

OPEN DN$ + DFN$ + ".COF" FOR APPEND AS #2
PRINT #2, SLOPE1; CORRCOFF1; SLOPE2; CORRCOFF2; SpOUR; " "; tt$; " "; dt$

CLOSE 2

LOCATE 9, 10
PRINT "SLOPE1 = "; SLOPE1;
LOCATE 11, 10
PRINT "SLOPE2 = "; SLOPE2
LOCATE 10, 10
PRINT "CORRELATION COEFFICIENT 1 = "; CORRCOFF1
LOCATE 12, 10
PRINT "CORRELATION COEFFICIENT 2 = "; CORRCOFF2

FOR FIFO% = 0 TO 19
    SpOUR(FIFO%) = SpOUR(FIFO% + 1)
NEXT FIFO%
SpOUR(20) = SpOUR
RUNNUM% = RUNNUM% + 1
IF stopflag% = 1 THEN
    CLOSE
    END
END IF
GOSUB NEWGRAPH
RETURN

-----
GRAPH:

VIEW (50, 100)-(638, 190), , 1
WINDOW (0, ymin%)-(20, ymax%)

FOR x = 1 TO 19
LINE (x, ymin%)-(x, ymax%)
NEXT x

LOCATE 13, 1

```

```

PRINT ymax%;
LOCATE 24, 1
PRINT ymin%;
LOCATE 19, 1
PRINT ymid;

LOCATE 25, 37
PRINT "SpOUR = "; SpOUR;

FOR x = 1 TO 20
LINE ((x - 1), SpOUR(x - 1))-(x, SpOUR(x))
NEXT x

LINE (0, ymid)-(20, ymid)

RETURN
'-----
delay2:
RETURN
t1 = TIMER + .1

DO
LOOP UNTIL TIMER > t1
RETURN
'-----

NEWGRAPH:
CLS
GOSUB GRAPH

RETURN
'-----

TMCAL:
TN$ = TIME$
HOUR% = VAL(MIDS(TN$, 1, 2))
MIN% = VAL(MIDS(TN$, 4, 2))
SEC% = VAL(MIDS(TN$, 7, 2))

IF SEC% < SECS% THEN
    SEC% = SEC% + 60
    MIN% = MIN% - 1
END IF

TSEC% = SEC% - SECS%

IF TSEC% < 10 THEN
    TSEC$ = RIGHT$(STR$(TSEC%), 1)
    TSEC$ = "0" + TSEC$
END IF

IF TSEC% >= 10 THEN

```

```

TSEC$ = RIGHT$(STR$(TSEC%), 2)
END IF

IF MIN% < MINS% THEN
    MIN% = MIN% + 60
    HOUR% = HOUR% - 1
END IF

TMIN% = MIN% - MINS%
IF TMIN% < 10 THEN
    TMIN$ = RIGHT$(STR$(TMIN%), 1)
    TMIN$ = "0" + TMIN$
END IF

IF TMIN% >= 10 THEN
    TMIN$ = RIGHT$(STR$(TMIN%), 2)
END IF

IF HOUR% < HOURS% THEN
    HOUR% = HOUR% + 24
END IF
THOUR% = HOUR% - HOURS%

IF THOUR% < 10 THEN
    THOUR$ = RIGHT$(STR$(THOUR%), 1)
    THOUR$ = "0" + THOUR$
END IF

IF THOUR% >= 10 THEN
    THOUR$ = RIGHT$(STR$(THOUR%), 2)
END IF

RETURN
-----
ptime:
LOCATE 2, 57
PRINT "PRESENT TIME "; TIME$
LOCATE 4, 61
PRINT "RUN TIME "; THOUR$; ":"; TMIN$; ":"; TSEC$;

IF INKEY$ = CHR$(27) THEN
    IF stopflag% = 0 THEN
        stopflag% = 1
        LOCATE 7, 1
        PRINT "Test will STOP after this run.      "
        GOTO GETOUT
    END IF
    IF stopflag% = 1 THEN
        stopflag% = 0
        LOCATE 7, 1
    END IF
END IF

```

```

        PRINT "Test will CONTINUE after this run. "
END IF

GETOUT: END IF
RETURN

'-----

retrieve:

    LOCATE 8, 1
    PRINT "Data Are Now Being Transmitted"
    lopcont$ = STR$(lopcont%)
    lopcont$ = RIGHT$(lopcont$, LEN(lopcont$) - 1)

    OPEN DN$ + DFN$ + lopcont$ + ".PRN" FOR OUTPUT AS #2
    lopcont% = lopcont% + 1

indata:
FOR count% = 1 TO 60
GOSUB getdo
do2%(count%) = do2%
NEXT count%

FOR count% = 1 TO 60
GOSUB gettemp
temp%(count%) = temp%
NEXT count%

FOR count% = 1 TO 60
PRINT #2, do2%(count%); temp%(count%)
dat2(count%) = do2%(count%) / 666   'Convert to D02 Value
NEXT count%

CLOSE 2

LOCATE 8, 1
PRINT " "
RETURN

'-----

SENTSTART:
sentti = TIMER + 20

```

```

TRY:    CM$ = "STARTT"
        IF TIMER > sentti THEN
            CLS
            LOCATE 1, 1
            PRINT "Communications Error!"
            LOCATE 3, 1
            PRINT "DO2 System NOT Responding"
            LOCATE 5, 1
            PRINT "Check Connections and Rerun Program"
            END

        END IF

        FOR h% = 1 TO 6
            PRINT #1, MID$(CM$, h%, 1);
            GOSUB delay

            IF LOC(1) > 0 AND h% <> 6 THEN
                a$ = INPUT$(LOC(1), 1)
                'PRINT a$
                GOTO TRY
            END IF

            NEXT h%

            tout% = 0
        DO
            tout% = tout% + 1

            IF tout% > 30 THEN GOTO TRY

        LOOP UNTIL LOC(1) > 1
        a$ = INPUT$(LOC(1), 1)
        'PRINT a$
        IF LEFT$(a$, 2) = "ER" THEN GOTO TRY

        RETURN
        -----
erlist:
        OPEN "A:ERROR.LST" FOR APPEND AS #4

        PRINT #4, "Error number "; ERR; " on line number "; ERL
        CLOSE 4

        RESUME NEXT
        -----

```

Title:

```
LOCATE 1, 25
PRINT "DO2 Data System"
LOCATE 3, 20
PRINT "Version 4.6 Date Sept. 10 / 90"
RETURN
```

'-----'

## Appendix B : DO2VER13.C program.

```

/*      Date Nov.17/89

This program loops until the value of the A/D converter is greater
than 1000 hex (1.000 volts). Once this value is => the program
will drop out.

ad(1) is a function that starts the A/D converter and returns the
a/d value.

*/


int doarray[30]; /*      DO2 array */ */
int doaray[30];

int temparray[30]; /*      Temperature array */ */
int tmparray[30];

int rsarray[5]; /*      RS232 input array */ */
int *dopnt; /*      DO2 array data pointer */ */
int *dopnt1;

int *tempnt; /*      temperature array data pointer */ */
int *tmpnt1;

int *cmpnt; /*      command array buffer pointer */ */
int *rspnt; /*      RS232 array buffer pointer */ */

int a2dttemp; /*      temp location for DO2 reading */ */
int a2dttemp1; /*      temp location fo DO2 reading */ */
int bufcount=125; /*      data buffer size */ */

int sec; /*      total second counter */ */
int nib; /*      nib = 25 m. sec. */ */
int min; /*      one minuite counter */ */
int tsec; /*      one second counter */ */
int rscount; /*      data buffer counter */ */
int tempirqflag; /*      temperature interrupt flag */ */
int data; /*      Command data OK or NOT */ */
int ccount; /*      Communications Counter */ */
int comnum; /*      Command Number */ */
int EOSpnt; /*      End Of String pointer */ */
int fillcount; /*      cylinder level timeout conter */ */
int x;



char comarray[]="STARTTSTOPNSENTDATESTSY##"; /*      command array buffer */
/* char EOS[]="#"; */

/*

```

```

#include icl7135b.lib          A/D converter (5 1/2 digs.) for the DO2 probe
#include setmotor.lib          Turn motors on and off
#include setac.lib              Turn solenoids on and off
#include 8bita2d.lib            A/D converter (8 bit) for the temp probe
#include readlev.lib            Read the water level probes
#include delayc.lib             Delay by X second
#include timeirq.lib            Timer Interrupt (Every 25 m. sec.)
#include setport.lib            Set I/O ports
#include setirq.lib              Set interrupts
#include 8bita2d.lib            Internal 8 bit A/D routine
#include readrs23.lib            Check for start command from host
#include strngcom.lib           String compare
*/

#include timeirq.lib
#include setport.lib
#include setirq.lib
#include icl7135b.lib
#include delayc.lib
#include sentrs23.lib
#include 8bita2d.lib
#include setac.lib
#include setmotor.lib
#include readlev.lib
#include readrs23.lib
#include strngcom.lib

main()
{
    #asm
        lds #$FF      Set stack pointer to HEX FF
    #endasm

        setport(1);
        setirq(1);
        sampoff(1);

    do
    {
        }while(a2d(1)!=0);
    do
    {

        dopnt=&doarray[0];
        dopnt1=&doarray[0];

        tempnt=&temparray[0];
        tmppnt1=&tmaparray[0];

        cmpnt=&comarray[0];

        tempirqflag=0;
        rscount=0;
        motoron(2);

        do
        {
            }while(checkcom(1)!=1); /* wait for STARTT command from host */

        acon(3);
        delay(10);
}

```

```

acoff(3);
acon(1);

do
{
    if(readlev(1)==0);

    acoff(1);
    motoron(1);
    acon(4);
    delay(240);
    acori(4);

    do
    {
        *dopnt=ad(1);
        dopnt++;
        *temppt=a2d(1);
        temppt++;
        rscount++;
        delay(20);
    }while(rscount<30);

    acon(2);
    sampon(1);           /* sampler on and off */
    delay(1);
    sampoff(1);

    do
    {
        fillcount++;
        delay(1);

        /* if(fillcount>120) , program to be written yet */

        if(readlev(1)<=1);

        acoff(2);
        acon(4);
        delay(240);
        acoff(4);

        rscount=0;

        do
        {
            *dopnt1=ad(1);
            dopnt1++;
            *tmppt1=a2d(1);
            tmppt1++;
            rscount++;
            delay(10);

        }while(rscount<30);

        motoroff(1);
        acon(3);
        sent(1);
    }while(x==x);
}

```

**Procedure for Changing Auto-Sampler Sample Container**

When the sampler has taken 24 samples (in about 10 hours) the auto-sampler will stop function until a new sample container is installed. The procedure for changing the sample container is listed as follows:

**1. If a continuation of sampling is required -**

Press off when SpOUR unit is on RAS endogenous respiration testing. The full sample container is replaced with a new one. Then press on , chang/halt start program .

Screen will ask "Resume? or Start?"

Press start

Screen will show "Seeking bottle #1" while sample spout looks for bottle number 1. When bottle number 1 is found the sampler will automatically resume the sampling as programmed.

**2. A stop is required to do maintenance -**

When computer is still doing the SpOUR test, press ESC on the keyboard of computer and press off on the autosampler. To resume testing, type in DO2CON46 and repeat the starting procedure.

## Instruction on Programming the American Sigma Streamline

## Auto-sampler

## 1. To enter new programme:

The command in bold should be keyed in, the sentences in italics are the responses from the auto-sampler on the 16 character alpha-numeric display.

	<b>ON</b>	Activate the auto-sampler
	<b>NEW PROGRAM</b>	Tells the sampler new programme is to be entered
<i>Programme Delay?</i>	<b>NO</b>	Do you want to delay start of the sampling
<i>Timed Mode?</i>	<b>NO</b>	Do you want to sample on a timed cycle
<i>Flow Mode?</i>	<b>YES</b>	Do you want to sample on a flow proportional basis
<i>Total Count =</i>	<b>1 ENTER</b>	Enter 1 contact closure for each sampling
<i>Discrete Mode?</i>	<b>YES</b>	Will deliver samples into 24 sequential (discrete) bottles
<i>Samples / Bottle?</i>	<b>YES</b>	Ask the total number of samples per bottle
<i>Sample / Bottle=</i>	<b>1 ENTER</b>	Will deposit 1 sample per bottle
<i>Sample Volume=</i>	<b>999 ENTER</b>	Indicate desire volume of sample maximum 999mL. The actual volume can be adjusted by calibration.
<i>Calibrate Volume?</i>	<b>YES</b>	Ask if a calibration of volume to be delivered is needed
<i>Timed Calibrate?</i>	<b>YES</b>	Use time calibrate for better accuracy

<i>Ready to Start?</i>	<b>YES</b>	Ask if ready to start time calibration
<i>Pre-Purge</i>		Pump starts to purge sample line
<i>Stop at Mark</i>		After purging, sampler pump start drawing sample and you are asked to press stop when desired quantity of sample is obtained
<i>Post Purge</i>		Purge line after finishes sampling
<i>Do That Again?</i>	<b>NO</b>	Ask if you want to calibrate again
<i>Set up Complete, Ready to Start</i>	<b>START PROGRAM</b>	Tell sampler to start the program
<i>Seeking Bottle #1</i>		The sampler is seeking for bottle #1 location
<i>At bottle #1, Program Started</i>		The sampler is activated and will start for the 1 pulse count signal from the computer to start sampling
<b>2. To Review:</b>		The 16-character Alpha-Numeric display will review the program

## APPENDIX

### SpOUR Apparatus and 68HC11F1 Micro-Controller Unit (MCU)Softwares Setup

#### 1. Files needed to Assemble and Download Software:

a. SMC11.EXE	Small C Compiler
b. OPT11.EXE	HC11 Optimizer
c. C11LIB.TXT	HC11 Library File
d. C11.BAT	Batch file to compile software and create .S19 file to be sent to HC11
e. EELOAD3.EXE	Download software to HC11
f. E1PROGIX.BIN	HC11 downloading programme
g. DO2VER13.S19	DO2 software to be loaded into HC11

#### 2. Files required by 68HC11F1 MCU

##### Main C Programme

a. DO2VER13.C	Main Control Programme
---------------	------------------------

##### Library Files

a. READLEV.LIB	Read Fluid Level and Return a value
b. TIMEIRQ.LIB	Timer interrupt (every 25msec.)
c. SETAC.LIB	Turn AC solenoids on and off
d. SETIRQ.LIB	Set interrupts
e. ICL7135B.LIB	A/D converter (5 1/2 digs.) DO2 reading
f. DELAYC.LIB	Delay by X seconds
g. READRS23.LIB	Check for command from host PC
h. 8BITA2D.LIB	Function to read HC11 internal 8 bit A/D
i. SETMOTOR.LIB	Turns motors on or off
j. STRNGCOM.LIB	String compare routine
k. SETPORT.LIB	Set I/O port as in or out
l. SENTRS23.LIB	Sent data to host PC

#### 3. Example Procedure

C:\HC11>C11 DO2VER13 [ENTER]

C:\HC11>SMC11 <DO2VER13.C > DO2VER13.ASM

C:\HC11>OPT11 <DO2VER13 >DO2VER13.OPT

C:\HC11>TYPE C11LIB.TXT >>DO2VER13OPT

C:\HC11>AS11 DO2VER13.OPT -L >Do2VER13.LST

C:\HC11>FIND ":" DO2VER13.LST

All JMP and JSR labels will be listed on screen

**APPENDIX****Down Loading Instructions**

1. Unplug power from SpOUR apparatus system.
2. Disconnect RS232 cable from SpOUR apparatus system.
3. Connect down loading cable to end of RS232 cable.
4. Reconnect RS232 cable, now with down loading cable installed.
5. Plug power cord of apparatus back into AC outlet.
6. Type EELOAD3 [ENTER]

Follow instructions of software. Data will be echoed back from HC11 to host PC to indicate that software is being loaded.

7. Once software has been loaded, unplug power from apparatus.
8. Disconnect RS232 cable from apparatus.
9. Disconnect down loading cable from end of RS232 cable.
10. Reconnect RS232 cable, now with down loading cable not installed.
11. Plug power of apparatus back into AC outlet.
12. Type DO2CON46 [ENTER]  
Follow instructions of software.

## Appendix F. Example of Raw Data File for DO and Temperature

(a)	(b)	(a)	(b)
5960	112	5492	112
5960	112	5512	112
5907	111	5503	111
5827	111	5465	111
5741	112	5409	111
5657	112	5341	112
5571	112	5269	111
5485	112	5196	112
5390	112	5122	112
5300	112	5045	112
5217	112	4965	111
5136	112	4883	111
5057	112	4802	112
4980	112	4719	112
4899	112	4643	111
4821	112	4564	111
4750	112	4488	111
4675	112	4415	111
4604	112	4341	111
4531	112	4263	112
4460	112	4182	112
4390	112	4102	112
4320	112	4027	112
4251	112	3947	112
4188	112	3864	112
4125	112	3787	112
4066	112	3714	112
4003	112	3636	111
3937	112	3561	111
3872	112	3488	111

(a) = Raw DO readings as bits

(b) = Raw temperature readings as bits

## Appendix G. Example of Daily Summary File.

OUR1	coef	OUR2	coef	SpOUR
mg 02/sec	corr	mg 02/sec	corr	mg 02/(g.h) Time
2.47203E-03	1.00011	6.524482E-03	.9997854	31.13814 120029 071490
7.981161E-03	.9806876	1.355798E-02	.9996579	58.30603 122443 071490
9.800267E-03	.9999862	1.161766E-02	.999869	43.29876 124852 071490
6.814533E-03	.99931	1.075887E-02	.9995423	45.18596 131303 071490
6.810882E-03	.9996933	5.405299E-03	.998959	15.08033 133716 071490
6.688052E-03	.9994209	1.471754E-02	.9997836	67.73805 140127 071490
6.645747E-03	.9997336	1.032719E-02	.9992605	43.13753 142539 071490
6.742637E-03	.9992051	1.051289E-02	.9990127	43.96407 144952 071490
6.863691E-03	.999436	1.967414E-02	.9992275	95.22375 151420 071490
7.026593E-03	.9996482	1.675521E-02	.9995108	78.43823 153833 071490
6.907824E-03	.9996939	1.113657E-02	.999029	47.1006 160316 071490
6.423689E-03	.9996299	1.154138E-02	.9995189	50.46695 162727 071490
6.636173E-03	.9995729	.0188244	.9995794	90.95586 165154 071490
6.585699E-03	.9997645	1.181716E-02	.9998962	51.65369 171607 071490
6.586153E-03	.999831	1.515248E-02	.999254	70.41383 174015 071490
7.19766E-03	.9997545	1.097871E-02	.9993596	45.5605 180428 071490
6.480111E-03	.9997144	1.048659E-02	.9993951	44.40684 212221 071490
8.577206E-03	.9999132	1.209863E-02	.9992802	48.75608 214647 071490
6.979696E-03	.9998776	1.189004E-02	.9994451	51.17715 221118 071490
6.611151E-03	.9999136	1.113837E-02	.9993692	47.77826 223531 071490
6.922834E-03	.9997998	1.126855E-02	.999137	47.8092 225945 071490
6.860025E-03	.9998245	1.120304E-02	.9992746	47.58205 232358 071490
7.092542E-03	.9996156	1.134378E-02	.9995661	47.85054 234811 071490
6.240312E-03	.9998176	1.149477E-02	.9993253	50.61737 001239 071590
7.137573E-03	.9997427	1.138918E-02	.9992692	48.00458 003652 071590
7.171728E-03	.9998317	1.990522E-02	.9996423	95.83044 010105 071590
7.072523E-03	.999618	2.114803E-02	.9993745	103.0445 012517 071590
7.109838E-03	.9999182	1.240702E-02	.9998521	53.79235 014930 071590
7.125773E-03	.9998146	.0117229	.9994834	49.90833 021343 071590
7.178996E-03	.9999238	1.135844E-02	.9992037	47.73848 023757 071590
7.05616E-03	1.000006	1.070521E-02	.9991485	44.34043 030212 071590
7.062525E-03	.999885	1.095833E-02	.999074	45.74993 032627 071590
6.981079E-03	.9998636	1.024812E-02	.9992367	41.93825 035043 071590
7.056138E-03	.9999381	1.055573E-02	.999099	43.49966 041459 071590
6.997894E-03	.9999341	1.013157E-02	.99878	41.24493 043916 071590
6.416861E-03	.99998	1.008573E-02	.9992093	42.29432 050334 071590
6.736738E-03	.9999966	1.003612E-02	.9990696	41.29552 052753 071590
6.717632E-03	.9999828	1.010557E-02	.9992425	41.72917 055211 071590
6.465106E-03	1.000002	9.794311E-03	.9991225	40.54651 061630 071590
6.486909E-03	.9999322	9.770817E-03	.9994349	40.3653 064049 071590
6.363175E-03	.9999745	9.784228E-03	.9994091	40.71914 070506 071590
6.188467E-03	.9999654	9.255498E-03	.9994735	38.13812 072925 071590

**Appendix H. Raw Data for Monitoring Period Jun 28 to Sept. 1**

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept. 1, 1990)

Test No.	OUR1 mg/Lsec	Coef. Corr.	OUR2 mg/Lsec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR1 mg/Lsec	Coef. Corr.	OUR2 mg/Lsec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY								
1	8.88E-03	1.000	5.793	1.06E-02	1.000	35.30	203004	62900	74														
2	8.45E-03	1.000	1.16E-02	0.999	45.23	210252	62900	75															
3	5.84E-03	1.000	1.12E-02	1.000	44.48	212738	62900	76															
4	5.72E-03	1.000	9.08E-03	1.000	33.98	215429	62900	77															
5	5.53E-03	1.000	9.35E-03	1.000	35.70	222011	62900	78															
6	5.35E-03	1.000	9.29E-03	0.999	35.78	224423	62900	79															
7	7.97E-03	1.000	1.16E-02	1.000	43.08	230841	62900	80															
8	9.03E-03	1.000	1.30E-02	0.999	47.02	233300	62900	81															
9	8.54E-03	1.000	1.19E-02	0.999	42.51	235716	62900	82															
10	8.69E-03	1.000	1.14E-02	0.999	38.49	2133	62900	83															
11	8.54E-03	1.000	1.10E-02	0.999	42.33	4551	62900	84															
12	8.48E-03	1.000	1.46E-02	0.999	58.23	11017	62900	85															
13	8.20E-03	1.000	1.22E-02	0.999	44.60	13429	62900	86															
14	8.13E-03	1.000	1.33E-02	0.999	50.27	15848	62900	87															
15	7.82E-03	1.000	1.16E-02	0.999	42.37	22300	62900	88															
16	8.34E-03	1.000	1.37E-02	0.999	51.63	24709	62900	89															
17	7.52E-03	1.000	1.23E-02	0.999	46.24	31131	62900	90															
18	8.30E-03	1.000	1.29E-02	0.999	47.85	33542	62900	91															
19	7.46E-03	1.000	1.11E-02	0.999	40.89	35051	62900	92															
20	8.97E-03	1.000	1.08E-02	0.999	39.09	42408	62900	93															
21	7.09E-03	1.000	1.10E-02	0.999	37.72	44819	62900	94	1.91E-03	0.827	4.56E-03	0.999	21.34	101233	63090								
22	6.55E-03	1.000	1.10E-02	0.999	51.234	62900	95	3.42E-03	0.999	4.13E-03	0.999	15.54	103855	63090									
23	6.64E-03	1.000	1.21E-02	0.999	53.655	62900	96	3.49E-03	1.000	4.59E-03	0.999	17.96	110122	63090									
24	6.26E-03	1.000	1.12E-02	0.999	60.09	60109	62900	97	3.38E-03	1.000	4.15E-03	0.999	15.78	112545	63090								
25	6.18E-03	1.000	1.11E-02	0.999	61.01	62528	62900	98	3.52E-03	1.000	4.09E-03	0.999	15.08	114957	63090								
26								99	3.22E-03	0.999	4.57E-03	0.999	18.48	121410	63090								
27	6.13E-03	1.000			33.23	73459	62900	100	3.28E-03	0.998	5.25E-03	0.999	22.14	123810	63090								
28	5.72E-03	1.000	1.07E-02	0.999	42.95	75018	62900	101	3.40E-03	1.000	4.94E-03	0.999	20.13	130234	63090								
29	7.77E-03	0.997	9.88E-03	1.000	34.38	82332	62900	102	3.45E-03	0.999	6.06E-03	0.999	28.30	132662	63090								
30	5.45E-03	1.000	1.12E-02	0.999	45.03	84749	62900	103	3.58E-03	0.999	5.98E-03	0.999	25.58	135104	63090								
31	5.89E-03	1.000	1.08E-02	0.999	41.75	91204	62900	104	3.57E-03	1.000	5.91E-03	0.999	25.20	141521	63090								
32	5.45E-03	1.000	7.99E-03	1.000	29.08	93833	62900	105	3.81E-03	0.999	8.17E-03	0.997	26.14	143940	63090								
33	5.52E-03	1.000	1.11E-02	0.999	44.35	100045	62900	106	3.56E-03	0.982	6.96E-03	0.999	31.14	150349	63090								
34	5.57E-03	1.000	1.13E-02	0.999	45.16	102502	62900	107	3.07E-03	0.971	8.78E-03	0.999	31.29	152804	63090								
35	5.45E-03	1.000	1.07E-02	0.999	42.79	104912	62900	108	3.83E-03	0.999	6.82E-03	0.999	29.72	155217	63090								
36	5.29E-03	1.000	1.08E-02	0.999	43.22	111322	62900	109	2.87E-03	0.953	7.43E-03	0.999	35.78	161636	63090								
37	5.40E-03	1.000	1.11E-02	0.999	44.81	113733	62900	110	3.52E-03	0.999	7.45E-03	1.000	34.01	164055	63090								
38	7.72E-03	1.000	1.14E-02	0.999	41.77	120141	62900	111	7.73E-03	0.859	4.80E-03	0.999	26.82	170526	63090								
39	2.78E-05	0.553	3.56E-05	0.999	0.12	122560	62900	112	7.90E-04	0.813	5.21E-03	0.999	27.50	172954	63090								
40	5.89E-05	0.929	1.91E-05	0.798	-0.02	125018	62900	113	3.58E-03	1.000	8.32E-03	0.999	27.54	175426	63090								
41	4.73E-03	0.810	8.07E-10	0.002	-0.09	131431	62900	114	3.47E-03	1.000	7.00E-03	0.999	31.56	181845	63090								
42	2.32E-05	0.807	2.19E-05	0.853	0.08	133830	62900	115	4.22E-04	0.982	1.20E-03	0.942	5.78	184317	63090								
43	7.35E-03	1.000	1.47E-02	0.999	58.70	140315	62900	116	3.62E-03	1.000	6.51E-03	0.999	26.45	190740	63090								
44	7.77E-03	1.000	1.32E-02	0.999	50.42	142725	62900	117	Note 2: DO Probe calibration														
45	7.98E-03	1.000	1.42E-02	0.999	54.80	145154	62900	118															
46	8.02E-03	1.000	1.03E-02	0.999	65.26	151819	62900	119															
47	7.87E-03	1.000	1.47E-02	0.999	57.66	154064	62900	120															
48	8.14E-03	1.000	1.48E-02	0.999	57.06	160519	62900	121	4.01E-03	0.987	4.83E-03	0.999	18.12	211246	63090								
49	7.82E-03	1.000	1.58E-02	0.999	63.90	162927	62900	122	8.80E-03	1.000	8.58E-03	0.999	33.38	213702	63090								
50	7.72E-03	1.000	1.02E-02	0.999	66.80	165347	62900	123	8.49E-03	1.000	7.33E-03	0.999	26.65	220119	63090								
51	7.71E-03	1.000	1.49E-02	0.999	58.92	171803	62900	124	5.43E-03	0.974	8.21E-03	0.999	33.96	222538	63090								
52	7.89E-03	1.000	1.48E-02	0.999	57.81	174211	62900	125	6.22E-03	1.000	7.18E-03	0.999	26.40	224960	63090								
53	7.75E-03	1.000	1.50E-02	0.999	58.09	180288	62900	126	5.50E-03	0.999	7.55E-03	0.999	30.10	231411	63090								
54	7.42E-03	1.000	1.48E-02	0.999	58.11	183036	62900	127	5.88E-03	1.000	7.08E-03	0.999	26.58	233625	63090								
55	7.19E-03	1.000	1.48E-02	0.999	58.55	185444	62900	128	5.84E-03	1.000	8.92E-03	0.999	37.02	301	70190								
56	9.61E-03	1.000	1.39E-02	0.999	50.23	191855	62900	129	5.82E-03	1.000	8.88E-03	0.999	35.74	2718	70190								
57	8.82E-03	0.982	1.47E-02	0.999	58.41	194317	62900	130	5.73E-03	1.000	8.63E-03	0.999	36.63	5129	70190								
58	8.64E-03	1.000	1.39E-02	0.999	58.28	200724	62900	131	5.36E-03	1.000	8.30E-03	0.970	23.36	11543	71190								
59	8.33E-03	1.000	1.43E-02	0.999	58.63	203139	62900	132	5.58E-03	1.000	8.72E-03	0.999	36.48	14003	70190								
60	8.32E-03	1.000	1.35E-02	0.999	54.70	205647	62900	133	5.29E-03	1.000	8.92E-03	0.999	36.29	20432	70190								
61	8.38E-03	1.000	1.36E-02	0.999	58.55	211868	62900	134	5.22E-03	1.000	8.65E-03	0.999	36.94	22858	70190								
62	8.43E-03	1.000	1.34E-02	0.999	54.22	214407	62900	135	Note 3: Solenoid #3 leaked														
63	8.24E-03	1.000	1.36E-02	0.999	56.81	220815	62900	136															
64	8.26E-03	0.999	1.48E-02	0.999	58.41	223234	62900	137															
65	8.19E-03	1.000	1.05E-02	0.999	65.97	225850	62900	138															
66	7.93E-03	1.000	1.59E-02	0.999	63.78	232055	62900	139															
67	8.03E-03	1.000	1.50E-02	0.999	58.99	234610	62900	140															
68	7.88E-03	1.000	1.41E-02	0.999	54.99	628	62900	141															
69	Note 1: Solenoid #3 leaked due to debris blocking valve																						

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept. 1, 1990)

Test No.	OUR 1 mg/Lsec	Coeff. Corr.	OUR 2 mg/Lsec	Coeff. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MODYY
147							
148							
149	3.61E-03	1.000	4.37E-03	0.988	14.61	81306	70190
150	3.33E-03	0.989	5.21E-03	0.987	19.40	84400	70190
151	5.27E-03	0.989	4.11E-03	0.982	10.01	90825	70190
152	Note: Motor #1 fuse blown						
153							
154							
155							
156							
157	3.49E-03	1.000	4.34E-03	1.000	14.73	113636	70190
158	9.75E-04	0.980	1.48E-03	0.981	5.46	115060	70190
159	1.36E-03	0.984	4.51E-03	0.989	19.82	122404	70190
160	5.87E-03	1.000	5.82E-03	0.985	17.78	124825	70190
161	5.80E-03	1.000	5.87E-03	0.989	16.75	131240	70190
162	5.88E-03	1.003	5.42E-03	0.988	15.74	133703	70190
163	5.53E-03	1.000	5.57E-03	0.988	18.61	140122	70190
164	5.88E-03	1.000	8.28E-03	0.989	30.07	142537	70190
165	5.93E-03	1.000	7.92E-03	0.989	27.72	144956	70190
166	5.41E-03	1.000	6.71E-03	0.988	22.74	151410	70190
167	8.92E-06	0.938	6.86E-03	0.989	33.11	153850	70190
168	Note 4: DC Motor #3 overheated						
169							
170							
171							
172							
173							
174							
175							
176							
177							
178							
179							
180							
181	3.20E-04	1.000	5.27E-04	0.987	1.99	210853	70190
182	4.57E-03	0.984	6.70E-03	0.988	24.38	213317	70190
183	3.70E-03	1.000	8.42E-03	0.988	24.69	215741	70190
184	3.48E-03	1.000	6.41E-03	0.988	25.08	222152	70190
185	4.27E-03	0.988	7.08E-03	0.989	36.74	224812	70190
186	4.02E-03	1.000	6.03E-03	0.989	22.10	231025	70190
187	3.58E-03	1.000	5.83E-03	0.988	20.97	233430	70190
188	3.80E-03	1.000	5.14E-03	0.988	17.90	235847	70190
189	Note 5: Unit sent to U of A for motor repair						
190	(July 2-4)						
191							
192							
193	1.19E-02	1.000	1.73E-02	1.000	40.38	102412	70580
194	1.05E-02	0.988	1.50E-02	0.989	34.84	104820	70580
195	7.30E-03	1.000	1.29E-02	0.989	32.00	111228	70580
196	8.88E-03	1.000	1.82E-02	0.988	43.41	113633	70580
197	8.57E-03	1.000	1.71E-02	1.000	48.43	120038	70580
198	8.88E-03	1.000	1.22E-02	1.000	30.51	122447	70580
199	8.78E-03	1.000	2.20E-02	0.988	61.68	124807	70580
200	6.77E-03	1.000	1.99E-02	0.988	56.32	131314	70580
201	Note 6: No test due to low Raw Influent level						
202							
203							
204							
205							
206							
207							
208							
209							
210							
211							
212							
213	8.70E-03	1.000	1.38E-02	0.988	36.88	185808	70580
214	1.15E-02	1.000	1.32E-02	1.000	27.58	193012	70580
215	7.23E-03	1.000	9.74E-03	1.000	22.00	194418	70580
216	8.50E-03	0.989	9.30E-03	1.000	21.42	200823	70580
217	6.53E-03	1.000	8.31E-03	0.988	16.32	203227	70580
218	6.22E-03	0.989	7.80E-03	1.000	16.42	206830	70580
219	8.31E-03	1.000	7.73E-03	1.000	16.75	212035	70580

Test No.	OUR 1 mg/Lsec	Coeff. Corr.	OUR 2 mg/Lsec	Coeff. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MODYY
220	8.12E-03	1.000	7.43E-03	1.000	16.01	214441	70580
221	8.05E-03	1.000	7.83E-03	1.000	17.40	220845	70580
222	8.18E-03	0.989	8.21E-03	1.000	18.48	223308	70580
223	6.13E-03	1.000	8.15E-03	0.988	21.53	225729	70580
224	5.97E-03	1.000	8.18E-03	1.000	18.82	232134	70580
225	5.86E-03	1.000	8.14E-03	1.000	18.88	234541	70580
226	6.01E-03	1.000	8.58E-03	0.987	19.80	947	70890
227	5.82E-03	1.000	8.78E-03	0.987	20.86	3353	70890
228	Note 7: Solenoid #3 leaked						
229							
230							
231							
232							
233							
234							
235							
236							
237							
238							
239							
240							
241							
242							
243							
244							
245							
246							
247							
248							
249							
250							
251							
252							
253							
254							
255							
256							
257							
258							
259							
260							
261							
262							
263							
264							
265							
266							
267							
268							
269							
270							
271							
272							
273							
274							
275							
276							
277							
278							
279							
280							
281							
282							
283							
284							
285							

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)

Test OUR1 Coef. OUR2 Coef. SpOUR Time Date  
No mg/Lsec Corr mg/Lsec Corr mg/g/hr HHMMSS MDDYY

293  
294  
295  
296  
297  
298  
299  
300  
301  
302  
303  
304  
305  
306  
307 6.88E-03 1.000 6.03E-03 1.000 16.98 90348 70790  
308 Note 9 DO Probe calibration  
309  
310  
311  
312 1.18E-02 1.000 8.91E-03 1.000 13.34 110733 70790  
313 4.96E-05 1.211 9.10E-03 0.999 28.76 113149 70790  
314 6.27E-03 1.000 8.66E-03 0.999 19.49 122224 70790  
315 6.63E-03 1.000 1.75E-02 1.000 47.08 124836 70790  
316 6.20E-03 1.000 1.03E-02 1.000 24.85 131107 70790  
317 6.80E-03 1.000 1.12E-02 0.999 27.27 133540 70790  
318 6.38E-03 1.000 1.02E-02 1.000 24.33 135953 70790  
319 6.56E-03 1.000 1.07E-02 0.999 25.74 142430 70790  
320 6.01E-03 1.000 1.08E-02 1.000 28.78 144859 70790  
321 6.02E-03 1.000 1.13E-02 1.000 28.30 151337 70790  
322 6.20E-03 1.000 1.11E-02 1.000 27.35 153807 70790  
323 6.43E-03 1.000 1.12E-02 0.999 27.27 160238 70790  
324 6.51E-03 1.000 1.61E-02 0.999 42.80 162708 70790  
325 5.86E-03 1.000 1.53E-02 1.000 41.20 165124 70790  
326 6.03E-03 1.000 1.11E-02 1.000 27.05 171804 70790  
327 6.28E-03 1.000 1.05E-02 1.000 25.37 174040 70790  
328 6.44E-03 1.000 1.04E-02 0.999 24.80 180513 70790  
329 5.53E-03 1.000 1.04E-02 1.000 25.90 182943 70790  
330 5.08E-03 1.000 1.31E-02 0.999 34.28 185421 70790  
331 5.74E-03 1.000 1.00E-02 1.000 24.54 191903 70790  
332 5.54E-03 0.999 1.00E-02 0.999 24.68 194343 70790  
333 5.36E-03 0.999 1.11E-02 1.000 28.32 200879 70790  
334 6.89E-03 0.999 1.14E-02 0.999 27.32 203258 70790  
335 6.94E-03 1.000 1.16E-02 1.000 28.06 206727 70790  
336 7.10E-03 1.000 1.16E-02 1.000 27.06 212200 70790  
337 7.07E-03 1.000 1.78E-02 1.000 47.50 214836 70790  
338  
339 6.95E-03 0.999 1.19E-02 0.999 28.06 224444 70790  
340 7.25E-03 1.000 1.22E-02 1.000 29.59 230614 70790  
341 7.00E-03 0.994 1.21E-02 1.000 29.59 233340 70790  
342 6.54E-03 1.000 1.20E-02 0.999 29.86 235812 70790  
343 7.08E-03 1.000 1.24E-02 0.999 30.23 2249 70890  
344 6.80E-03 0.999 1.23E-02 0.999 30.47 4721 70890  
345 6.43E-03 0.999 1.21E-02 0.999 30.18 11203 70890  
346 6.81E-03 0.999 1.24E-02 1.000 30.50 13833 70890  
347 7.06E-03 0.999 1.39E-02 0.999 53.78 20109 70890  
348 6.85E-03 1.000 1.25E-02 0.999 31.08 22546 70890  
349 6.82E-03 1.000 1.15E-02 1.000 28.18 25021 70890  
350 6.53E-03 0.999 1.13E-02 1.000 27.68 31483 70890  
351 6.53E-03 1.000 1.14E-02 0.999 27.82 33903 70890  
352 6.54E-03 1.000 1.12E-02 1.000 27.29 40411 70890  
353 6.34E-03 1.000 1.08E-02 0.999 26.36 42861 70890  
354 6.08E-03 0.999 1.07E-02 1.000 26.14 45323 70890  
355 6.14E-03 1.000 1.04E-02 0.999 25.29 51808 70890  
356 6.34E-03 1.000 1.02E-02 0.999 24.17 54248 70890  
357 6.72E-03 1.000 1.09E-02 1.000 25.91 60722 70890  
358 6.48E-03 1.000 1.03E-02 1.000 24.30 63200 70890  
359 6.82E-03 1.000 9.93E-03 1.000 23.07 65641 70890  
360 7.01E-03 0.999 9.53E-03 1.000 21.31 72118 70890  
361 6.43E-03 1.000 9.84E-03 1.000 22.40 74558 70890  
362 6.26E-03 1.000 9.20E-03 1.000 21.23 81038 70890  
363 Note 10: Maintenance ( Cleanup etc.)  
364  
365

Test OUR1 Coef. OUR2 Coef. SpOUR Time Date  
No mg/Lsec Corr mg/Lsec Corr mg/g/hr HHMMSS MDDYY

366  
367 6.50E-03 1.000 9.10E-03 1.000 20.88 101526 70890  
368 6.42E-03 1.000 9.88E-03 1.000 23.43 104008 70890  
369 6.29E-03 1.000 9.89E-03 1.000 23.71 110431 70890  
370 6.98E-03 0.997 1.02E-02 1.000 23.88 112648 70890  
371 6.77E-03 1.000 1.01E-02 1.000 23.82 115321 70890  
372 7.40E-03 1.000 1.07E-02 0.999 24.88 121748 70890  
373 6.97E-03 1.000 1.10E-02 1.000 26.43 124210 70890  
374 6.85E-03 1.000 1.08E-02 1.000 26.00 130834 70890  
375 7.18E-03 1.000 1.07E-02 0.999 25.01 133056 70890  
376 7.03E-03 1.000 1.08E-02 1.000 25.03 135618 70890  
377 7.08E-03 1.000 1.13E-02 0.999 27.30 141939 70890  
378 7.15E-03 1.000 1.11E-02 1.000 26.52 144356 70890  
379 7.08E-03 1.000 1.18E-02 0.999 26.67 150817 70890  
380 7.17E-03 1.000 1.13E-02 0.999 27.10 153236 70890  
381 7.28E-03 1.000 1.11E-02 0.999 26.29 155657 70890  
382 7.10E-03 1.000 1.10E-02 1.000 26.31 162117 70890  
383 7.00E-03 0.999 1.12E-02 1.000 27.06 164538 70890  
384 6.59E-03 0.997 1.14E-02 1.000 26.10 171000 70890  
385 6.99E-03 0.997 1.14E-02 1.000 27.88 173423 70890  
386 6.99E-03 0.998 1.21E-02 1.000 29.75 175848 70890  
387 6.71E-03 0.999 1.18E-02 1.000 29.30 182306 70890  
388 6.58E-03 1.000 1.21E-02 1.000 30.29 184730 70890  
389 6.46E-03 0.999 1.14E-02 1.000 28.43 191151 70890  
390 6.82E-03 0.998 1.14E-02 1.000 28.01 193812 70890  
391 6.55E-03 1.000 1.12E-02 1.000 27.53 200035 70890  
392 6.77E-03 1.000 1.16E-02 1.000 28.50 202458 70890  
393 6.08E-03 0.998 1.13E-02 0.999 28.43 204921 70890  
394 5.43E-03 0.982 1.14E-02 1.000 29.58 211348 70890  
395 5.77E-03 0.999 1.09E-02 0.999 27.58 213812 70890  
396 5.80E-03 0.951 1.06E-02 1.000 26.44 220244 70890  
397 5.81E-03 1.000 1.10E-02 1.000 27.75 222717 70890  
398 5.49E-03 1.000 1.12E-02 0.999 28.90 226150 70890  
399 5.72E-03 0.999 1.16E-02 1.000 29.82 231812 70890  
400 4.30E-03 0.941 1.15E-02 0.999 31.48 234020 70890  
401 5.93E-03 1.000 1.18E-02 0.999 29.92 437 70890  
402 5.84E-03 1.000 1.23E-02 0.999 31.98 2852 70890  
403 5.54E-03 1.000 1.20E-02 0.999 31.46 5315 70890  
404 5.92E-03 1.000 1.20E-02 1.000 30.00 11733 70890  
405 6.74E-03 0.999 1.15E-02 1.000 28.45 14154 70890  
406 5.80E-03 0.998 1.21E-02 0.999 31.31 20601 70890  
407 5.84E-03 1.000 1.13E-02 0.991 28.11 23025 70890  
408 5.74E-03 1.000 1.13E-02 0.999 28.94 25448 70890  
409 5.78E-03 1.000 1.11E-02 0.999 28.32 31813 70890  
410 5.90E-03 1.000 1.15E-02 0.999 29.70 34338 70890  
411 5.81E-03 1.000 1.08E-02 1.000 27.40 40788 70890  
412 5.45E-03 0.998 1.09E-02 0.999 27.89 43228 70890  
413 5.81E-03 1.000 1.12E-02 1.000 28.65 46653 70890  
414 5.75E-03 0.997 1.06E-02 1.000 28.38 52120 70890  
415 5.75E-03 0.997 8.04E-03 0.999 18.47 54845 70890  
416 6.89E-03 0.991 1.06E-02 1.000 28.25 60857 70890  
417 5.32E-02 1.000 1.03E-02 0.999 36.13 63410 70890  
418 5.38E-03 1.000 1.05E-02 1.000 26.87 66822 70890  
419 5.07E-03 1.000 8.94E-03 1.000 22.22 72242 70890  
420  
421  
422 5.58E-03 0.999 1.49E-02 1.000 56.82 84428 70890  
423 5.52E-03 1.000 1.18E-02 1.000 43.54 81002 70890  
424 6.44E-03 1.000 1.00E-02 1.000 36.19 83411 70890  
425 5.27E-03 1.000 1.12E-02 1.000 40.83 85827 70890  
426 5.44E-03 1.000 1.19E-02 1.000 38.53 102251 70890  
427 5.54E-03 1.000 1.13E-02 0.998 40.88 104718 70890  
428 5.04E-03 0.998 1.11E-02 0.999 40.72 111153 70890  
429 5.84E-03 1.000 1.38E-02 1.000 50.80 113616 70890  
430 5.89E-03 1.000 1.25E-02 1.000 46.47 120033 70890  
431 5.87E-03 1.000 1.72E-02 1.000 88.87 122608 70890  
432 6.02E-03 1.000 1.81E-02 1.000 75.20 124629 70890  
433 6.05E-03 1.000 1.58E-02 1.000 60.84 131353 70890  
434 6.12E-03 1.000 1.29E-02 1.000 47.20 133819 70890  
435 6.29E-03 1.000 1.48E-02 1.000 54.66 140243 70890  
436 Note 11: Computer disk memory full  
437  
438

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept. 1, 1990)**

Test	OUR 1 mg/L/sec	Coef Corr	OUR 2 mg/L/sec	Coef Corr	SpOUR mg/g/hr	Time HHMMSS	Date DDYY
439							
440							
441							
442							
443							
444							
445							
446							
447							
448							
449							
450							
451	5.98E-03	0.990	1.68E-02	0.998	64.85	202042	70999
452	4.83E-03	1.000	1.73E-02	1.000	69.32	204509	70999
453	5.25E-03	1.000	1.69E-02	1.000	66.78	210833	70999
454	4.54E-03	1.000	1.54E-02	1.000	61.10	213406	70999
455	4.68E-03	1.000	1.42E-02	0.999	56.27	223003	70999
456	5.61E-03	1.000	1.66E-02	1.000	65.36	225429	70999
457	5.21E-03	1.000	1.57E-02	1.000	61.12	231851	70999
458	5.18E-03	1.000	1.53E-02	1.000	59.58	234313	70999
459	5.20E-03	0.999	1.37E-02	1.000	52.56	725	71000
460	5.44E-03	1.000	1.45E-02	0.999	56.32	3151	71000
461	5.35E-03	0.999	1.64E-02	1.000	64.31	5802	71000
462	5.43E-03	1.000	1.71E-02	0.998	67.38	12025	71000
463	5.28E-03	1.000	1.61E-02	0.999	63.04	14451	71000
464	5.52E-03	1.000	1.48E-02	1.000	56.54	20922	71000
466	5.28E-03	1.000	1.58E-02	1.000	61.71	23048	71000
468	5.38E-03	1.000	1.82E-02	0.999	63.40	25189	71000
467	5.34E-03	1.000	1.46E-02	1.000	58.06	32243	71000
468	5.37E-03	0.999	1.18E-02	1.000	43.53	34765	71000
469	5.21E-03	1.000	1.22E-02	0.999	45.37	41120	71000
470	5.09E-03	1.000	1.59E-02	0.999	62.31	43534	71000
471	5.14E-03	1.000	1.39E-02	0.999	53.52	45956	71000
472	4.30E-03	0.999	1.01E-02	1.000	38.87	52411	71000
473	4.88E-03	1.000	1.08E-02	0.999	39.48	54840	71000
474	5.20E-03	1.000	1.30E-02	1.000	46.26	61258	71000
475	4.58E-03	1.000	1.29E-02	1.000	49.73	63717	71000
476	5.01E-03	1.000	1.26E-02	1.000	48.56	70157	71000
477	4.71E-03	1.000	1.26E-02	1.000	48.37	72823	71000
478							
479	4.57E-03	1.000	8.58E-03	1.000	37.03	82123	71000
480	4.88E-03	1.000	1.10E-02	1.000	49.40	84832	71000
481	4.78E-03	1.000	9.58E-03	0.999	42.03	91060	71000
482	4.97E-03	1.000	1.25E-02	0.999	57.58	82.906	71000
483	5.02E-03	1.000	1.13E-02	1.000	50.88	96802	71000
484	5.12E-03	0.999	1.34E-02	0.999	62.51	102410	71000
485	5.03E-03	1.000	1.43E-02	1.000	67.58	104840	71000
486	5.01E-03	1.000	1.40E-02	1.000	65.99	111308	71000
487	7.28E-03	0.999	1.36E-02	0.999	58.78	113741	71000
488	5.11E-03	1.000	1.34E-02	0.938	62.24	120155	71000
489	4.83E-03	1.000	1.28E-02	0.999	60.17	122811	71000
490	5.38E-03	1.000	1.32E-02	0.999	60.51	125026	71000
491	5.32E-03	1.000	1.38E-02	0.999	64.02	131508	71000
492	5.44E-03	1.000	1.43E-02	1.000	66.46	133222	71000
493	5.51E-03	1.000	1.27E-02	1.000	57.71	140339	71000
494	5.50E-03	0.994	1.43E-02	1.000	68.17	142752	71000
496	4.94E-03	1.000	1.36E-02	1.000	63.91	142608	71000
496	5.12E-03	0.991	1.29E-02	1.000	50.79	151226	71000
497	5.28E-03	0.999	1.32E-02	1.000	60.67	154108	71000
498	5.08E-03	0.998	1.37E-02	0.999	63.81	160522	71000
499	5.24E-03	0.995	1.35E-02	1.000	62.42	162941	71000
500	8.18E-03	0.999	1.65E-02	0.999	77.12	185403	71000
501	6.01E-03	1.000	1.50E-02	0.999	73.99	171834	71000
502	6.01E-03	1.000	1.80E-02	1.000	74.45	174250	71000
503	5.86E-03	1.000	1.55E-02	1.000	71.92	180708	71000
504	5.75E-03	0.998	1.79E-02	1.000	85.39	183125	71000
505	8.73E-03	0.993	1.85E-02	1.000	88.97	185541	71000
506	8.09E-03	0.999	1.77E-02	1.000	83.78	191964	71000
507	5.71E-03	1.000	1.69E-02	1.000	75.95	194411	71000
508	6.09E-03	1.000	1.75E-02	0.999	82.44	200832	71000
509	5.79E-03	1.000	1.43E-02	1.000	65.75	203340	71000
510	5.52E-03	1.000	1.58E-02	1.000	74.78	205618	71000
511	5.89E-03	1.000	1.69E-02	1.000	80.38	212231	71000

Test No.	OUR 1 mg/Lsec	Coef Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/lhr	Time HHMMSS	Date MDDYY
512	5.79E-03	1.000	1.84E-02	1.000	88.21	214858	71190
513	5.88E-03	1.000	1.80E-02	1.000	85.93	221108	71190
514	5.89E-03	1.000	1.48E-02	1.000	88.51	223524	71190
515	5.54E-03	1.000	1.73E-02	1.000	83.03	230013	71190
516	5.75E-03	1.000	1.66E-02	1.000	78.25	232532	71190
517							
518	5.35E-03	1.000	1.58E-02	1.000	67.95	2046	71190
519	5.65E-03	1.000	1.68E-02	0.999	73.22	4500	71190
520	5.67E-03	1.000	1.62E-02	0.999	70.61	10914	71190
521	5.55E-03	0.999	1.62E-02	1.000	70.39	13340	71190
522	5.73E-03	1.000	1.50E-02	1.000	88.64	15820	71190
523	5.74E-03	1.000	1.41E-02	1.000	59.44	22250	71190
524	5.79E-03	1.000	1.38E-02	1.000	58.05	24711	71190
525	5.54E-03	1.000	1.65E-02	1.000	72.44	31144	71190
526	5.75E-03	1.000	1.63E-02	1.000	70.98	33623	71190
527	5.68E-03	1.000	1.30E-02	1.000	54.25	40103	71190
528	5.66E-03	1.000	1.49E-02	1.000	63.84	42538	71190
529	5.56E-03	1.000	1.20E-02	1.000	49.63	45004	71190
530	5.41E-03	1.000	1.54E-02	1.000	67.14	51431	71190
531	5.30E-03	1.000	1.04E-02	1.000	41.87	53306	71190
532	5.06E-03	1.000	1.01E-02	0.999	40.98	60343	71190
533	5.08E-03	1.000	1.13E-02	1.000	46.84	62758	71190
534	5.16E-03	1.000	1.10E-02	1.000	45.33	65237	71190
535	4.98E-03	1.000	9.80E-03	1.000	38.48	71707	71190
536	4.96E-03	1.000	1.41E-02	1.000	81.30	74128	71190
537	5.01E-03	1.000	9.23E-03	0.949	36.52	80805	71190
538	5.47E-03	1.000	1.58E-02	0.999	69.87	83015	71190
539	5.29E-03	1.000	1.45E-02	0.999	82.69	85436	71190
540	5.57E-03	1.000	1.67E-02	1.000	73.05	91904	71190
541	5.34E-03	1.000	1.16E-02	0.999	47.98	94326	71190
542	5.40E-03	1.000	1.38E-02	0.999	42.81	100749	71190
543	5.18E-03	1.000	1.45E-02	0.999	62.84	103206	71190
544	5.80E-03	1.000	1.50E-02	1.000	64.88	105636	71190
545	5.75E-03	1.000	1.04E-02	1.000	81.28	112058	71190
546	5.82E-03	1.000	1.68E-02	0.999	72.79	114821	71190
547	5.82E-03	1.000	1.18E-02	1.000	47.87	120629	71190
548	5.31E-03	1.000	1.15E-02	1.000	47.58	123351	71190
549	5.86E-03	0.999	1.23E-02	1.000	50.88	125820	71190
550	5.98E-03	1.000	1.87E-02	1.000	72.38	132229	71190
551	Note 12: Solenoid #3 not functioning						
552							
553							
554							
555							
556							
557							
558							
559							
560							
561							
562							
563							
564							
565							
566							
567							
568							
569							
570							
571	6.04E-03	0.999	1.86E-02	1.000	82.98	214422	71190
572	5.00E-03	1.000	1.68E-02	1.000	82.77	220861	71190
573	5.22E-03	1.000	1.74E-02	1.000	88.59	223307	71190
574	5.29E-03	1.000	1.84E-02	0.999	94.13	226718	71190
575	5.50E-03	1.000	1.86E-02	1.000	93.87	232139	71190
576	5.82E-03	1.000	1.52E-02	1.000	74.27	234554	71190
577	6.03E-03	1.000	1.45E-02	1.000	69.95	1019	71290
578	5.93E-03	1.000	1.23E-02	1.000	57.57	3428	71290
579	5.42E-03	1.000	1.53E-02	1.000	75.48	5867	71290
580	5.65E-03	1.000	1.79E-02	1.000	90.20	12330	71290
581	5.72E-03	1.000	1.42E-02	1.000	88.73	14801	71290
582	5.84E-03	1.000	1.32E-02	1.000	82.88	21207	71290
583	5.44E-03	1.000	1.09E-02	1.000	101.82	26618	71290
584	5.37E-03	1.000	1.58E-02	1.000	77.35	30027	71290

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept. 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY
----------	---------------	-------------	---------------	-------------	---------------	-------------	------------

585	5.17E-03	1.000	1.21E-02	1.000	57.99	32440	71290
586	5.24E-03	1.000	1.11E-02	1.000	52.04	34852	71290
587	5.41E-03	1.000	1.18E-02	0.999	54.24	41303	71290
588	5.27E-03	1.000	1.14E-02	0.999	53.71	43712	71290
589	5.40E-03	1.000	1.18E-02	0.999	55.36	50120	71290
590	5.24E-03	1.000	1.57E-02	0.999	78.68	52527	71290
591	5.13E-03	1.000	1.12E-02	0.999	52.92	54933	71290
592	4.87E-03	1.000	1.13E-02	1.000	53.85	61341	71290
593	4.90E-03	1.000	1.23E-02	1.000	59.52	63745	71290
594	4.80E-03	1.000	1.13E-02	0.999	54.48	70154	71290
595	4.88E-03	1.000	9.68E-03	0.999	41.45	75129	71290
596	4.80E-03	0.999	1.14E-02	1.000	54.42	81541	71290
597	4.98E-03	1.000	1.09E-02	1.000	51.92	83845	71290
598	4.81E-03	1.000	1.19E-02	1.000	58.28	90349	71290
599	4.78E-03	1.000	7.89E-03	1.000	34.47	92745	71290
600	2.88E-04	0.987	9.82E-03	1.000	58.00	96152	71290
601	5.38E-03	1.000	1.73E-02	1.000	87.18	101556	71290
602	4.93E-03	1.000	4.08E-03	1.000	12.19	103640	71290
603	2.78E-04	0.974	1.65E-02	1.000	94.28	110341	71290
604	3.06E-04	0.999	1.13E-02	1.000	64.55	112741	71290
605	7.59E-04	0.998	1.30E-02	0.999	74.28	115142	71290
606	3.17E-04	0.998	1.02E-02	1.000	58.20	121802	71290
607	3.15E-04	0.998	1.00E-02	1.000	58.73	124016	71290
608	3.05E-04	1.000	1.57E-02	1.000	75.32	130339	71290
609	6.65E-02	1.000	1.50E-02	0.999	70.76	132726	71290
610	5.79E-03	1.000	1.58E-02	0.999	78.53	136129	71290
611	8.27E-03	1.000	1.59E-02	0.999	77.75	141531	71290
612	8.11E-03	1.000	1.52E-02	1.000	73.47	143936	71290
613							
614	Note 13: No SpOUR work during 12-13 July						
615							
616	2.47E-03	1.000	6.52E-03	1.000	31.14	120039	71400
617	7.98E-03	0.981	1.38E-02	1.000	58.31	122443	71400
618	9.80E-03	1.000	1.18E-02	1.000	43.30	124852	71400
619	6.81E-03	0.999	1.08E-02	1.000	45.19	131303	71400
620	3.81E-03	1.000	5.41E-03	0.999	15.08	133716	71400
621	6.89E-03	0.999	1.47E-02	1.000	67.74	140127	71400
622	6.95E-03	1.000	1.03E-02	0.999	43.14	142559	71400
623	6.74E-03	0.999	1.05E-02	0.999	43.98	144982	71400
624	6.98E-03	0.993	1.97E-02	0.999	95.22	151420	71400
625	7.03E-03	1.000	1.88E-02	1.000	78.44	153833	71400
626	6.91E-03	1.000	1.11E-02	0.999	47.10	180318	71400
627	6.42E-03	1.000	1.15E-02	1.000	50.47	182727	71400
628	6.84E-03	1.000	1.88E-02	1.000	90.79	185154	71400
629	6.59E-03	1.000	1.18E-02	1.000	51.88	171807	71400
630	6.59E-03	1.000	1.52E-02	0.999	70.41	174015	71400
631	7.20E-03	1.000	1.10E-02	0.999	45.58	180428	71400
632	Note 14: No test due to low Raw Influent flow						
633							
634							
635							
636							
637							
638							
639	4.48E-03	1.000	1.05E-02	0.999	44.41	212221	71400
640	8.58E-03	1.000	1.21E-02	0.999	48.76	214847	71400
641	6.99E-03	1.000	1.18E-02	0.999	51.18	221118	71400
642	6.81E-03	1.000	1.11E-02	0.999	47.78	223531	71400
643	6.82E-03	1.000	1.13E-02	0.999	47.81	225845	71400
644	6.86E-03	1.000	1.12E-02	0.999	47.58	232368	71400
645	7.00E-03	1.000	1.13E-02	1.000	47.86	234811	71400
646	6.24E-03	1.000	1.15E-02	0.999	50.82	1239	71500
647	7.14E-03	1.000	1.14E-02	0.999	48.00	3852	71500
648	7.17E-03	1.000	1.96E-02	1.000	95.83	10106	71500
649	7.07E-03	1.000	2.11E-02	0.999	103.04	12517	71500
650	7.11E-03	1.000	1.24E-02	1.000	53.79	14830	71500
651	7.13E-03	1.000	1.17E-02	0.999	49.91	21343	71500
652	7.18E-03	1.000	1.14E-02	0.999	47.74	23757	71500
653							
654							
655							
656							
657							
658							
659							
660							
661							
662							
663							
664							
665							
666							
667							
668							
669							
670							
671							
672							
673							
674							
675							
676							
677							
678							
679							
680							
681							
682							
683							
684							
685							
686							
687							
688							
689							
690							
691							
692							
693							
694							
695							
696							
697							
698							
699							
700							
701							
702							
703							
704							
705							
706							
707							
708							
709							
710							
711							
712							
713							
714							
715							
716							
717							
718							
719							
720							
721							
722							
723							
724							
725							
726							
727							
728							
729							
730							

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY
731	4.03E-03	1.000	1.18E-02	0.999	57.21	131551	71890	804	1.18E-02	0.998	1.18E-02	1.000	38.55	181700	71790
732	4.08E-03	1.000	7.41E-03	0.999	32.54	134001	71890	805	1.38E-02	0.994	9.79E-03	0.999	23.92	184126	71790
733	3.91E-03	1.000	7.30E-03	0.999	32.29	140412	71890	806	4.93E-03	1.000	8.28E-03	0.998	35.51	200552	71790
734	3.91E-03	1.000	7.44E-03	0.999	33.04	142826	71890	807	1.20E-02	0.978	8.81E-03	0.999	26.28	203016	71790
735	3.88E-03	1.000	7.83E-03	0.999	35.30	145240	71890	808							
736	3.81E-03	1.000	9.88E-03	0.999	45.65	151855	71890	809							
737	3.88E-03	1.000	1.05E-02	0.999	50.12	154110	71890	810							
738	3.90E-03	1.000	1.01E-02	1.000	48.02	180525	71890	811							
739	3.95E-03	1.000	9.78E-03	1.000	48.03	182858	71890	812							
740	4.04E-03	1.000	1.05E-02	1.000	50.17	186354	71890	813	6.58E-03	1.000	1.25E-02	0.999	55.70	231053	71790
741	3.91E-03	1.000	1.21E-02	1.000	59.34	171809	71890	814	6.58E-03	1.000	1.18E-02	0.999	51.74	233511	71790
742	4.15E-03	1.000	1.12E-02	0.999	53.88	174222	71890	815	6.18E-03	1.000	9.73E-03	0.999	40.83	235837	71790
743	4.38E-03	1.000	1.24E-02	0.999	50.74	180837	71890	816	7.08E-03	1.000	1.25E-02	0.994	54.11	2356	71890
744	4.57E-03	1.000	1.17E-02	0.999	55.44	183048	71890	817	8.50E-03	1.000	9.77E-03	0.999	40.34	4819	/1890
745	4.50E-03	1.000	1.08E-02	0.999	50.04	186503	71890	818	8.56E-03	1.000	1.38E-02	1.000	61.96	11242	71890
746	4.29E-03	1.000	1.09E-02	0.999	51.57	191918	71890	819	6.58E-03	1.000	9.90E-03	0.999	40.90	13703	71890
747	4.22E-03	1.000	1.12E-02	0.999	53.79	194331	71890	820	5.09E-03	0.998	1.03E-02	0.999	48.27	20132	71890
748	4.38E-03	1.000	1.15E-02	0.999	56.03	200747	71890	821	6.13E-03	1.000	8.80E-03	0.999	34.95	22558	71890
749	4.29E-03	1.000	1.20E-02	1.000	58.06	203203	71890	822	6.19E-03	1.000	9.46E-03	0.999	36.42	25025	71890
750	4.28E-03	1.000	1.10E-02	0.999	-2.31	205820	71890	823	6.22E-03	1.000	8.85E-03	0.999	34.88	31502	71890
751	4.27E-03	1.000	1.20E-02	1.000	57.84	212036	71890	824	6.17E-03	1.000	8.65E-03	0.991	23.56	33041	71890
752	4.37E-03	1.000	9.05E-03	0.999	41.06	214452	71890	825	5.88E-03	1.000	7.67E-03	0.999	29.92	40425	71890
753	4.08E-03	1.000	1.02E-02	0.999	48.17	220908	71890	826	5.53E-03	0.999	7.11E-03	0.999	27.58	42002	71890
754								827	5.36E-03	0.999	1.18E-02	1.000	54.58	45337	71890
755								828	5.69E-03	1.000	9.73E-03	0.999	41.94	51808	71890
756	5.93E-03	1.000	6.08E-03	0.999	20.73	232627	71890	829							
757	6.41E-03	1.000	5.48E-03	0.999	16.40	235044	71890	830							
758	6.44E-03	1.000	5.71E-03	0.992	17.84	1510	71790	831							
759	6.54E-03	0.999	5.80E-03	0.993	18.07	3934	71790	832							
760	6.52E-03	0.989	5.51E-03	0.994	18.34	10367	71790	833							
761	6.01E-03	1.000	6.39E-03	0.999	22.43	12626	71790	834							
762	3.03E-03	0.997	6.46E-03	0.999	29.53	15310	71790	835	7.08E-03	1.000	8.42E-03	0.997	20.88	82342	71890
763	6.33E-03	1.000	8.37E-03	0.999	21.80	21272	71790	836	5.81E-03	0.999	9.79E-03	0.994	43.32	84812	71890
764	6.00E-03	1.000	8.40E-03	0.994	22.48	24158	71790	837	5.88E-03	0.999	8.31E-03	0.995	22.99	91239	71890
765	5.99E-03	1.000	6.13E-03	0.997	21.00	30624	71790	838	5.68E-03	0.999	1.17E-02	0.999	54.60	93704	71890
766	5.88E-03	1.000	5.82E-03	0.995	20.04	33045	71790	839	5.73E-03	1.000	8.25E-03	0.992	22.97	10123	71890
767	5.69E-03	1.000	5.81E-03	0.999	19.98	36615	71790	840	5.93E-03	0.999	5.50E-03	0.994	18.14	102540	71890
768	5.58E-03	1.000	5.39E-03	0.999	17.85	41948	71790	841	5.88E-03	0.999	5.80E-03	0.994	20.00	104958	71890
769	5.41E-03	0.999	4.87E-03	0.998	14.12	44409	71790	842	5.92E-03	1.000	6.19E-03	0.992	22.17	111418	71890
770	5.32E-03	1.000	5.79E-03	0.995	20.58	50841	71790	843	5.86E-03	0.999	6.99E-03	0.991	27.01	113832	71890
771	5.18E-03	1.000	5.18E-03	0.995	17.38	53314	71790	844	6.18E-03	0.999	8.88E-03	0.994	29.19	120249	71890
772	5.14E-03	1.000	5.15E-03	0.995	17.38	55741	71790	845	6.25E-03	1.000	8.28E-03	0.995	21.02	122701	71890
773	4.93E-03	0.919	5.39E-03	0.995	19.26	62219	71790	846	5.90E-03	1.000	6.47E-03	0.994	23.87	125110	71890
774	4.69E-03	1.000	3.22E-03	0.995	18.38	64652	71790	847	5.06E-03	0.999	8.30E-03	0.995	34.97	131524	71890
775	4.74E-03	0.999	5.31E-03	0.997	19.21	71122	71790	848	4.80E-03	0.998	1.06E-02	0.994	50.44	133633	71890
776	4.58E-03	0.999	5.29E-03	0.999	19.48	73600	71790	849	5.63E-03	0.997	8.04E-03	0.997	33.80	140344	71890
777	4.41E-03	0.999	5.01E-03	0.997	18.27	8038	71790	850	5.77E-03	0.999	8.80E-03	0.993	37.88	142758	71890
778	6.32E-03	1.000	7.77E-03	0.999	29.50	82143	71790	851							
779	6.22E-03	1.000	6.82E-03	0.999	22.88	84613	71790	852							
780	5.63E-03	1.000	1.10E-02	0.999	40.40	93202	71790	853							
781	5.24E-03	1.000	8.29E-03	0.999	34.82	26523	71790	854							
782	4.85E-03	1.000	1.30E-02	0.999	58.55	102047	71790	855	5.48E-03	1.000	9.58E-03	0.999	42.84	165335	71890
783	4.52E-03	0.998	9.30E-03	1.000	42.82	104518	71790	856	5.63E-03	0.999	8.81E-03	0.995	38.07	17765	71890
784	5.06E-03	1.000	9.39E-03	1.000	40.94	110935	71790	857	5.84E-03	1.000	9.86E-03	0.999	38.41	174208	71890
785	4.91E-03	1.000	9.75E-03	0.999	38.18	113353	71790	858	6.41E-03	0.999	1.15E-02	0.998	51.88	180821	71890
786	4.84E-03	1.000	9.70E-03	0.999	43.67	115811	71790	859	6.31E-03	0.999	7.64E-03	0.998	29.88	183038	71890
787	4.67E-03	0.999	9.93E-03	0.999	43.39	122232	71790	860	6.46E-03	0.999	8.09E-02	0.992	48.22	185450	71890
788	4.74E-03	1.000	8.84E-03	1.000	44.69	124651	71790	861	6.58E-03	0.999	7.39E-03	0.997	27.61	181902	71890
789	4.72E-03	1.000	8.24E-03	1.000	41.37	131111	71790	862	5.58E-03	0.999	7.55E-03	0.997	30.81	194318	71890
790	5.29E-03	0.981	1.02E-02	1.000	45.51	133531	71790	863	5.32E-03	0.999	7.88E-03	0.994	33.12	200733	71890
791	4.91E-03	1.000	1.08E-02	1.000	49.83	136567	71790	864	6.01E-03	0.999	8.63E-03	0.994	36.15	203142	71890
792	4.74E-03	1.000	1.23E-02	1.000	58.56	142416	71790	865	6.14E-03	0.999	7.74E-03	0.993	30.71	205563	71890
793	4.94E-03	1.000	1.24E-02	0.999	58.50	144657	71790	866	6.15E-03	0.999	8.86E-03	0.991	28.11	212007	71890
794	5.19E-03	1.000	1.15E-02	1.000	52.82	151302	71790	867	5.34E-03	0.995	9.20E-03	0.997	41.02	214418	71890
795	5.15E-03	1.000	1.18E-02	0.999	54.87	153720	71790	868	5.67E-03	0.999	7.40E-03	0.998	29.77	220831	71890
796	5.03E-03	1.000	1.10E-02	0.999	50.74	180136	71790	869	5.72E-03	0.999	8.64E-03	0.990	25.25	223244	71890
797	4.21E-02	0.998	1.18E-02	0.994											

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 26 to Sept. 1, 1990)

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 26 to Sept 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY
877	6.48E-03	1.000	9.05E-03	0.994	35.19	15037	71900	950	2.55E-04	0.904	1.69E-03	0.998	7.54	71012	72080
878	6.48E-03	0.998	8.45E-03	0.987	31.94	22354	71900	951	2.88E-05	0.300	3.55E-03	0.999	16.74	73413	72000
879	5.52E-03	0.999	6.80E-03	0.996	21.78	24614	71900	952							
880	6.02E-03	0.999	6.86E-03	0.998	24.26	31203	71900	953	2.48E-03	0.998	2.59E-03	1.000	7.62	83631	72080
881	6.19E-03	0.999	6.74E-03	0.992	23.29	33644	71900	954	1.04E-03	0.985	1.42E-03	0.994	4.73	85804	72080
882	6.26E-03	1.000	6.21E-03	0.983	20.17	40101	71900	956	9.83E-05	0.843	2.70E-03	0.998	12.80	92303	72080
883	5.71E-03	0.999	6.43E-03	0.992	22.61	42515	71900	958	5.30E-04	0.985	4.34E-03	0.994	16.54	94704	72080
884	5.90E-03	0.999	6.56E-03	0.993	23.10	44926	71900	957	6.18E-04	1.001	1.26E-03	0.992	4.81	101059	72080
885	5.18E-03	0.999	6.10E-03	0.995	21.97	51344	71900	958	1.20E-03	0.994	2.70E-03	0.999	10.51	103425	72080
886	5.53E-03	0.999	6.34E-03	0.990	22.52	53758	71900	959	3.57E-04	0.984	1.37E-03	0.992	5.82	105825	72080
887	5.48E-03	0.999	6.66E-03	0.994	24.40	80213	71900	960	1.06E-03	0.978	3.36E-03	0.994	14.08	112152	72080
888	5.50E-03	0.999	6.34E-03	0.994	22.80	82631	71900	961	1.09E-03	0.989	4.27E-03	0.982	16.16	114555	72080
889	5.41E-03	0.999	7.22E-03	0.991	27.59	85044	71900	962	3.82E-04	0.985	1.84E-03	0.992	7.98	120952	72080
890	5.15E-03	0.998	1.04E-02	0.996	45.41	71450	71900	963	3.75E-04	1.000	2.82E-04	0.943	0.62	123344	72080
891	4.78E-03	0.999	5.17E-03	0.984	17.79	73902	71900	964	9.84E-04	0.999	2.22E-03	0.958	8.83	125748	72080
892								965							
893								966	4.18E-03	0.999	1.53E-02	1.000	64.44	136438	72080
894	5.47E-03	0.999	6.41E-03	0.993	21.89	15149	71900	967	5.37E-03	1.000	1.45E-02	1.000	58.71	141904	72080
895	4.75E-03	0.999	3.83E-03	0.914	9.93	15155	71900	968	5.06E-03	1.000	1.42E-02	1.000	57.88	144323	72080
896	4.50E-03	1.000	5.87E-03	0.912	20.96	15156	71900	969	5.57E-03	1.000	1.54E-02	1.000	62.24	150753	72080
897	4.99E-03	0.999	4.74E-03	0.998	14.11	16215	71900	970	5.45E-03	1.000	1.47E-02	1.000	58.17	153226	72080
898	4.81E-03	0.999	4.14E-03	0.981	11.41	10144	71900	971	5.27E-03	1.000	1.50E-02	0.999	61.24	155659	72080
899	4.69E-03	0.999	6.01E-03	0.987	21.27	104050	71900	972	5.81E-03	1.000	1.44E-02	0.999	57.32	162134	72080
900	5.18E-03	0.999	6.52E-03	0.992	22.86	110451	71900	973	5.40E-03	1.000	1.48E-02	1.000	58.87	164805	72080
901	3.82E-03	1.000	6.82E-03	0.994	28.15	112647	71900	974	5.71E-03	1.000	1.53E-02	0.999	61.64	171038	72080
902	4.89E-03	0.999	8.81E-03	0.990	24.98	115247	71900	975	5.57E-03	1.000	1.42E-02	0.999	58.72	173608	72080
903	4.37E-03	0.999	6.28E-03	0.985	23.30	121651	71900	976	5.77E-03	1.000	1.36E-02	1.000	53.05	175903	72080
904	5.24E-03	0.999	5.74E-03	0.988	18.73	124053	71900	977	5.58E-03	1.000	1.41E-02	0.999	56.24	182364	72080
905	4.30E-03	0.999	8.84E-03	0.994	36.64	130458	71900	978	5.58E-03	1.000	1.48E-02	0.999	59.53	184815	72080
906	4.99E-03	0.999	4.71E-03	0.982	13.96	132829	71900	979	5.52E-03	1.000	1.42E-02	1.000	56.88	191239	72080
907	4.48E-03	0.999	9.77E-03	0.988	41.01	136229	71900	980	5.59E-03	1.000	1.37E-02	0.999	54.30	193659	72080
908	3.67E-03	0.999	8.25E-03	0.995	34.89	141632	71900	981	6.52E-03	1.000	1.42E-02	0.999	56.07	200119	72080
909	5.32E-03	0.999	7.07E-03	0.991	25.40	144036	71900	982	5.80E-03	1.000	1.44E-02	0.999	57.00	202540	72080
910	4.74E-03	0.999	5.74E-03	0.988	23.03	150437	71900	983	5.80E-03	1.000	1.36E-02	0.999	52.89	205001	72080
911	4.89E-03	0.999	6.49E-03	0.993	29.65	152838	71900	984	5.71E-03	1.000	1.47E-02	0.999	58.72	211420	72080
912	5.05E-03	0.999	8.71E-03	0.993	34.42	156239	71900	985	5.78E-03	1.000	1.33E-02	0.999	52.12	213640	72080
913	2.65E-03	0.999	6.49E-03	0.985	27.93	161653	71900	986	5.69E-03	1.000	1.25E-02	0.999	48.59	220258	72080
914	5.12E-03	0.997	9.17E-03	0.988	31.82	164100	71900	987	7.61E-03	1.000	1.58E-02	1.000	60.40	222716	72080
915	5.29E-03	0.999	7.49E-03	0.983	27.82	170615	71900	988	7.78E-03	1.000	1.58E-02	0.999	59.97	225137	72080
916	5.24E-03	0.999	5.22E-03	0.979	16.05	172622	71900	989	7.57E-03	1.000	1.77E-02	1.000	69.87	231567	72080
917	4.67E-03	0.993	5.69E-03	0.983	10.83	175325	71900	990	7.40E-03	1.000	1.68E-02	1.000	75.27	234018	72080
918	4.58E-03	0.997	5.25E-03	0.988	17.59	181724	71900	991	7.13E-03	1.000	1.73E-02	0.999	69.53	443	72180
919	4.19E-03	0.997	4.82E-03	0.982	18.68	184126	71900	992	7.22E-03	1.000	1.48E-02	1.000	58.35	2811	72180
920	4.23E-03	0.999	4.33E-03	0.989	13.58	190623	71900	993	6.81E-03	1.000	1.44E-02	1.000	56.39	5338	72180
921	4.30E-03	0.999	5.88E-03	0.993	21.11	192831	71900	994	6.61E-03	1.000	1.68E-02	0.999	67.43	11806	72180
922	4.09E-03	0.997	4.80E-03	0.982	15.23	196334	71900	995	6.60E-03	1.000	1.70E-02	1.000	67.85	14232	72180
923	4.22E-03	0.998	5.00E-03	0.988	17.01	201741	71900	996	6.70E-03	1.000	1.63E-02	0.999	64.37	20654	72180
924	4.06E-03	0.999	5.14E-03	0.984	18.06	204148	71900	997	6.57E-03	1.000	1.58E-02	1.000	62.32	23124	72180
925	6.80E-03	0.999	6.12E-03	0.988	17.48	210548	71900	998	5.93E-03	1.000	1.38E-02	0.999	54.28	25660	72180
926	5.34E-03	0.999	6.32E-03	0.984	21.50	212960	71900	999	6.48E-03	1.000	1.38E-02	1.000	52.33	32015	72180
927								1000	6.02E-03	1.000	1.32E-02	0.999	51.34	34464	72180
928	5.92E-03	0.999	6.17E-03	0.987	18.02	222709	71900	1001	5.94E-03	1.000	1.28E-02	0.999	49.20	49031	72180
929	5.36E-03	0.999	5.71E-03	0.981	16.88	225114	71900	1002	6.02E-03	1.000	1.19E-02	0.999	46.08	43400	72180
930	6.13E-03	0.999	5.46E-03	0.982	14.25	230157	71900	1003	5.82E-03	1.000	1.23E-02	0.999	47.30	45839	72180
931	1.13E-03	0.983	6.94E-03	0.984	30.68	233018	71900	1004	5.83E-03	1.000	1.16E-02	0.999	44.19	52314	72180
932	5.54E-03	0.993	5.98E-03	0.984	17.82	322	72080	1006	5.42E-03	1.000	1.11E-02	0.999	42.12	64754	72180
933	5.81E-03	0.999	6.18E-03	0.992	18.27	2724	72080	1008	5.41E-03	1.000	1.07E-02	0.999	40.63	81236	72180
934	1.48E-03	0.992	6.57E-03	0.980	28.35	5102	72080	1007	5.54E-03	1.000	9.74E-03	1.000	36.88	83713	72180
935	1.55E-03	0.999	5.90E-03	0.981	17.38	11502	72080	1008	5.38E-03	1.000	9.51E-03	1.000	34.84	70153	72180
936	4.03E-03	0.998	6.98E-03	0.983	25.48	13656	72080	1009							
937	1.03E-04	0.829	8.38E-03	0.984	30.48	20303	72080	1010							
938	3.88E-03	0.999	5.58E-03	0.988	18.97	22867	72080	1011							
939	4.89E-03	0.999	3.84E-03	0.980	9.31	25028	72080	1012	5.40E-03	1.000	9.08E-03	0.999	32.88	83738	72180
940	2.90E-03	0.999	6.10E-03	0.982	23.22	31433	72080	1013	5.23E-03	1.000	7.98E				

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)

Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY
1023	4.90E-03	1.000	7.48E-03	0.999	26.14	130556	72190	1096	5.90E-03	1.000	1.01E-02	0.999	36.59	180759	72290
1024	3.82E-03	0.999	7.57E-03	1.000	29.00	133016	72190	1097	5.90E-03	1.000	9.98E-03	0.999	34.56	183212	72290
1025	4.52E-03	1.000	1.13E-02	0.999	45.07	135429	72190	1098	5.55E-03	1.000	9.95E-03	0.999	35.20	185625	72290
1026	7.09E-03	0.999	1.03E-02	1.000	35.46	141844	72190	1099	5.80E-03	1.000	6.22E-03	0.999	32.44	182039	72291
1027	7.59E-03	1.000	9.83E-03	1.000	31.24	144250	72190	1100							
1028	5.98E-03	1.000	8.75E-03	0.999	30.11	150716	72190	1101							
1029	7.04E-03	1.000	8.33E-03	0.999	26.10	153129	72190	1102							
1030	7.28E-03	1.000	8.99E-03	0.999	39.32	158544	72190	1103							
1031	6.59E-03	1.000	1.10E-02	1.000	39.81	161068	72190	1104	7.52E-03	1.000	8.40E-03	0.999	25.56	213311	72290
1032	6.32E-03	1.000	1.09E-02	1.000	39.82	164414	72190	1105	7.33E-03	1.000	1.01E-02	0.999	34.00	215722	72290
1033	Note 15 Solenoid #3 leaked														
1034								1106	2.28E-04	0.961	8.48E-04	0.953	3.58	222158	72290
1035								1107	1.58E-04	0.843	3.84E-03	0.993	17.90	224631	72290
1036								1108	2.59E-04	0.901	3.98E-03	0.999	18.38	231106	72290
1037								1109	9.15E-05	0.777	5.03E-03	0.999	23.85	233632	72290
1038								1110	1.84E-04	1.034	3.99E-03	0.999	18.56	3	72390
1039								1111	3.59E-05	0.412	5.29E-03	0.998	24.99	2428	72390
1040								1112	3.53E-03	0.987	9.42E-03	0.999	37.94	4638	72390
1041								1113	1.70E-04	0.544	8.03E-03	0.999	37.71	11258	72390
1042								1114	2.19E-05	0.350	5.31E-03	0.997	25.11	13722	72390
1043								1115	6.32E-05	1.069	4.78E-03	0.999	22.44	20148	72390
1044								1116	6.23E-06	0.803	5.39E-03	0.997	25.36	22614	72390
1045								1117	3.05E-05	0.818	4.88E-03	0.999	22.95	25041	72390
1046								1118	2.23E-05	0.268	4.58E-03	0.997	21.64	31510	72390
1047	7.72E-03	1.000	9.98E-03	1.000	32.86	221717	72190	1120	1.38E-04	0.907	4.70E-03	0.999	22.02	40428	72390
1048	7.30E-03	0.999	8.98E-03	1.000	28.81	224131	72190	1121	1.48E-04	1.027	4.37E-03	0.995	20.40	42908	72390
1049	6.24E-03	1.000	1.05E-02	1.000	38.04	230645	72190	1122	8.19E-05	0.792	5.08E-03	0.999	23.83	45361	72390
1050	6.49E-03	1.000	9.99E-03	1.000	35.00	232850	72190	1123	5.59E-03	1.000	1.03E-02	0.996	38.40	51808	72390
1051	6.04E-03	1.000	1.07E-02	1.000	38.26	235413	72190	1124	5.57E-03	1.000	8.48E-03	0.999	28.80	54224	72390
1052	5.65E-03	0.999	1.09E-02	0.999	40.80	1827	72290	1125	5.42E-03	1.000	8.36E-03	0.999	28.27	60841	72390
1053	5.33E-03	1.000	1.04E-02	1.000	38.98	4241	72290	1126	5.21E-03	1.000	8.74E-03	0.999	31.53	63057	72390
1054	5.65E-03	1.000	1.05E-02	1.000	38.74	10654	72290	1127	5.31E-03	1.000	7.28E-03	0.999	24.30	65517	72390
1055	5.95E-03	1.000	1.07E-02	0.999	38.56	13108	72290	1129	4.68E-03	0.999	8.72E-03	0.999	22.97	71835	72390
1056	5.84E-03	1.000	1.07E-02	0.999	38.57	15528	72290	1128							
1057	5.91E-03	1.000	1.03E-02	0.999	37.71	21941	72290	1130	7.08E-03	0.999	7.71E-03	0.999	27.34	81421	72390
1058	5.76E-03	1.000	1.03E-02	1.000	37.77	24356	72290	1131	8.81E-03	1.000	7.48E-03	0.999	23.64	83838	72390
1059	5.63E-03	1.000	1.04E-02	1.000	38.25	30813	72290	1132	8.18E-03	1.000	7.68E-03	0.999	26.49	90252	72390
1060	5.65E-03	1.000	1.03E-02	0.999	38.24	33230	72290	1133	7.60E-03	1.000	8.88E-03	0.999	34.93	82708	72390
1061	5.95E-03	1.000	1.03E-02	0.999	37.53	36648	72290	1134	8.17E-03	1.000	9.98E-03	1.000	44.51	96120	72390
1062	5.33E-03	1.000	8.74E-03	1.000	36.06	42108	72290	1135	6.32E-03	1.000	1.07E-02	0.999	48.06	101534	72390
1063	6.48E-03	1.000	9.87E-03	0.999	33.54	44823	72290	1136	8.72E-03	1.000	8.83E-03	0.999	36.87	103946	72390
1064	5.61E-03	1.000	8.13E-03	0.999	27.86	50649	72290	1137	6.37E-03	1.000	1.31E-02	0.999	63.19	110358	72390
1065	5.67E-03	1.000	8.09E-03	1.000	27.60	53414	72290	1138	6.54E-03	1.000	1.43E-02	1.000	70.34	112811	72390
1066	5.41E-03	1.000	7.91E-03	1.000	27.20	55634	72290	1139	8.79E-03	1.000	1.30E-02	1.000	61.48	115222	72390
1067	4.80E-03	0.997	7.34E-03	0.999	25.50	62301	72290	1140	6.77E-03	1.000	1.24E-02	0.999	57.93	121834	72390
1068	5.41E-03	1.000	7.54E-03	0.999	25.44	64727	72290	1141	6.80E-03	1.000	1.28E-02	1.000	58.88	124044	72390
1069	5.13E-03	1.000	7.57E-03	1.000	26.14	71154	72290	1142	6.88E-03	1.000	1.41E-02	0.999	68.30	130454	72390
1070	5.20E-03	1.000	7.49E-03	0.999	26.64	73820	72290	1143	8.99E-03	1.000	1.29E-02	1.000	59.07	132301	72390
1071								1144	8.82E-03	1.000	1.42E-02	0.999	68.81	136313	72390
1072								1145	6.81E-03	1.000	1.27E-02	0.999	60.15	141723	72390
1073	5.64E-03	1.000	8.20E-03	0.999	28.15	65026	72290	1146	6.71E-03	1.000	1.43E-02	1.000	69.81	144135	72390
1074	4.48E-03	0.994	7.25E-03	0.999	25.86	91447	72290	1147	6.32E-03	1.000	1.34E-02	1.000	65.50	150546	72390
1075	5.22E-03	0.999	6.99E-03	0.999	23.21	93808	72290	1148	5.71E-03	1.000	1.20E-02	1.000	64.19	152958	72390
1076	5.96E-03	1.000	6.97E-03	0.999	21.75	100311	72290	1149	6.98E-03	1.010	1.31E-02	0.999	61.91	155407	72390
1077	8.82E-03	1.000	9.10E-03	0.999	23.64	102738	72290	1150	7.08E-03	1.000	1.32E-02	1.000	62.46	161818	72390
1078	7.65E-03	1.000	7.65E-03	0.999	21.07	106158	72290	1151	6.99E-03	1.000	1.33E-02	0.999	62.74	164228	72390
1079	7.44E-03	1.000	7.48E-03	0.999	21.36	111620	72290	1152	6.50E-03	1.000	1.37E-02	1.000	59.43	170840	72390
1080	8.78E-03	1.000	7.93E-03	0.999	24.24	114026	72290	1153	6.00E-03	1.000	1.40E-02	0.999	60.76	173052	72390
1081	8.80E-03	1.000	7.92E-03	0.999	24.98	120454	72290	1154	6.80E-03	1.000	1.39E-02	0.999	61.15	175503	72390
1082	8.48E-03	1.000	7.89E-03	0.999	25.08	122904	72290	1155	6.22E-03	1.000	1.38E-02	0.999	61.32	181915	72390
1083	6.54E-03	1.000	8.02E-03	0.999	25.58	125324	72290	1156	6.30E-03	1.000	1.37E-02	1.000	62.34	184328	72390
1084	6.33E-03	1.000	7.93E-03	0.999	25.58	131738	72290	1157	6.33E-03	1.000	1.36E-02	1.000	63.57	190740	72390
1085	6.05E-03	1.000	8.23E-03	0.999	27.54	134150	72290	1158	6.70E-03	1.000	1.48E-02	1.000	67.85	193150	72390
1086	8.13E-03	1.000	8.33E-03	0.999	27.88	140802	72290	1159	6.07E-03	1.000	1.36E-02	0.999	62.15	195801	72390
1087	8.08E-03	1.000	8.18E-03	0.999	27.11	143013	72290	1160	6.19E-03	1.000	1.23E-02	0.999	54.36	202014	72390
1088	6.23E-03	1.000	8.48E-03	1.000	28.39	145424	72290	1161	8.02E-03	1.000	1.31E-02	0.999	59.20	204425	72390
1089	6.20E-03	1.000	9.30E-03	1.000	32.30	151834	72290	1162	8.01E-03						

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)

Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY															
1169	8.61E-03	1.000	1.29E-02	1.000	80.73	440	72490	1242	7.22E-03	0.999	8.84E-03	0.999	23.71	52512	72590															
1170	7.98E-03	1.000	1.35E-02	0.999	86.01	2901	72490	1243	7.18E-03	0.999	7.35E-03	0.999	26.85	54925	72590															
1171	8.33E-03	0.998	1.25E-02	0.999	83.97	5317	72490	1244	7.06E-03	0.999	8.29E-03	0.999	20.76	61368	72590															
1172	8.89E-03	1.000	1.26E-02	0.999	57.89	11729	72490	1245	8.88E-03	0.999	5.45E-03	0.999	16.22	63627	72590															
1173	8.40E-03	1.000	1.27E-02	0.999	59.83	14141	72490	1246	8.57E-03	0.997	5.71E-03	0.998	16.50	70253	72590															
1174	8.33E-03	1.000	1.29E-02	0.999	81.23	20558	72490	1247	8.81E-03	0.999	5.47E-03	0.992	16.94	72715	72590															
1175	7.98E-03	1.000	1.25E-02	1.000	59.58	23007	72490	1248																						
1176	8.80E-03	1.000	1.28E-02	0.999	58.57	25421	72490	1249	7.43E-03	0.998	7.12E-03	0.999	23.34	82128	72590															
1177	8.26E-03	1.000	1.17E-02	0.999	54.10	31839	72490	1250	8.98E-03	1.000	5.16E-03	0.998	12.31	84548	72590															
1178	8.27E-03	1.000	1.22E-02	0.999	57.43	34254	72490	1251	4.50E-03	0.997	5.27E-03	0.994	18.52	91004	72590															
1179	7.98E-03	1.000	1.16E-02	0.997	54.40	40711	72490	1252	5.95E-03	0.999	1.98E-02	0.801	98.42	93420	72590															
1180	7.78E-03	1.000	1.08E-02	0.998	49.31	43127	72490	1253	6.30E-03	0.998	6.11E-03	0.998	20.17	96834	72590															
1181	7.11E-03	1.000	1.08E-02	0.999	50.15	45548	72490	1254	5.77E-03	0.995	5.88E-03	1.000	20.09	102248	72590															
1182	7.13E-03	1.000	1.01E-02	0.999	46.78	52010	72490	1255	6.04E-03	0.998	6.38E-03	0.997	22.32	104702	72590															
1183	7.00E-03	1.000	1.25E-02	0.999	82.14	54426	72490	1256	5.90E-03	0.998	5.84E-03	1.000	19.80	111117	72590															
1184	8.87E-03	1.000	9.47E-03	0.998	43.19	60849	72490	1257	8.02E-03	1.000	5.82E-03	0.998	18.08	113631	72590															
1185	8.88E-03	1.000	1.11E-02	0.999	54.22	63309	72490	1258	8.02E-03	0.999	6.12E-03	0.998	20.86	115845	72590															
1186	7.00E-03	1.000	1.10E-02	0.999	52.67	65726	72490	1259	5.33E-03	0.998	4.81E-03	0.993	15.06	122359	72590															
1187	8.97E-03	1.000	1.01E-02	0.998	47.25	72148	72490	1260	6.08E-03	0.995	4.85E-03	0.994	12.50	124808	72590															
1188	Note 16. DO Probe coated with grease																													
1189								1261	5.90E-03	0.997	3.13E-03	0.992	4.31	131220	72590															
1190								1262	6.33E-03	0.997	< 87E-03	0.999	12.01	133834	72590															
1191								1263	5.30E-03	1.000	4.08E-03	0.995	10.84	140045	72590															
1192								1264	5.27E-03	0.998	4.84E-03	0.998	14.25	142458	72590															
1193								1265	6.10E-03	0.998	5.30E-03	1.000	18.08	144811	72590															
1194								1266	5.07E-03	0.998	4.23E-03	0.999	12.38	151325	72590															
1195								1267	4.52E-03	0.997	4.00E-03	1.000	12.38	153737	72590															
1196								1268	5.07E-03	0.999	2.69E-03	0.995	3.72	160152	72590															
1197								1269	5.80E-03	0.998	4.32E-03	0.998	11.85	162603	72590															
1198								1270	5.78E-03	0.999	4.42E-03	1.000	11.92	165015	72590															
1199								1271	5.87E-03	0.999	4.04E-03	0.998	9.50	171429	72590															
1200								1272	4.71E-03	0.999	3.58E-03	0.998	9.54	173841	72590															
1201								1273	Note 17. Sampler not functioning																					
1202	3.86E-03	0.998	9.14E-03	0.998	48.83	130916	72490	1275																						
1203	5.52E-03	0.999	8.22E-03	0.997	38.88	133330	72490	1276																						
1204	6.18E-03	1.000	8.15E-03	0.995	58.52	136745	72490	1277																						
1205	4.18E-03	0.998	7.74E-03	0.998	38.07	142203	72490	1278																						
1206	6.16E-03	0.998	7.45E-03	0.998	32.03	144618	72490	1279																						
1207	6.50E-03	0.999	7.91E-03	0.998	34.15	151031	72490	1280																						
1208	6.55E-03	1.000	7.21E-03	0.997	29.51	153447	72490	1281																						
1209	9.80E-04	0.995	2.41E-03	0.992	13.02	156924	72490	1282																						
1210	7.36E-03	0.999	7.16E-03	1.000	27.00	162339	72490	1283																						
1211	6.67E-03	0.999	8.03E-03	0.995	34.50	164753	72490	1284																						
1212	6.14E-03	0.999	8.05E-03	1.000	36.94	171209	72490	1285																						
1213	7.10E-03	0.999	6.48E-03	0.997	38.18	173621	72490	1286																						
1214	7.06E-03	1.000	7.82E-03	0.999	32.14	180035	72490	1287																						
1215	8.98E-03	0.999	8.19E-03	0.999	34.78	182449	72490	1288	5.52E-03	0.999	3.30E-03	0.995	4.83	230014	72590															
1216	7.18E-03	1.000	7.35E-03	0.997	28.77	184903	72490	1289	6.44E-03	0.994	4.75E-03	0.995	11.80	236428	72590															
1217	7.08E-03	0.999	8.31E-03	0.995	36.25	181324	72490	1290	6.37E-03	0.997	4.57E-03	0.999	10.85	1837	72600															
1218	5.20E-03	0.999	6.87E-03	0.995	27.33	193739	72490	1291	5.29E-03	0.998	4.43E-03	0.998	10.41	4300	72600															
1219	4.53E-03	0.999	7.09E-03	0.998	33.88	200153	72490	1292	5.43E-03	0.998	4.75E-03	0.998	11.82	10710	72600															
1220	6.89E-03	1.000	7.78E-03	1.000	32.31	202808	72490	1293	5.20E-03	0.999	4.20E-03	0.997	8.54	13121	72600															
1221	7.08E-03	1.000	7.12E-03	0.995	27.54	206422	72490	1294	5.25E-03	0.998	3.30E-03	0.998	9.14	15534	72600															
1222	7.30E-03	0.995	8.02E-03	0.995	18.72	211435	72490	1295	3.89E-03	0.998	3.33E-03	0.999	7.87	21947	72600															
1223								1296	4.72E-03	1.000	2.78E-03	0.999	3.92	24401	72600															
1224	9.93E-03	1.000	8.93E-03	0.998	29.98	220818	72490	1297	4.58E-03	0.999	4.58E-03	0.998	12.38	30819	72600															
1225	9.86E-03	1.000	9.44E-03	0.999	33.40	223230	72490	1298	4.78E-03	0.999	4.47E-03	0.998	11.40	33233	72600															
1226	8.89E-03	1.000	1.01E-02	0.998	38.44	225844	72490	1299	4.89E-03	1.000	4.31E-03	0.995	10.88	35644	72600															
1227	8.04E-03	1.000	1.00E-02	0.999	40.93	232068	72490	1300	4.92E-03	0.995	4.84E-03	1.000	12.06	42103	72600															
1228	8.76E-03	1.000	9.18E-03	0.998	34.04	234611	72490	1301	4.31E-03	0.998	2.14E-03	0.997	1.87	44620	72600															
1229	8.73E-03	0.999	8.88E-03	0.997	32.22	927	72590	13																						

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 28 to Sept 1, 1990)

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 28 to Sept 1, 1990)

Test No.	OUR 1 mg/L/sec Corr.	OUR 2 mg/L/sec Corr.	Coef. mg/g/hr	SpOUR mg/g/hr	Time HHMMSS	Date MDYY	Test No.	OUR 1 mg/L/sec Corr.	OUR 2 mg/L/sec Corr.	Coef. mg/g/hr	SpOUR mg/g/hr	Time HHMMSS	Date MDYY		
1315	5.37E-03	0.988	3.45E-03	0.993	5.88	102545	72890	1388	1.43E-02	1.000	2.03E-02	1.000	52.70	164202	72790
1316	5.97E-03	0.980	4.38E-03	0.987	8.98	105004	72890	1389	1.52E-02	1.000	2.07E-02	1.000	52.83	170815	72790
1317	5.00E-03	0.988	3.57E-03	0.998	7.08	111417	72890	1390	1.38E-02	1.000	2.05E-02	1.000	53.87	173030	72790
1318	5.05E-03	0.987	4.58E-03	0.990	11.58	113828	72890	1391	1.43E-02	0.999	1.99E-02	1.000	51.00	175444	72790
1319	4.85E-03	0.987	4.14E-03	0.984	10.28	120242	72890	1392	1.48E-02	1.000	2.08E-02	1.000	53.95	161857	72790
1320	4.49E-03	0.988	3.59E-03	0.988	8.08	122863	72890	1393	1.43E-02	1.000	2.00E-02	1.000	51.41	184312	72790
1321	4.85E-03	0.987	3.34E-03	0.988	8.67	125105	72890	1394	1.47E-02	1.000	2.04E-02	1.000	52.47	190725	72790
1322	4.55E-03	0.984	1.97E-03	0.984	8.67	131518	72890	1395	1.45E-02	1.000	1.89E-02	1.000	47.19	193139	72790
1323	5.28E-03	0.989	2.71E-03	0.988	2.69	133828	72890	1396	1.39E-02	1.000	1.97E-02	1.000	51.08	195553	72790
1324	4.52E-03	0.983	2.33E-03	0.988	2.35	140341	72890	1397	1.36E-02	1.000	1.93E-02	1.000	49.56	202008	72790
1325	4.10E-03	0.989	2.87E-03	0.987	5.58	142752	72890	1398	1.39E-02	1.000	1.86E-02	1.000	48.83	204423	72790
1326	2.90E-03	0.988	1.78E-03	0.989	2.61	145204	72890	1399	1.13E-02	1.000	1.78E-02	1.000	47.01	210837	72790
1327								1400	1.22E-02	0.989	1.79E-02	1.000	48.83	213251	72790
1328	6.42E-03	0.989	1.88E-03	0.988	-2.55	155012	72890	1401							
1329	5.53E-03	1.000	2.32E-03	0.989	0.38	161422	72890	1402	1.51E-02	1.000	2.10E-02	1.000	53.90	223514	72790
1330								1403	1.58E-02	1.000	2.11E-02	1.000	53.83	225027	72790
1331								1404	1.62E-02	1.002	1.73E-02	1.000	40.31	232338	72790
1332	1.45E-02	0.979	2.35E-02	1.000	63.65	172522	72890	1405	1.55E-02	1.000	1.89E-02	1.000	45.61	234750	72790
1333	9.96E-03	0.989	1.81E-02	1.000	52.23	174840	72890	1406	9.49E-02	1.020	1.68E-02	1.000	45.53	1205	72890
1334	8.27E-03	0.988	1.88E-02	1.000	58.17	181404	72890	1407	1.50E-02	1.000	1.88E-02	1.000	45.97	3617	72890
1335	1.14E-02	1.000	1.84E-02	1.000	42.67	183824	72890	1408	1.44E-02	1.000	1.93E-02	1.000	50.73	10030	72890
1336	1.10E-02	1.000	1.54E-02	1.000	39.43	190243	72890	1409	1.47E-02	1.000	1.55E-02	1.000	45.86	12444	72890
1337	1.13E-02	1.000	1.54E-02	1.000	36.09	192701	72890	1410	1.48E-02	1.000	1.55E-02	1.000	47.83	14658	72890
1338	1.04E-02	1.000	1.48E-02	1.000	38.36	195119	72890	1411	1.48E-02	1.000	1.51E-02	1.000	56.73	21307	72890
1339	1.10E-02	1.000	1.49E-02	1.000	37.65	201540	72890	1412	1.48E-02	1.000	1.50E-02	1.000	47.74	23721	72890
1340	1.03E-02	1.000	1.57E-02	1.000	41.47	204000	72890	1413	1.48E-02	1.000	1.51E-02	1.000	49.54	30137	72890
1341	9.97E-03	1.000	1.67E-02	1.000	45.02	210414	72890	1414	1.48E-02	1.000	1.74E-02	1.000	50.82	32618	72890
1342	6.93E-03	1.000	1.59E-02	1.000	44.22	212830	72890	1415	1.41E-02	1.000	1.78E-02	1.000	50.10	35033	72890
1343								1416	1.42E-02	1.000	1.87E-02	1.000	46.00	41449	72890
1344	1.18E-02	0.989	1.88E-02	1.000	50.87	222018	72890	1417	1.40E-02	1.000	1.98E-02	1.000	51.07	43808	72890
1345	1.40E-02	1.000	1.84E-02	1.000	50.38	224429	72890	1418	1.38E-02	1.000	1.88E-02	1.000	40.84	50321	72890
1346	1.26E-02	1.000	1.86E-02	1.000	49.73	230843	72890	1419	1.16E-02	1.000	1.87E-02	1.000	50.53	52740	72890
1347	1.34E-02	0.989	1.91E-02	1.000	49.31	233258	72890	1420	1.27E-02	1.000	1.58E-02	1.000	38.83	55158	72890
1348	1.26E-02	1.000	1.87E-02	1.000	47.06	236713	72890	1421	1.15E-02	1.000	1.41E-02	1.000	34.28	61617	72890
1349	1.28E-02	1.000	1.52E-02	1.000	50.08	2127	72790	1422	1.09E-02	1.000	1.83E-02	1.000	43.18	84035	72890
1350	1.29E-02	1.000	1.97E-02	1.000	48.80	4543	72790	1423	1.08E-02	1.000	1.38E-02	1.000	34.18	70455	72890
1351	1.27E-02	1.000	1.97E-02	1.000	52.44	10956	72790	1424	1.09E-02	1.000	1.31E-02	1.000	32.79	72915	72890
1352	1.18E-02	0.989	1.79E-02	1.000	48.44	13412	72790	1425	9.64E-03	1.000	1.85E-02	1.000	45.63	75333	72890
1353	1.24E-02	1.000	1.80E-02	1.000	47.10	15828	72790	1426							
1354	1.17E-02	1.000	1.77E-02	1.000	48.98	22244	72790	1427							
1355	1.14E-02	1.000	1.83E-02	1.000	49.85	24702	72790	1428	1.20E-02	0.989	1.27E-02	1.000	28.38	90621	72890
1356	1.18E-02	1.000	1.88E-02	1.000	49.87	31118	72790	1429	1.44E-02	1.000	1.19E-02	1.000	21.82	82639	72890
1357	9.80E-03	1.000	1.58E-02	1.000	42.88	33539	72790	1430	1.19E-02	1.000	1.24E-02	1.000	27.51	96367	72890
1358	1.05E-02	1.000	1.58E-02	1.000	40.94	40003	72790	1431	1.22E-02	0.999	1.25E-02	1.000	27.47	101813	72890
1359	9.40E-03	1.000	1.49E-02	1.000	40.06	42430	72790	1432	1.41E-02	1.000	1.31E-02	1.000	26.84	104226	72890
1360	9.55E-03	1.000	1.53E-02	1.000	41.43	44853	72790	1433	1.48E-02	1.000	1.32E-02	1.000	26.58	110639	72890
1361	8.84E-03	1.000	1.69E-02	1.000	48.19	51315	72790	1434	1.38E-02	0.989	1.34E-02	1.000	28.79	113052	72890
1362	8.80E-03	1.000	1.57E-02	1.000	43.83	53737	72790	1435	6.51E-03	0.989	1.30E-02	1.000	40.48	115604	72890
1363	9.17E-03	1.000	1.53E-02	1.000	41.78	82200	72790	1436	1.58E-02	1.000	1.48E-02	1.000	30.67	121913	72890
1364	9.02E-03	1.000	1.68E-02	1.000	48.89	82620	72790	1437	1.49E-02	1.000	1.45E-02	1.000	31.41	124321	72890
1365	7.85E-03	0.989	1.53E-02	1.000	43.98	66048	72790	1438	1.35E-02	0.989	1.45E-02	1.000	32.81	130730	72890
1366	8.12E-03	1.000	1.20E-02	1.000	30.19	71512	72790	1439	1.50E-02	1.000	1.44E-02	1.000	30.32	133130	72890
1367								1440	1.58E-02	1.000	1.56E-02	1.000	32.08	135544	72890
1368	1.73E-02	0.983	1.98E-02	1.000	46.31	80522	72790	1441	1.53E-02	1.000	1.50E-02	1.000	32.08	141961	72890
1369	1.40E-02	1.000	1.98E-02	1.000	50.34	82941	72790	1442	1.28E-02	0.989	1.50E-02	1.000	36.49	144358	72890
1370	1.36E-02	1.000	1.98E-02	1.000	50.82	86401	72790	1443	1.23E-02	0.989	1.42E-02	1.000	33.46	150805	72890
1371	1.41E-02	1.000	1.73E-02	1.000	41.83	91820	72790	1444	7.40E-03	0.989	1.24E-02	1.000	33.88	153212	72890
1372	1.41E-02	1.000	2.07E-02	1.000	54.44	94235	72790	1445	1.39E-02	0.989	1.36E-02	1.000	28.98	156818	72890
1373	1.37E-02	1.000	2.08E-02	1.000	54.41	100849	72790	1446	1.32E-02	1.000	1.35E-02	1.000	29.78	162025	72890
1374	1.31E-02	1.000	1.78E-02	1.000	48.29	103108	72790	1447	1.43E-02	1.000	1.38E-02	1.000	28.28	164432	72890
1375								1448	5.24E-03	0.974	1.51E-02	1.000	48.75	170843	72890
1376								1449	1.52E-02	1.000	1.48E-02	1.000	30.85	173419	72890
1377								1450	2.57E-03	0.974	1.78E-02	1.000	80.41	175832	72890
1378								1451	1.40E-02	0.988	1.48E-02	1.000	32.37	182242	

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDY
1461								1524							
1462	3.85E-03	0.999	7.88E-03	0.998	22.82	230415	72880	1535							
1463	1.15E-02	0.999	1.40E-02	1.000	33.82	232629	72880	1536							
1464	1.22E-02	0.999	1.41E-02	1.000	33.28	236242	72880	1537							
1465	1.18E-02	1.000	1.40E-02	1.000	33.28	1655	72880	1538							
1466	1.25E-02	0.999	1.40E-02	1.000	32.26	4109	72880	1539							
1467	1.10E-02	0.999	1.38E-02	1.000	33.74	10523	72880	1540							
1468	1.33E-02	1.000	1.40E-02	1.000	31.07	12938	72880	1541							
1469	1.21E-02	1.000	1.41E-02	1.000	33.33	15353	72880	1542							
1470	1.23E-02	0.999	1.37E-02	1.000	31.72	21809	72880	1543							
1471	1.32E-02	1.000	1.37E-02	1.000	30.13	24226	72880	1544	1.19E-02	1.000	9.05E-03	0.999	16.76	80125	73090
1472	1.19E-02	1.000	1.35E-02	1.000	31.47	30842	72880	1545	1.01E-02	1.000	8.53E-03	1.000	17.60	82547	73090
1473	1.19E-02	0.999	1.34E-02	1.000	31.20	33058	72880	1546	9.59E-03	1.000	1.23E-02	1.000	32.98	85006	73090
1474	1.14E-02	0.999	1.34E-02	0.998	31.72	36615	72880	1547	8.44E-03	1.000	1.34E-02	1.000	39.04	91424	73090
1475	1.18E-02	1.000	1.29E-02	1.000	29.73	41834	72880	1548	1.15E-02	0.999	1.45E-02	1.000	38.72	92841	73090
1476	1.12E-02	1.000	1.26E-02	1.000	29.41	44352	72880	1549	9.00E-03	0.999	1.30E-02	1.000	38.93	100300	73090
1477	1.09E-02	1.000	1.23E-02	1.000	28.70	50810	72880	1550	7.82E-03	0.999	1.37E-02	1.000	41.06	102714	73090
1478	1.03E-02	0.999	1.20E-02	1.000	28.43	53229	72880	1551	9.75E-03	1.000	1.41E-02	1.000	38.92	106126	73090
1479	1.00E-02	1.000	1.18E-02	1.000	28.00	55863	72880	1552	8.82E-03	1.000	1.39E-02	1.000	38.34	111538	73090
1480	9.83E-03	1.000	1.14E-02	1.000	27.59	62115	72880	1553	9.75E-03	1.000	1.45E-02	1.000	41.42	113950	73090
1481	9.36E-03	1.000	1.11E-02	1.000	26.82	64539	72880	1554	9.26E-03	0.999	1.29E-02	1.000	38.07	120407	73090
1482	9.02E-03	1.000	9.14E-03	1.000	19.90	71002	72880	1555	9.29E-03	1.000	1.33E-02	1.000	37.33	122619	73090
1483	8.79E-03	1.000	8.49E-03	1.000	17.92	73426	72880	1556	9.26E-03	1.000	1.44E-02	1.000	42.04	125229	73090
1484								1557	9.58E-03	1.000	1.45E-02	1.000	41.77	131841	73090
1485	1.22E-02	1.000	9.38E-03	1.000	16.28	82826	72880	1558	8.93E-03	1.000	1.33E-02	0.999	38.15	134063	73090
1486	1.07E-02	1.000	1.01E-04	0.995	-15.03	85254	72880	1559	8.51E-03	1.000	1.40E-02	1.000	41.34	140506	73090
1487	9.48E-05	0.995	1.43E-06	0.995	-0.06	91723	72880	1560	7.83E-03	1.000	1.38E-02	1.000	40.86	142917	73090
1488	5.12E-04	0.903	1.55E-04	0.907	-0.18	94150	72880	1561	8.02E-03	1.000	1.38E-02	1.000	40.86	145344	73090
1489	4.32E-03	0.999	9.19E-03	1.000	26.88	100817	72880	1562	7.88E-03	0.999	1.38E-02	1.000	41.81	151757	73090
1490	1.34E-02	0.999	9.78E-03	1.000	15.82	103036	72880	1563	7.67E-03	0.999	1.26E-02	1.000	37.11	154214	73090
1491	1.33E-02	1.000	9.64E-03	1.000	15.80	105455	72880	1564	8.19E-03	1.000	1.30E-02	1.000	37.98	160826	73090
1492	1.33E-02	1.000	9.99E-03	1.000	16.85	111914	72880	1565	7.36E-03	0.997	1.29E-02	0.999	38.09	163042	73090
1493	1.33E-02	1.000	1.08E-02	1.000	10.86	114329	72880	1566	1.07E-02	1.000	1.39E-02	1.000	37.57	165455	73090
1494	1.26E-02	1.000	1.08E-02	1.000	20.33	120746	72880	1567	1.07E-02	0.999	1.36E-02	1.000	37.56	171908	73090
1495	1.32E-02	1.000	1.11E-02	1.000	20.97	123157	72880	1568	1.05E-02	1.000	1.38E-02	1.000	37.38	174319	73090
1496	1.35E-02	0.999	1.14E-02	1.000	21.79	125600	72880	1569	1.02E-02	0.999	1.35E-02	1.000	38.73	180731	73090
1497	1.32E-02	1.000	1.13E-02	1.000	21.73	135019	72880	1570	1.00E-02	1.000	1.32E-02	1.000	38.12	183145	73090
1498	1.33E-02	1.000	1.15E-02	1.000	22.21	134431	72880	1571	9.92E-03	1.000	1.37E-02	1.000	38.01	186600	73090
1499	1.33E-02	1.000	1.65E-02	1.000	47.48	140842	72880	1572	1.01E-02	1.000	1.32E-02	1.000	36.97	182013	73090
1500	1.35E-02	1.000	1.25E-03	1.000	25.55	143251	72880	1573	9.41E-03	0.999	1.35E-02	1.000	37.94	184428	73090
1501	1.31E-02	1.000	1.22E-02	1.000	25.01	145700	72880	1574	9.43E-03	1.000	1.25E-02	1.000	34.03	20840	73090
1502	Note 18: RAS seed tank empty														
1503								1575	9.21E-03	1.000	1.25E-02	1.000	34.32	203256	73090
1504								1576	8.84E-03	0.999	1.27E-02	1.000	36.03	206709	73090
1505								1577							
1506								1578	9.22E-03	0.999	1.33E-02	1.000	57.57	215215	73090
1507								1579	1.04E-02	1.000	1.30E-02	1.000	53.07	221627	73090
1508								1580	9.72E-03	1.000	1.38E-02	0.999	59.36	224036	73090
1509								1581	8.68E-03	0.999	1.28E-02	1.000	60.78	230453	73090
1510								1582	8.52E-03	0.992	1.32E-02	1.000	58.79	222804	73090
1511								1583	9.61E-03	1.000	1.28E-02	1.000	53.80	236315	73090
1512								1584	8.05E-03	0.999	1.24E-02	1.000	58.04	173190	
1513								1585	8.27E-03	0.999	1.33E-02	1.000	60.10	41.31	73190
1514								1586	8.40E-03	0.999	1.36E-02	1.000	60.61	105656	73190
1515								1587	8.34E-03	1.000	1.27E-02	1.000	61.07	130099	73190
1516								1588	5.89E-03	0.999	1.33E-02	0.999	66.91	15423	73190
1517								1589	8.10E-03	0.999	1.36E-02	1.000	63.18	21835	73190
1518								1590	7.82E-02	0.999	1.27E-02	1.000	57.00	24250	73190
1519								1591	7.23E-03	0.999	1.27E-02	1.000	58.78	30703	73190
1520								1592	7.54E-03	0.999	1.23E-02	1.000	56.42	33122	73190
1521								1593	7.38E-03	0.999	1.19E-02	1.000	53.72	36641	73190
1522								1594	6.83E-03	1.000	1.27E-02	1.000	58.56	42002	73190
1523								1595	7.26E-03	1.000	1.29E-02	1.000	58.95	44428	73190
1524	Note 19: Sampler tubing blocked														
1525								1596	3.19E-03	0.995	1.24E-02	1.000	67.06	53306	73190
1526								1597	6.31E-03	0.999	1.18E-02	1.000	55.98	56730	73190
1527								1598	4.82E-03	0.999	9.88E-03	0.999	46.85	62153	73190
1528								1599	5.87E-03	0.999	9.88E-03	0.999	44.04	64815	73190
1529								1600	4.58E-03	0.999	1.23E-02	0.999	62.88	71043	73190
1530								1601	3.67E-03	0.993	9.71E-03	1.000	49.46	81228	73190
1531								1602	3.89E-03	0.997	1.03E-02	0.999	52.92	83848	73190
1532								1603	4.28E-03	0.999	9.88E-03	1.000	49.98	80108	73190
1533								1604	5.50E-03	1.000	9.88E-03	0.999	40.67	82536	73190

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 26 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 26 to Sept. 1, 1990)

Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY								
1607	3.46E-03	0.908	8.27E-03	1.000	41.33	040567	73190	1680	3.26E-03	1.000	4.82E-03	1.000	18.62	153948	80190								
1608	5.13E-03	1.000	9.27E-03	0.999	43.31	101411	73190	1681	3.43E-04	0.747	2.68E-03	1.000	13.38	160445	80190								
1609								1682	8.03E-04	0.979	3.17E-03	0.999	15.08	162912	80190								
1610								1683	2.85E-04	0.863	2.70E-03	0.998	13.89	165412	80190								
1611	4.88E-03	1.000	9.87E-03	0.998	48.38	114111	73190	1684	6.60E-03	1.000	7.67E-03	1.000	26.62	171826	80190								
1612	4.85E-03	1.000	1.03E-02	0.998	50.21	120624	73190	1685	6.82E-03	1.000	6.99E-03	1.000	22.54	174240	80190								
1613	5.26E-03	1.000	9.13E-03	1.000	42.14	122834	73190	1686	6.84E-03	1.000	8.18E-03	1.000	26.79	180658	80190								
1614	4.79E-03	1.000	8.97E-03	0.999	42.36	125347	73190	1687	6.71E-03	1.000	8.20E-03	1.000	29.21	193110	80190								
1615	5.05E-03	1.000	9.84E-03	0.999	47.51	131759	73190	1688	Note 21: Solenoid #3 blocked														
1616	5.31E-03	1.000	9.15E-03	0.998	42.19	134211	73190	1689															
1617	5.16E-03	1.000	1.04E-02	1.000	50.29	140624	73190	1690															
1618	4.83E-03	0.999	9.84E-03	0.999	47.44	143037	73190	1691															
1619	4.91E-03	0.993	9.10E-03	0.999	42.81	145449	73190	1692															
1620	8.57E-03	1.000	9.88E-03	0.999	38.70	151850	73190	1693															
1621	8.88E-03	1.000	1.09E-02	1.000	44.34	154310	73190	1694	2.70E-04	0.948	4.57E-03	0.995	23.61	212035	80190								
1622	8.85E-03	1.000	1.13E-02	1.000	46.09	160721	73190	1695															
1623	9.51E-03	1.000	1.12E-02	1.000	44.59	163130	73190	1696	8.84E-03	0.998	7.61E-03	1.000	25.38	222120	80190								
1624	9.05E-03	1.000	1.07E-02	0.999	42.37	165538	73190	1697	6.54E-03	1.000	7.37E-03	1.000	23.77	224533	80190								
1625	8.72E-03	1.000	1.04E-02	1.000	41.78	171949	73190	1698	6.24E-03	0.999	7.87E-03	0.999	26.88	230847	80190								
1626	8.16E-03	1.000	1.05E-02	1.000	43.24	174369	73190	1699	6.37E-03	1.000	7.88E-03	1.000	26.55	233359	80190								
1627	6.85E-03	0.999	1.02E-02	0.999	44.59	180808	73190	1700	6.14E-03	1.000	7.18E-03	1.000	23.64	235813	80190								
1628	7.80E-03	1.000	1.05E-02	1.000	44.50	183217	73190	1701	6.10E-03	1.000	6.93E-03	1.000	22.44	2227	80290								
1629	8.33E-03	1.000	1.03E-02	0.999	41.77	185627	73190	1702	5.74E-03	1.000	7.18E-03	1.000	24.33	4845	80290								
1630	6.04E-03	0.984	1.04E-02	0.998	48.10	192036	73190	1703	5.80E-03	1.000	7.38E-03	1.000	25.72	11058	80290								
1631	8.08E-03	1.000	9.83E-03	1.000	39.57	194442	73190	1704	5.64E-03	1.000	7.08E-03	1.000	24.02	13614	80290								
1632	8.00E-03	1.000	8.80E-03	1.000	33.58	200651	73190	1705	5.33E-03	1.000	6.97E-03	0.999	24.17	15830	80290								
1633	6.30E-03	0.998	8.55E-03	1.000	36.20	203300	73190	1706	5.29E-03	0.998	6.51E-03	0.999	21.97	22346	80290								
1634	7.72E-03	1.000	9.61E-03	1.000	36.14	205707	73190	1707	6.22E-03	1.000	6.78E-03	0.999	21.34	24802	80290								
1635	6.36E-03	1.000	9.85E-03	0.999	44.41	212117	73190	1708	4.97E-03	0.998	7.10E-03	1.000	25.58	31217	80290								
1636								1709	4.87E-03	1.000	6.05E-03	0.998	20.53	33634	80290								
1637	7.83E-03	1.000	1.09E-02	1.000	46.40	221508	73190	1710	4.76E-03	0.998	6.01E-03	1.000	20.54	40049	80290								
1638	5.98E-03	1.000	1.02E-02	1.000	47.13	223613	73190	1711	4.84E-03	0.997	6.94E-03	1.000	25.05	42502	80290								
1639	7.64E-03	0.999	7.92E-03	0.999	29.15	230318	73190	1712	4.52E-03	1.000	6.88E-03	1.000	24.37	44917	80290								
1640	6.43E-03	0.998	1.04E-02	1.000	46.66	232724	73190	1713	Note 22: Solenoid #3 blocked														
1641	6.94E-03	0.998	8.29E-03	1.000	33.08	236131	73190	1714															
1642	7.12E-03	1.000	9.85E-03	1.000	42.60	1539	80190	1715															
1643	7.16E-03	0.998	1.00E-02	1.000	43.04	3844	80190	1716															
1644	8.07E-03	1.000	8.23E-03	1.000	30.03	10349	80190	1717															
1645	7.01E-03	0.998	8.63E-03	0.998	34.98	12756	80190	1718															
1646	6.12E-03	0.999	9.42E-03	1.000	41.85	15203	80190	1719	4.63E-03	1.000	6.26E-03	1.000	24.77	81921	80290								
1647	6.78E-03	0.999	9.09E-03	1.000	38.24	21610	80190	1720	3.98E-03	1.000	5.58E-03	1.000	22.44	84339	80290								
1648	5.40E-03	0.999	9.39E-03	0.999	43.40	24017	80190	1721	4.09E-03	1.000	5.69E-03	0.998	22.82	90758	80290								
1649	2.04E-03	0.974	1.02E-02	1.000	58.41	30428	80190	1722	3.80E-03	1.000	5.48E-03	1.000	22.25	93214	80290								
1650	4.86E-03	0.999	8.99E-03	0.998	42.17	32836	80190	1723	3.68E-03	0.997	5.76E-03	0.999	24.15	95629	80290								
1651	6.50E-03	1.000	9.24E-03	1.000	39.80	36242	80190	1724	3.72E-03	1.000	6.35E-03	0.999	27.36	102043	80290								
1652	4.88E-03	1.000	9.10E-03	0.999	42.92	41649	80190	1725	3.53E-03	0.998	6.08E-03	1.000	26.15	104458	80290								
1653	4.32E-03	0.992	8.92E-03	0.999	43.12	44057	80190	1726	3.75E-03	1.000	5.94E-03	1.000	24.98	110911	80290								
1654	3.88E-04	0.858	8.79E-03	1.000	51.87	50508	80190	1727	3.73E-03	1.000	5.88E-03	1.000	24.70	113323	80290								
1655	2.64E-03	0.983	9.19E-03	1.000	48.31	52912	80190	1728	3.71E-03	1.000	5.78E-03	1.000	24.16	115736	80290								
1656	8.94E-04	0.991	8.06E-03	0.999	46.23	56323	80190	1729	3.36E-03	1.000	5.82E-03	0.999	25.10	122148	80290								
1657	7.48E-04	0.990	7.34E-03	1.000	42.23	61734	80190	1730	3.48E-03	1.000	5.79E-03	0.999	24.88	124800	80290								
1658	1.57E-03	0.994	8.88E-03	0.999	49.41	84143	80190	1731	3.88E-03	0.999	6.36E-03	0.999	27.13	131011	80290								
1659	9.94E-04	0.994	8.00E-03	1.000	46.03	70552	80190	1732	3.26E-03	0.999	4.87E-03	0.999	20.81	133424	80290								
1660	5.26E-04	0.995	8.18E-03	1.000	47.81	73001	80190	1733	3.82E-03	1.000	3.45E-03	0.999	22.50	135837	80290								
1661	6.88E-04	0.998	8.92E-03	0.999	51.88	75408	80190	1734	1.33E-03	0.999	5.57E-03	0.992	28.31	142327	80290								
1662	8.85E-04	0.991	7.88E-03	0.999	44.02	81811	80190	1735	4.10E-03	0.999	4.40E-03	1.000	15.58	144740	80290		</						

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 28 to Sept. 1, 1990)

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 28 to Sept. 1, 1990)

Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY
1753								1826	8.57E-03	1.000	1.00E-02	0.998	33.08	34837	80490
1754	4.49E-03	1.000	6.46E-03	0.999	23.30	221332	80290	1827	8.27E-03	1.000	1.11E-02	0.998	38.98	41010	80490
1755	4.85E-03	1.000	6.25E-03	0.999	21.57	223745	80290	1828	8.30E-03	1.000	1.07E-02	0.994	38.71	43443	80490
1756	4.88E-03	1.000	6.40E-03	0.999	22.23	230157	80290	1829	1.03E-02	0.998	2.99E-03	0.307	-21.55	45918	80490
1757	5.04E-03	1.000	4.88E-03	0.999	14.22	232609	80290	1830	8.47E-03	1.000	9.70E-03	1.000	31.58	52354	80490
1758	4.82E-03	1.000	4.84E-03	0.997	13.56	235020	80290	1831	7.82E-03	1.000	8.54E-03	0.998	27.08	54829	80490
1759	4.94E-03	0.999	8.11E-03	0.999	20.66	1433	80390	1832	7.55E-03	1.000	8.18E-03	0.998	25.79	61305	80490
1760	5.15E-03	0.999	4.25E-03	0.995	10.97	3648	80390	1833	1.40E-02	0.998	8.82E-03	0.994	6.21	63742	80490
1761	5.14E-03	1.000	4.88E-03	0.997	14.02	10300	80390	1834	1.22E-02	0.999	8.48E-03	1.000	17.88	70220	80490
1762	5.11E-03	1.000	6.24E-03	0.993	20.97	12714	80390	1835	8.41E-03	1.000	6.73E-03	0.998	20.81	72657	80490
1763	4.95E-03	1.000	5.06E-03	0.997	15.38	15129	80390	1836	1.03E-02	0.999	7.34E-03	1.000	18.02	75137	80490
1764	4.42E-03	0.998	5.16E-03	0.999	16.94	21544	80390	1837	5.74E-03	1.000	5.86E-03	0.999	17.76	61816	80490
1765	4.96E-03	0.997	5.17E-03	0.999	15.92	24000	80390	1838							
1766	5.05E-03	0.999	4.60E-03	0.997	12.93	30418	80390	1839	6.94E-03	1.000	5.73E-03	0.998	18.63	91034	80490
1767	4.47E-03	1.000	4.89E-03	0.994	15.50	32835	80390	1840	8.90E-03	0.998	5.16E-03	0.998	13.31	93508	80490
1768	4.52E-03	1.000	3.94E-03	0.997	10.86	35254	80390	1841	7.24E-03	1.000	4.78E-03	0.998	10.50	95937	80490
1769	4.35E-03	1.000	5.20E-03	0.999	17.32	41715	80390	1842	7.33E-03	1.000	7.52E-03	1.000	25.77	102408	80490
1770	4.21E-03	1.000	5.54E-03	0.999	19.29	44138	80390	1843	7.75E-03	1.000	1.64E-02	0.990	74.57	104841	80490
1771	4.31E-03	1.000	5.48E-03	0.997	18.76	50558	80390	1844	7.91E-03	1.000	1.12E-02	0.982	45.06	111314	80490
1772	4.03E-03	1.000	5.24E-03	0.999	18.14	53021	80390	1845	9.63E-03	1.000	1.38E-02	0.998	58.75	113744	80490
1773	3.80E-03	1.000	4.52E-03	0.999	19.53	55440	80390	1846	9.40E-03	1.000	1.57E-02	1.000	86.97	120213	80490
1774	3.79E-03	1.000	5.81E-03	0.999	21.46	61800	80390	1847	7.89E-03	1.000	8.40E-03	0.998	18.69	122642	80490
1775	3.44E-03	0.998	5.61E-03	0.998	21.17	64320	80390	1848	7.23E-03	1.000	6.67E-03	1.000	21.25	125110	80490
1776	3.59E-03	1.000	6.00E-03	0.999	22.81	70743	80390	1849	7.08E-03	0.998	8.20E-03	0.995	19.01	131537	80490
1777								1850	8.87E-03	0.998	8.25E-03	0.998	19.70	134006	80490
1778	4.08E-03	1.000	4.85E-03	1.000	14.87	50929	80390	1851	1.05E-02	1.000	6.94E-03	0.999	15.46	140433	80490
1779	4.61E-03	0.999	5.28E-03	1.000	17.10	83356	80390	1852	9.45E-03	0.997	7.55E-03	1.000	21.21	142900	80490
1780	4.31E-03	0.998	4.57E-03	1.000	14.22	85823	80390	1853	1.10E-02	1.000	5.98E-03	0.998	8.89	145328	80490
1781	4.41E-03	0.999	4.58E-03	1.000	14.07	92248	80390	1854	8.02E-03	1.000	8.88E-03	0.998	24.06	151757	80490
1782	4.66E-03	1.000	6.56E-03	0.999	23.47	94712	80390	1855	4.42E-03	0.982	8.43E-03	0.998	26.23	154226	80490
1783	4.39E-03	1.000	5.57E-03	0.999	19.06	101138	80390	1856	1.21E-02	1.000	2.20E-02	0.999	98.43	160655	80490
1784	4.13E-03	0.998	6.01E-03	1.000	21.76	103603	80390	1857	1.19E-02	0.998	2.17E-02	0.999	94.95	163124	80490
1785	4.32E-03	0.999	4.89E-03	1.000	15.83	110029	80390	1858	1.15E-02	0.998	2.22E-02	0.999	98.81	166554	80490
1786	4.30E-03	0.998	6.35E-03	0.998	23.15	112453	80390	1859	1.15E-02	0.998	2.19E-02	0.998	98.92	172028	80490
1787	4.25E-03	0.999	3.45E-03	0.999	8.72	114221	80390	1860	1.16E-02	0.999	2.17E-02	0.999	98.11	174560	80490
1788	4.08E-03	1.000	3.29E-03	0.998	8.25	121347	80390	1861	1.12E-02	0.999	2.17E-02	0.999	98.59	180830	80490
1789	3.74E-03	0.999	4.78E-03	0.999	18.27	120814	80390	1862	1.12E-02	0.999	2.19E-02	0.998	97.31	183403	80490
1790	4.38E-03	0.998	4.74E-03	0.999	14.98	122445	80390	1863	1.12E-02	0.999	2.18E-02	0.999	97.76	186538	80490
1791	4.34E-03	1.000	3.71E-03	1.000	9.87	132710	80390	1864	1.08E-02	0.999	2.18E-02	0.999	98.18	182213	80490
1792	4.40E-03	0.998	3.09E-03	0.999	8.64	136138	80390	1865	1.10E-02	0.999	2.17E-02	0.999	97.46	184747	80490
1793	4.15E-03	0.999	2.84E-03	0.998	4.88	141806	80390	1866	5.25E-03	0.998	2.06E-02	0.999	103.58	201226	80490
1794	4.41E-03	1.000	2.36E-03	1.000	3.13	144038	80390	1867	1.85E-03	0.998	2.30E-02	0.999	125.14	203703	80490
1795	3.97E-03	1.000	3.20E-03	0.998	8.07	150507	80390	1868	1.82E-03	0.997	2.36E-02	0.998	128.42	210142	80490
1796	4.04E-03	0.999	2.16E-03	0.998	2.72	152607	80390	1869	1.85E-03	0.997	8.01E-03	0.995	29.84	212624	80490
1797	1.71E-02	0.728	1.27E-02	1.000	29.40	155403	80390	1870	1.23E-03	0.995	8.57E-03	0.998	34.22	215101	80490
1798	7.94E-03	1.000	1.27E-02	0.999	47.44	161822	80390	1871							
1799	7.73E-03	1.000	1.26E-02	0.999	47.34	164248	80390	1872	8.04E-03	1.000	5.81E-03	0.998	14.53	224516	80490
1800	8.11E-03	0.998	1.10E-02	1.000	36.01	170708	80390	1873	7.41E-03	0.998	5.88E-03	0.997	16.35	230932	80490
1801	8.10E-03	0.999	1.09E-02	0.998	36.22	173133	80390	1874	6.92E-03	0.998	6.41E-03	0.995	20.36	233352	80490
1802	8.18E-03	1.000	1.14E-02	1.000	40.44	175552	80390	1875	7.27E-03	0.998	6.45E-03	0.998	19.88	236813	80490
1803	8.19E-03	1.000	1.17E-02	1.000	42.23	182012	80390	1876	7.26E-03	1.000	6.11E-03	0.998	17.98	2234	80560
1804	8.19E-03	1.000	1.16E-02	0.999	41.44	184430	80390	1877	6.80E-03	0.998	6.88E-03	0.998	22.72	4701	80560
1805	8.63E-03	1.000	1.17E-02	1.000	41.18	190852	80390	1878	7.31E-03	0.998	8.23E-03	0.997	18.52	111244	80560
1806	8.32E-03	1.000	1.47E-02	0.999	56.83	193315	80390	1879	6.87E-03	0.998	6.82E-03	0.998	21.70	13550	80560
1807	8.31E-03	1.000	1.25E-02	1.000	45.97	195738	80390	1880	7.85E-03	1.000	8.36E-03	0.995	29.81	20015	80560
1808	8.39E-03	1.000	1.24E-02	1.000	45.32	202158	80390	1881	7.36E-03	1.000	6.74E-03	1.000	21.30	22442	80560
1809	8.18E-03	0.999	1.20E-02	1.000	41.80	204821	80390	1882	6.99E-03	0.998	6.54E-03	0.998	21.22	24810	80560
1810	8.28E-03	1.000	1.21E-02	1.000	44.07	211044	80390	1883	7.84E-03	0.998	8.05E-03	1.000	27.63	31339	80560
1811	8.26E-03	1.000	1.17E-02	1.000	42.04	213604	80390	1884	1.47E-03	0.991	7.42E-03	0.998	38.28	33809	80560
1812	8.02E-03	1.000	1.19E-02	0.999	43.27	215027	80390	1885	6.70E-03	0.997	7.02E-03	1.000	35.63	40238	80560
1813								1886	4.03E-03	0.993	7.97E-03	0.994	35.83	42706	80560
1814	9.03E-03	1.000	1.12E-02	0.999	37.94	225222	80390	1887	3.98E-03	0.998	6.28E-03	1.000	28.33	46138	80560
1815	8.30E-03	1.000													

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Test No.	OUR 1 mg/L sec	Coef. Corr.	OUR 2 mg/L sec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L sec	Coef. Corr.	OUR 2 mg/L sec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY
1899	2.48E-03	0.987	5.17E-03	1.000	18.82	003800	80580	1972	7.10E-03	1.000	1.00E-02	0.988	34.12	152238	80690
1900	1.53E-03	0.989	5.57E-03	1.000	22.34	100358	80580	1973	7.64E-03	1.000	7.18E-03	0.985	19.59	154738	80690
1901	1.18E-03	0.988	5.85E-03	1.000	23.32	102825	80580	1974	7.48E-03	1.000	7.88E-03	0.988	22.29	161241	80690
1902	4.37E-03	0.988	4.97E-03	1.000	14.51	105248	80580	1975	7.94E-03	1.000	7.78E-03	0.988	21.79	163748	80690
1903	1.10E-03	1.000	5.91E-03	0.988	24.63	111710	80580	1976	7.02E-03	1.000	7.81E-03	0.988	24.15	170303	80690
1904	1.13E-03	0.988	5.51E-03	0.988	22.77	114128	80580	1977	6.39E-03	0.987	7.64E-03	0.988	24.00	172827	80690
1905	9.78E-04	1.000	5.13E-03	0.988	21.32	120548	80580	1978	6.79E-03	1.000	7.77E-03	0.988	23.84	175347	80690
1906	1.10E-03	0.989	5.29E-03	1.000	21.83	123004	80580	1979	7.08E-03	1.000	7.04E-03	0.988	19.91	161908	80690
1907	3.32E-04	0.980	4.58E-03	1.000	20.07	125421	80580	1980	5.40E-03	0.982	7.38E-03	0.988	24.77	184429	80690
1908	1.47E-03	0.988	6.18E-03	0.983	25.08	131837	80580	1981	6.88E-03	0.988	7.48E-03	0.988	22.31	190958	80690
1909	1.32E-03	0.984	5.53E-03	0.988	22.53	134256	80580	1982	6.84E-03	0.981	7.27E-03	0.988	18.07	193458	80690
1910	1.98E-03	0.977	6.20E-03	1.000	24.37	140708	80580	1983	7.64E-03	0.988	7.85E-03	0.988	21.77	200010	80690
1911	1.02E-03	0.971	7.77E-03	0.988	33.13	145127	80580	1984	4.14E-04	0.931	7.86E-03	1.000	36.88	202604	80690
1912	1.38E-03	0.988	6.11E-03	1.000	25.02	146543	80580	1985	8.10E-03	1.000	7.50E-03	0.988	20.20	205312	80690
1913	1.58E-03	0.988	5.83E-03	0.988	23.38	152001	80580	1986							
1914	4.14E-03	0.988	8.03E-03	0.988	26.88	154414	80580	1987	1.02E-02	1.000	8.55E-03	0.988	21.25	214949	80690
1915	1.84E-03	0.988	7.07E-03	1.000	28.86	160835	80580	1988	8.31E-03	1.000	1.04E-02	0.988	33.73	221402	80690
1916	3.18E-03	1.000	6.12E-03	0.988	21.85	163250	80580	1989	8.41E-03	1.000	8.48E-03	0.988	24.14	223818	80690
1917	8.25E-04	0.988	6.34E-03	1.000	27.42	165712	80580	1990	8.21E-03	1.000	7.85E-03	0.988	21.63	230236	80690
1918	1.19E-03	0.989	7.29E-03	1.000	30.64	172138	80580	1991	8.58E-03	1.000	1.10E-02	1.000	36.11	232855	80690
1919	1.62E-03	0.988	7.00E-03	0.988	31.29	174558	80580	1992	8.82E-03	1.000	7.32E-03	0.988	17.94	236118	80690
1920	1.50E-03	0.988	8.08E-03	1.000	33.53	181036	80580	1993	8.91E-03	1.000	7.24E-03	0.987	17.41	1549	80790
1921	9.07E-04	0.983	6.53E-03	1.000	27.78	180518	80580	1994	8.90E-03	1.000	7.98E-03	0.988	20.85	4028	80790
1922	1.74E-03	0.988	8.98E-03	1.000	28.32	185955	80580	1995	4.70E-04	0.988	1.24E-02	0.988	57.94	10521	80790
1923	1.48E-03	0.988	7.37E-03	0.988	30.48	192436	80580	1996	9.18E-03	1.000	7.45E-03	0.988	17.93	12958	80790
1924	1.81E-03	1.000	6.97E-03	1.000	26.12	194915	80580	1997	9.42E-03	1.000	8.21E-03	0.988	21.06	15436	80790
1925	1.41E-03	0.988	6.87E-03	1.000	28.36	201354	80580	1998	9.08E-03	1.000	7.58E-03	0.987	18.72	21914	80790
1926	1.54E-03	0.988	7.55E-03	1.000	31.10	203035	80580	1999	8.80E-03	1.000	1.08E-02	0.988	34.75	24353	80790
1927	1.23E-03	0.983	9.64E-03	0.988	41.19	210311	80580	2000	8.83E-03	1.000	1.00E-02	0.988	31.02	30836	80790
1928								2001	8.92E-03	1.000	7.47E-03	0.988	18.49	33316	80790
1929	6.78E-03	0.988	7.29E-03	0.988	20.62	221701	80580	2002	8.43E-03	1.000	8.41E-03	1.000	14.38	36811	80790
1930	6.37E-03	0.989	6.34E-03	0.988	17.08	224129	80580	2003	8.23E-03	1.000	7.30E-03	0.988	18.99	42310	80790
1931	6.91E-03	0.989	7.07E-03	0.988	19.38	230544	80580	2004	8.72E-03	1.000	6.48E-03	1.000	14.09	44811	80790
1932	7.43E-03	1.000	7.33E-03	0.988	19.80	233001	80580	2005	7.51E-03	1.000	7.27E-03	0.988	20.18	51328	80790
1933	7.78E-03	1.000	7.02E-03	0.988	17.59	236421	80580	2006	7.53E-03	1.000	5.88E-03	0.988	13.46	53842	80790
1934	7.15E-03	0.989	6.97E-03	0.988	18.51	1843	80580	2007	7.21E-03	1.000	5.84E-03	0.988	14.01	60367	80790
1935	7.21E-03	0.988	6.72E-03	0.987	17.27	4306	80580	2008	8.65E-03	1.000	5.62E-03	0.988	13.46	62916	80790
1936	7.31E-03	1.000	7.23E-03	0.987	19.39	10731	80580	2009	8.65E-03	1.000	4.86E-03	0.988	10.36	65438	80790
1937	7.39E-03	1.000	7.42E-03	1.000	20.07	13158	80580	2010	8.54E-03	1.000	6.48E-03	1.000	18.31	72000	80790
1938	7.76E-03	1.000	7.75E-03	0.988	20.92	15620	80580	2011							
1939	7.62E-03	1.000	7.17E-03	0.988	18.54	22045	80580	2012	8.56E-03	0.988	4.98E-03	0.988	11.21	81945	80790
1940	7.42E-03	1.000	7.38E-03	0.988	19.88	24511	80580	2013	8.21E-03	0.988	4.94E-03	0.988	12.28	64418	80790
1941	7.44E-03	0.988	7.27E-03	0.988	19.31	30039	80580	2014	6.59E-03	1.000	4.74E-03	0.988	10.53	90802	80790
1942	6.07E-03	0.988	7.03E-03	1.000	20.72	33412	80580	2015	8.31E-03	1.000	5.31E-03	0.988	13.82	93343	30790
1943	7.05E-03	0.988	7.38E-03	1.000	20.45	36840	80580	2016	8.39E-03	0.988	7.85E-03	0.988	25.46	65825	80790
1944	6.88E-03	1.000	7.11E-03	0.988	19.95	42313	80580	2017	8.88E-03	0.988	1.12E-02	0.988	42.25	102307	80790
1945	6.91E-03	1.000	6.51E-03	0.988	18.85	44744	80580	2018	7.02E-03	0.988	6.18E-03	1.000	16.84	104751	80790
1946	Note 24	No test due to low Raw influent flow						2019	8.88E-03	0.988	7.52E-03	0.988	23.82	111237	80790
1947								2020	7.22E-03	1.000	7.25E-03	1.000	21.84	113727	80790
1948								2021	7.70E-03	0.988	7.81E-03	1.000	22.89	120214	80790
1949								2022	7.71E-03	1.000	8.08E-03	0.984	14.88	122706	80790
1950								2023	7.07E-03	1.000	9.03E-03	0.988	31.00	125203	80790
1951								2024	6.92E-03	1.000	5.79E-03	0.985	15.12	131668	80790
1952								2025	7.68E-03	1.000	3.97E-03	0.985	4.52	134154	80790
1953								2026	8.42E-03	1.000	4.22E-03	0.987	8.25	140702	80790
1954								2027	7.27E-03	1.000	8.85E-03	0.981	19.70	143210	80790
1955								2028	9.85E-03	0.988	5.19E-03	0.988	6.02	146719	80790
1956	7.80E-03	1.000	5.41E-03	0.988	10.87	84144	80580	2029	7.80E-03	0.987	4.22E-03	0.988	5.32	152307	80790
1957	3.20E-03	0.979	4.05E-03	0.988	15.83	80701	80580	2030	9.33E-03	0.988	4.12E-03	0.985	1.84	154852	80790
1958	8.34E-03	1.000	5.81E-03	0.988	11.73	93528	80580	2031	9.26E-03	1.000	2.87E-03	0.987	-4.14	161438	80790
1959	7.05E-03	1.000	5.24E-03	0.988	10.35	95588	80580	2032	1.00E-02	1.000	1.25E-02	1.000	40.21	170815	80790
1960	7.62E-03	1.000	5.38E-03	0.988	11.04	104247	80580	2033	8.83E-03	0.987	1.18E-02	1.000	38.17	173331	80790
1961	7.54E-03	1.000	5.40E-03	0.988	11.29	104850	80580	2034	5.37E-03	1.000	1.05E-02	0.988	38.32	175748	80790
1962	6.84E-03	1.000	5.17E-03	0.988	11.52	111342	80580	2035	8.85E-03	1.000	1.17E-02	1.000	37.36	182200	80790
1963	7.66E-03	1.000	5.47E-03	0.988	11.41	1									

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY
2045	7.69E-03	0.998	1.17E-02	1.000	41.07	223103	80790	2118	8.61E-03	1.000	1.07E-02	0.999	36.23	42754	80980
2046	8.77E-03	1.000	1.15E-02	1.000	38.04	225803	80790	2119	7.01E-03	0.999	1.09E-02	0.999	40.70	45253	80990
2047	8.61E-03	1.000	1.11E-02	1.000	38.28	232221	80790	2120	6.70E-03	0.999	9.74E-03	0.999	36.32	51749	80990
2048								2121	7.23E-03	0.999	1.24E-02	0.999	47.81	54248	80990
2049	9.04E-03	0.999	1.34E-02	1.000	48.58	1738	80890	2122	8.08E-03	1.000	1.33E-02	1.000	50.51	60747	80990
2050	9.51E-03	1.000	1.23E-02	1.000	40.39	2132	80890	2123	5.77E-03	0.999	1.17E-02	1.000	46.79	63248	80990
2051	8.85E-03	1.000	1.32E-02	0.999	48.07	10908	80890	2124	4.78E-03	0.997	8.11E-03	0.999	31.03	85750	80990
2052	8.67E-03	1.000	1.17E-02	1.000	39.11	13027	80890	2125	2.78E-03	0.994	7.63E-03	0.999	32.48	72248	80990
2053	8.53E-03	1.000	1.11E-02	1.000	36.85	15453	80890	2126							
2054	1.30E-04	0.740	1.12E-02	0.999	52.93	22003	80890	2127	6.73E-03	1.000	8.25E-03	0.999	23.77	82838	80990
2055	Note 25: Solenoid #3 blocked														
2056								2128	3.91E-03	0.999	7.89E-03	0.999	31.61	85258	80990
2057								2129	4.29E-03	0.997	1.02E-02	1.000	42.20	91707	80990
2058								2130	3.73E-03	0.993	1.05E-02	0.999	44.81	94126	80990
2059								2131	8.00E-03	1.007	9.49E-03	0.999	31.44	100543	80990
2060								2132	8.70E-04	0.998	8.81E-03	0.999	41.31	102959	80990
2061								2133	5.25E-03	0.999	8.76E-03	0.999	33.32	105418	80990
2062								2134	5.01E-03	0.999	1.03E-02	0.999	41.54	111805	80990
2063								2135	4.91E-03	0.997	8.84E-03	0.999	33.38	114257	80990
2064								2136	6.70E-03	1.000	8.53E-03	0.999	34.24	120722	80990
2065								2137	8.06E-03	1.000	8.12E-03	0.999	24.49	123141	80990
2066								2138	7.78E-03	1.000	8.55E-03	0.999	27.19	125401	80990
2067								2139	7.07E-03	1.000	8.08E-03	0.999	18.25	131962	80990
2068								2140	7.23E-04	0.999	7.82E-04	0.991	2.48	134361	80990
2069								2141	1.50E-04	0.927	3.13E-04	0.987	1.25	140736	80990
2070								2142	6.75E-03	1.000	5.90E-03	0.999	18.01	143153	80990
2071								2143	5.91E-04	0.999	1.03E-02	0.999	50.44	145619	80990
2072	7.01E-05	0.779	6.85E-03	0.999	32.32	91215	80890	2144	2.46E-04	0.824	4.18E-03	0.992	20.33	152012	80990
2073	9.15E-03	1.000	1.35E-02	0.999	48.80	93658	80890	2145	5.91E-05	0.998	8.86E-04	0.948	4.31	154406	80990
2074	1.15E-02	1.000	1.24E-02	0.999	37.16	100135	80890	2146	5.08E-04	0.998	3.20E-04	0.993	0.43	160804	80990
2075	9.36E-03	1.000	1.27E-02	1.000	42.47	102812	80890	2147	3.18E-04	0.997	9.69E-04	0.992	3.81	163202	80990
2076	8.80E-03	1.000	1.04E-02	0.999	33.00	105042	80890	2148	1.12E-04	0.938	1.01E-03	0.994	4.81	165800	80990
2077	8.30E-01	1.000	1.14E-02	0.999	38.10	111518	80890	2149	7.80E-06	0.935	2.21E-04	0.956	0.95	171966	80990
2078	8.11E-03	0.998	1.24E-02	0.999	49.88	120644	80890	2150	6.62E-04	0.992	8.38E-04	0.953	2.27	174362	80990
2079	8.48E-03	1.000	1.10E-02	0.999	37.91	123302	80890	2151	2.84E-05	1.147	5.36E-04	0.998	2.62	180748	80990
2080	8.33E-03	0.999	1.13E-02	1.000	43.00	125725	80890	2152	1.70E-04	0.918	1.23E-04	0.794	0.27	183144	80990
2081	5.48E-04	0.885	1.10E-02	1.000	53.87	132156	80890	2153	2.36E-04	0.973	7.93E-05	0.848	-0.07	186541	80990
2082	8.72E-03	1.000	1.21E-02	1.000	42.82	134823	80890	2154	3.03E-04	0.992	5.47E-04	0.985	2.13	191937	80990
2083	9.21E-03	1.000	1.20E-02	0.999	41.87	141049	80890	2155	3.49E-04	0.980	1.18E-03	0.983	5.21	194336	80990
2084	8.38E-03	1.000	1.19E-02	1.000	42.56	143517	80890	2156	1.70E-04	0.872	7.11E-04	0.985	3.22	200734	80990
2085	8.01E-03	1.000	1.27E-02	0.999	47.28	145844	80890	2157	4.93E-04	0.980	9.28E-04	1.002	3.66	203131	80990
2086	9.18E-03	1.000	1.22E-02	1.000	42.56	152413	80890	2158	3.11E-04	1.004	5.21E-04	0.784	1.98	206530	80990
2087	9.83E-03	1.000	1.17E-02	1.000	36.93	154841	80890	2159	Note 27: DO Probe coated with grease						
2088	8.71E-03	1.000	1.48E-02	0.999	55.78	161306	80890	2160	4.46E-03	0.993	1.22E-02	0.999	52.25	220849	80990
2089	7.91E-03	0.997	1.01E-02	0.997	34.86	163740	80890	2161	3.77E-03	0.988	1.05E-02	0.999	44.93	223111	80990
2090	9.03E-03	1.000	1.14E-02	0.999	30.10	170211	80890	2162	5.51E-03	0.998	1.09E-02	0.999	45.37	225534	80990
2091	9.63E-03	0.999	1.23E-02	1.000	42.42	172545	80890	2163	4.45E-03	0.992	1.09E-02	0.999	45.87	231959	80990
2092	8.88E-03	1.000	1.18E-02	1.000	41.38	175120	80890	2164	5.73E-03	1.000	1.05E-02	0.999	41.23	234423	80990
2093	1.17E-03	0.971	1.10E-02	0.982	52.48	182022	80890	2165	8.58E-03	1.000	1.08E-02	0.998	40.67	847	81090
2094	Note 28: SpOUR Apparatus down for maintenance														
2095								2166	8.47E-03	1.000	1.12E-02	0.999	43.05	3318	81090
2096								2167	8.24E-03	0.999	1.02E-02	0.999	38.41	5746	81090
2097								2168	7.08E-03	1.000	1.07E-02	1.000	39.14	12220	81090
2098								2169	1.20E-02	0.998	1.03E-02	0.999	27.61	14660	81090
2100								2170	8.88E-03	1.000	1.06E-02	0.999	38.58	21121	81090
2101								2171	8.82E-03	1.000	1.01E-02	0.999	38.89	235651	81090
2102								2172	8.54E-03	1.000	9.98E-03	0.999	32.58	30036	81090
2103								2173	7.00E-03	1.000	1.02E-02	0.999	38.99	32607	81090
2104	1.03E-02	1.000	1.32E-02	1.000	45.42	224144	80890	2174	8.15E-03	0.999	1.05E-02	0.999	40.19	34866	81090
2105	1.08E-02	1.000	1.52E-02	1.000	54.33	230813	80890	2175	5.42E-03	0.994	8.58E-03	0.999	37.08	41434	81090
2106	9.23E-03	1.000	1.38E-02	0.999	49.82	233044	80890	2176	8.30E-03	0.998	8.46E-03	0.999	28.80	43808	81090
2107	8.50E-03	1.000	1.34E-02	0.999	49.80	235520	80890	2177	8.38E-03	0.999	1.00E-02	0.994	37.44	50347	81090
2108	8.84E-03	1.000	1.47E-02	0.999	56.53	2007	80890	2178	8.94E-03	1.000	8.15E-03	0.999	28.88	62823	81090
2109	8.80E-03	1.000	1.32E-02	0.999	48.81	4453	80890	2179	5.90E-03	0.999	7.75E-03	0.999	28.90	56320	81090
2110	8.23E-03	1.000	1.42E-02	1.000	54.06	10443	80890	2180	5.92E-03	0.998	8.86E-03	0.997	32.92	61815	81090
2111	8.97E-03	1.000	1.19E-02	1.000	41.80	13419	80890	2181	8.10E-03	1.000	7.76E-03	0.997	28.58	64310	81090
2112	9.37E-03	1.000	1.29E-02	1.000	45.82	15859	80890	2182	5.95E-03	0.999	7.50E-03	0.999	25.63	70830	81090
2113	9.12E-03	1.000	1.34E-02	0.999	48.54	22338	80890	2183	4.84E-03	0.997	6.29E-03	0.999	21.58	73347	81090
2114	8.56E-03	1.000	1.51E-02	1.000	58.34	24818	80890	2184							

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 28 to Sept 1, 1990)

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 28 to Sept 1, 1990)

Test No.	OUR 1 mg/Lsec	Coeff. Corr.	OUR 2 mg/m <sup>3</sup> sec	Coeff. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coeff. Corr.	OUR 2 mg/Lsec	Coeff. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY						
2191	6.20E-03	0.999	1.70E-02	0.999	66.53	105115	81090	2264	8.40E-03	1.000	8.98E-03	0.999	18.07	181113	81190						
2192	9.17E-03	1.000	1.45E-02	1.000	54.37	111529	81090	2265	9.88E-03	1.000	9.58E-03	0.999	18.10	183521	81190						
2193	1.22E-02	0.997	1.27E-02	1.000	39.38	113943	81090	2266	9.50E-03	1.000	8.81E-03	0.999	18.11	185801	81190						
2194	9.66E-03	1.000	1.08E-02	0.999	64.88	120368	81090	2267	9.61E-03	1.000	8.71E-03	0.997	18.16	172339	81190						
2195	9.72E-03	1.000	1.29E-02	0.999	45.19	122810	81090	2268	9.00E-03	1.000	8.00E-03	0.999	18.29	174753	81190						
2196	9.72E-03	1.000	1.37E-02	0.999	59.90	125225	81090	2269	9.46E-03	1.000	8.47E-03	0.999	18.28	181205	81190						
2197	9.50E-03	1.000	1.78E-02	0.999	69.94	131308	81090	2270	9.33E-03	1.000	8.74E-03	0.999	18.30	183610	81190						
2198	1.08E-02	1.000	1.82E-02	0.999	59.98	134048	81090	2271	9.58E-03	1.000	9.71E-03	0.999	18.90	190018	81190						
2199	1.01E-02	1.000	1.27E-02	0.997	43.15	140458	81090	2272	8.45E-03	1.000	8.54E-03	0.997	18.80	192425	81190						
2200	1.02E-02	1.000	1.10E-02	0.997	34.42	142909	81090	2273	9.68E-03	1.000	9.16E-03	0.999	17.02	194833	81190						
2201	8.03E-03	0.998	1.71E-02	0.999	67.86	145323	81090	2274	9.84E-03	1.000	8.82E-03	0.997	18.26	201238	81190						
2202	9.82E-03	1.000	1.12E-02	0.998	36.25	151734	81090	2275	9.46E-03	0.999	8.20E-03	0.999	17.41	203700	81190						
2203	1.03E-02	1.000	1.12E-02	0.997	35.39	154144	81090	2276	9.46E-03	1.000	8.43E-03	0.999	18.18	210106	81190						
2204	1.00E-02	1.000	1.48E-02	0.999	52.93	180567	81090	2277	9.43E-03	1.000	9.45E-03	0.997	18.25	212613	81190						
2205	9.97E-03	1.000	1.75E-02	1.000	67.49	183010	81090	2278	8.29E-03	1.000	9.44E-03	0.999	18.41	223228	81190						
2206	1.00E-02	1.000	1.31E-02	0.999	45.80	184242	81090	2279	9.21E-03	0.999	8.39E-03	0.993	18.32	230035	81190						
2207	1.26E-02	0.997	1.24E-02	1.000	38.80	171838	81090	2280	8.40E-03	0.999	8.02E-03	0.999	14.98	232447	81190						
2208	9.37E-03	1.000	1.78E-02	0.999	68.06	174152	81090	2281	9.74E-03	0.999	7.29E-03	0.999	14.13	234901	81190						
2209	9.80E-03	1.000	1.83E-02	0.999	61.79	180707	81090	2282	8.31E-03	0.999	7.58E-03	0.993	13.72	1317	81290						
2210	9.70E-03	1.000	1.46E-02	0.999	53.82	183122	81090	2283	8.41E-03	0.999	7.88E-03	0.994	14.52	3731	81290						
2211	1.63E-02	0.999	1.63E-02	0.999	48.79	185538	81090	2284	8.87E-03	1.000	8.00E-03	0.995	14.32	10144	81290						
2212	1.00E-02	1.000	1.48E-02	0.999	52.78	191951	81090	2285	7.93E-03	1.000	7.43E-03	0.994	13.67	12602	81290						
2213	9.03E-03	0.997	1.43E-02	0.999	53.29	194415	81090	2286	8.91E-03	0.999	7.24E-03	0.999	11.63	21831	81290						
2214	9.56E-03	1.000	1.05E-02	0.999	33.23	200827	81090	2287	8.59E-03	1.000	7.71E-03	0.994	13.73	24349	81290						
2215	9.83E-03	1.000	1.06E-02	0.999	33.31	203241	81090	2288	8.47E-03	1.000	7.09E-03	0.999	11.91	39507	81290						
2216	9.98E-03	1.000	9.80E-03	0.999	29.00	205863	81090	2289	8.82E-03	1.000	7.72E-03	0.999	13.47	33214	81290						
2217	8.73E-03	1.000	1.44E-02	0.999	54.70	212120	81090	2290	8.44E-03	0.999	7.93E-03	0.999	14.63	24437	81290						
2218								2291	Note 26: No test due to low Raw influent flow												
2219								2292													
2220	1.02E-02	1.000	1.15E-02	0.999	33.41	221716	81090	2293													
2221	8.32E-03	1.000	1.23E-02	0.999	40.43	224134	81090	2294													
2222	7.18E-03	0.993	1.53E-02	0.999	56.81	230650	81090	2295													
2223	1.62E-02	0.998	1.47E-02	0.999	38.89	233008	81090	2296													
2224	9.28E-03	1.000	1.48E-02	0.999	49.73	235425	81090	2297													
2225	7.50E-03	0.999	9.78E-03	0.999	30.30	1841	81190	2298													
2226	7.18E-03	0.999	1.10E-02	0.999	36.64	4257	81190	2299													
2227	6.73E-03	1.000	1.79E-02	1.000	42.29	10714	81190	2300													
2228	9.77E-03	1.000	1.37E-02	0.999	57.69	13130	81190	2301													
2229	1.02E-02	1.000	1.48E-02	0.999	48.18	156448	81190	2302	8.46E-03	1.000	8.37E-03	0.997	10.33	91827	81290						
2230	5.00E-03	0.974	1.06E-02	0.997	36.62	22006	81190	2303	8.50E-03	0.999	5.77E-03	0.999	10.98	94063	81290						
2231	9.88E-03	1.000	1.04E-02	1.000	28.98	24423	81190	2304	7.07E-03	1.000	5.84E-03	0.997	10.42	100617	81290						
2232	9.48E-03	1.000	9.19E-03	0.997	24.30	30841	81190	2305	8.88E-03	1.000	4.76E-03	0.997	8.94	104813	81290						
2233	9.08E-03	2.006	8.22E-03	0.995	20.65	33305	81190	2306	7.01E-03	1.000	8.37E-03	0.999	12.35	110647	81290						
2234	9.58E-03	1.000	1.54E-02	0.999	51.97	36724	81190	2307	7.06E-03	1.000	8.64E-03	0.999	13.18	114340	81290						
2235	9.64E-03	1.000	8.42E-03	0.999	20.54	42144	81190	2308													
2236	9.72E-03	1.000	8.12E-03	0.999	19.03	44608	81190	2309													
2237	6.38E-03	1.000	7.47E-03	0.997	18.51	51031	81190	2310													
2238	8.85E-03	1.000	7.70E-03	0.997	18.70	53454	81190	2311													
2239	6.50E-03	1.000	1.40E-02	0.999	45.86	56919	81190	2312													
2240	8.64E-03	0.999	1.37E-02	0.999	46.01	62347	81190	2313	7.33E-03	0.999	7.80E-03	0.997	18.17	142004	81290						
2241	9.07E-03	1.000	7.68E-03	0.999	18.23	64808	81190	2314	7.94E-03	0.999	1.79E-02	0.999	50.54	144415	81290						
2242	8.95E-03	1.000	7.42E-03	0.997	7.29	71231	81190	2315	8.81E-03	1.000	7.98E-03	0.999	14.65	150827	81290						
2243	8.64E-03	1.000	7.38E-03	0.997	17.84	73700	81190	2316	7.79E-03	1.000	7.74E-03	0.999	16.02	153240	81290						
2244								2317	8.07E-03	0.999	7.49E-03	0.999	14.74	155852	81290						
2245	7.34E-03	1.000	6.76E-03	0.999	12.28	83033	81190	2318	7.72E-03	1.000	8.13E-03	0.999	17.45	162105	81290						
2246	6.61E-03	1.000	7.21E-03	0.997	14.67	86501	81190	2319	7.89E-03	1.000	8.82E-03	0.999	18.92	164519	81290						
2247	6.41E-03	0.993	7.03E-03	0.997	14.36	91928	81190	2320	5.38E-03	1.000	1.11E-02	0.999	30.98	170834	81290						
2248	7.22E-03	1.000	7.23E-03	0.999	13.98	94362	81190	2321	6.88E-03	0.997	1.00E-02	1.000	25.58	173348	81290						
2249	9.23E-03	1.000	8.24E-03	0.997	14.64	100806	81190	2322	8.24E-03	0.999	9.39E-03	1.000	21.08	175803	81290						
2250	9.21E-03	1.000	7.65E-03	0.999	13.39	103228	81190	2323	8.07E-03	1.000	1.01E-02	0.999	23.68	162218	81290						
2251	8.80E-03	1.000	9.21E-03	0.999	14.95	105644	81190	2324	7.89E-03	1.000	8.03E-03	0.999	18.87	164833	81290						
2252	9.12E-03	1.000	8.07E-03	0.997	14.20	112057	81190	2325	7.88E-03	1.000	8.47E-03	0.999	18.71	161106	81290						
2253	8.57E-03	1.000	8.25E-03	0.997	15.48	114611	81190	2326	8.01E-03	1.000	8.27E-03	1.000	21.02	160522	81290						
2254	7.88E-03	0.998	8.08E-03	0.997	15.78	120628	81190	2327	7.84E-03	1.000	8.16E-03	0.999	17.38	166650	81290						
2255	4.49E-03	0.991	1.35E-02	0.997	37.84	123340	81190	2328	Note 29: DO Probe coated with grease												
2256	7.18E-03	1.000	8.52E-03	0.999	18.18	125751	81190	2329													

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

Test No.	OUR 1 mg/L/sec	Coeff. Corr.	OUR 2 mg/L/sec	Coeff. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L/sec	Coeff. Corr.	OUR 2 mg/L/sec	Coeff. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY
2337	8.12E-03	1.000	9.42E-03	0.999	21.36	234322	8129C	2410	7.68E-03	1.000	1.09E-02	0.999	28.62	50613	81490
2338	8.00E-03	1.000	9.10E-03	0.999	16.94	735	81360	2411	7.15E-03	1.000	1.03E-02	0.999	26.94	52027	81490
2339	7.56E-03	1.000	7.81E-03	0.997	16.56	3148	81360	2412	7.20E-03	1.000	1.08E-02	0.999	27.06	55341	81490
2340	7.84E-03	1.000	8.34E-03	0.997	18.01	9801	81360	2413	7.09E-03	1.000	1.04E-02	0.999	27.39	61757	81490
2341	7.31E-03	0.999	1.25E-02	0.998	33.22	12016	81360	2414	7.20E-03	1.000	9.58E-03	0.999	24.13	64214	81490
2342	7.80E-03	1.000	1.35E-02	0.998	38.37	14431	81360	2415	8.34E-03	1.000	1.01E-02	0.999	27.30	70630	81490
2343	7.77E-03	1.000	1.03E-02	0.998	25.04	20847	81360	2416	8.28E-03	1.000	8.43E-03	1.000	21.29	73048	81490
2344	7.80E-03	1.000	9.40E-03	0.999	21.73	23503	81360	2417	8.06E-03	1.000	8.38E-03	0.999	21.38	75503	81490
2345	7.63E-03	0.999	8.10E-03	0.999	17.49	25718	81360	2418							
2346	7.78E-03	1.000	1.01E-02	0.999	24.21	32135	81360	2419							
2347	7.81E-03	1.000	9.48E-03	0.999	22.01	34652	81360	2420							
2348	7.77E-03	1.000	7.08E-03	0.998	13.06	41010	81360	2421							
2349	7.88E-03	1.000	7.36E-03	0.997	14.58	43427	81360	2422							
2350	7.70E-03	1.000	7.18E-03	0.998	14.18	45845	81360	2423							
2351	Note 30 RAS seed tank empty														
2352								2424							
2353								2425	5.88E-03	1.000	8.87E-03	1.000	23.72	105418	81490
2354								2426	8.11E-03	1.000	9.41E-03	1.000	20.14	111828	81490
2355								2427	8.61E-03	1.000	1.27E-02	0.998	37.82	114239	81490
2356								2428	8.54E-03	0.999	9.24E-03	0.999	24.88	120655	81490
2357								2429	7.13E-03	1.000	1.15E-02	0.998	32.31	123106	81490
2358								2430	8.81E-03	1.000	1.25E-02	0.999	34.49	125517	81490
2359								2431	6.81E-03	1.000	1.12E-02	0.998	31.91	131928	81490
2360								2432	8.44E-03	1.000	1.11E-02	0.998	31.97	134337	81490
2361								2433	8.84E-03	1.000	1.07E-02	0.998	26.83	140746	81490
2362								2434	8.14E-03	1.000	1.13E-02	0.999	33.27	143155	81490
2363								2435	8.50E-03	1.000	8.91E-03	1.000	27.40	145803	81490
2364								2436	8.61E-03	1.000	8.17E-03	0.999	20.71	152012	81490
2365								2437	6.90E-03	1.000	9.87E-03	1.000	26.66	154422	81490
2366								2438	7.10E-03	1.000	8.58E-03	1.000	13.97	160833	81490
2367	7.59E-03	1.000	1.16E-02	0.999	30.78	110918	81360	2439	8.73E-03	1.000	8.47E-03	0.999	21.67	163244	81490
2368	5.57E-03	1.000	1.08E-02	0.999	30.02	113331	81360	2440	8.85E-03	1.000	9.10E-03	0.999	23.87	165655	81490
2369	5.19E-03	0.999	1.04E-02	0.997	30.03	115812	81360	2441	7.01E-03	1.000	9.04E-03	0.999	23.59	172106	81490
2370	8.52E-03	1.000	1.38E-02	0.997	36.12	124269	81360	2442	6.70E-03	1.000	5.77E-03	0.999	11.57	174520	81490
2371	6.62E-03	0.999	1.38E-02	1.000	40.15	131040	81360	2443							
2372	6.87E-03	1.000	1.37E-02	1.000	39.42	133454	81360	2444							
2373	7.23E-03	0.999	1.33E-02	1.000	37.59	135905	81360	2445							
2374	7.24E-03	0.999	1.40E-02	0.999	38.84	142317	81360	2446							
2375	7.83E-03	1.000	1.31E-02	1.000	35.80	147429	81360	2447							
2376	7.38E-03	1.000	1.36E-02	0.999	39.09	151140	81360	2448	6.16E-03	1.000	9.86E-03	0.998	28.06	204334	81490
2377	7.50E-03	1.000	1.31E-02	0.998	36.34	153549	81360	2449							
2378	7.31E-03	1.000	1.31E-02	0.999	38.77	155859	81360	2450							
2379	7.29E-03	1.000	1.30E-02	0.999	36.19	162408	81360	2451							
2380	7.30E-03	0.999	1.26E-02	1.000	34.75	164818	81360	2452	7.72E-03	1.000	2.08E-02	0.992	63.29	224624	81490
2381	7.04E-03	0.998	1.16E-02	0.999	31.61	171229	81360	2453	1.08E-02	0.975	2.08E-02	0.995	62.24	231038	81490
2382	6.99E-03	1.000	1.14E-02	1.000	30.92	173639	81360	2454	9.02E-03	0.979	1.97E-02	0.996	60.29	233451	81490
2383	7.27E-03	1.000	1.16E-02	1.000	31.29	180048	81360	2455	8.87E-03	0.998	2.18E-02	0.997	68.90	235905	81490
2384	7.00E-03	0.999	1.14E-02	1.000	31.00	182458	81360	2456	8.85E-03	0.999	1.98E-02	1.000	61.44	2320	81500
2385	7.45E-03	0.999	1.12E-02	1.000	29.83	184808	81360	2457	9.26E-03	1.000	2.09E-02	1.000	64.31	4735	81500
2386	7.04E-03	1.000	1.08E-02	0.999	27.85	191320	81360	2458	8.73E-03	0.978	1.98E-02	1.000	61.61	11151	81500
2387	6.78E-03	0.999	1.15E-02	1.000	31.51	193731	81360	2459	8.88E-03	1.000	2.13E-02	1.000	66.92	13607	81500
2388	6.68E-03	0.999	9.75E-03	1.000	25.50	200142	81360	2460	9.53E-03	0.999	2.05E-02	1.000	62.54	20023	81500
2389	6.90E-03	0.999	8.70E-03	0.999	21.81	202564	81360	2461	9.03E-03	1.000	2.22E-02	1.000	69.83	22440	81500
2390	7.17E-03	0.999	8.78E-03	0.999	14.02	205005	81360	2462	8.84E-03	0.998	1.85E-02	1.000	59.71	24868	81500
2391	6.84E-03	0.999	8.16E-03	0.998	12.34	211415	81360	2463	8.84E-03	0.998	2.11E-02	1.000	65.92	31318	81500
2392	5.89E-03	0.999	7.50E-03	0.997	17.36	213825	81360	2464	8.80E-03	1.000	2.24E-02	0.987	70.76	33738	81500
2393								2465	9.36E-03	1.000	1.98E-02	1.000	60.52	40202	81500
2394								2466	8.48E-03	0.998	1.81E-02	1.000	55.21	42826	81500
2395								2467	8.48E-03	1.000	1.98E-02	1.000	61.49	45050	81500
2396								2468	8.85E-03	1.000	1.83E-02	1.000	56.44	51514	81500
2397								2469	8.38E-03	0.971	1.90E-02	1.000	61.87	53999	81500
2398								2470	9.36E-03	1.000	1.94E-02	1.000	60.87	60405	81500
2399								2471	8.21E-03	1.000	1.93E-02	0.998	60.02	62831	81500
2400								2472	8.18E-03	1.000	1.87E-02	1.000	57.96	65258	81500
2401								2473	8.20E-03	1.000	1.97E-02	1.000	61.81	71726	81500
2402								2474	8.17E-03	0.999	1.77E-02	1.000	53.52	74154	81500
2403								2475							
2404								2476	8.25E-03	0.999	1.41E-02	0.999	37.13	84102	81500
2405								2477	8.12E-03	0.997	1.31E-02	0.997	34.10	90529	81500
2406								2478	8.15E-03	0.998	8.24E-03	0.998	21.12	93000	81500
2407								2479	8.28E-03	0.994	1.06E-02	0.999	25.88	95414	81500
2408								2480	8.20E-03	0.999	1.25E-02	0.999	31.49	101832	81500
2409								2481	8.14E-03	0.999	1.73E-02	1.000	47.23	104257	81500
								2482	8.02E-03	1.000	1.45E-02	1.000	36.25	110700	81500

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY
2483	8.92E-03	0.939	1.89E-02	1.000	45.47	113119	81590	2558	9.95E-03	1.000	1.94E-02	1.000	48.95	173800	81690
2484	8.87E-03	0.999	1.75E-02	1.000	47.43	115533	81590	2557	1.01E-02	1.000	2.10E-02	1.000	54.61	180218	81690
2485	8.45E-03	1.000	1.79E-02	0.999	48.72	121945	81590	2558	1.01E-02	1.000	2.37E-02	1.000	63.12	182642	81690
2486	8.58E-03	1.000	2.33E-02	0.999	63.99	124358	81590	2559	1.02E-02	1.000	1.98E-02	0.929	50.03	186104	81690
2487	8.89E-03	1.000	2.63E-02	1.000	72.95	130608	81590	2560	1.01E-02	0.999	2.20E-02	1.000	57.90	191528	81690
2488	9.08E-03	0.997	2.68E-02	1.000	73.78	133221	81590	2561	1.04E-02	1.000	1.88E-02	1.000	40.48	193840	81690
2489	9.04E-03	1.000	2.19E-02	0.997	58.63	136532	81590	2562	1.05E-02	0.998	1.81E-02	1.000	38.29	200410	81690
2490	8.89E-03	1.000	2.78E-02	1.000	77.91	142044	81590	2563	9.84E-03	1.000	2.56E-02	1.000	89.73	202633	81690
2491	9.11E-03	0.999	2.51E-02	1.000	68.95	144459	81590	2564	1.06E-02	0.999	2.26E-02	1.000	58.71	206256	81690
2492	8.80E-03	1.000	2.07E-02	0.998	55.46	150011	81590	2565	1.04E-02	1.000	1.57E-02	1.000	37.24	211718	81690
2493	8.87E-03	1.000	2.68E-02	1.000	81.22	153325	81590	2566							
2494	9.31E-03	0.993	2.49E-02	0.999	60.16	155735	81590	2567	9.40E-03	1.000	2.37E-02	1.000	81.76	221934	81690
2495	9.03E-03	1.000	2.82E-02	1.000	78.90	162149	81590	2568	9.33E-03	1.000	1.90E-02	0.999	47.43	224404	81690
2496	9.12E-03	1.000	2.98E-02	1.000	84.09	164601	81590	2569	9.08E-03	0.998	2.52E-02	1.000	66.95	23065	81690
2497	9.57E-03	0.998	2.92E-02	1.000	81.43	171015	81590	2570	9.82E-03	1.000	2.70E-02	1.000	71.80	233307	81690
2498	9.44E-03	1.000	2.78E-02	1.000	77.27	173400	81590	2571	1.01E-02	1.000	2.58E-02	1.000	87.40	236738	81690
2499	9.24E-03	0.998	2.69E-02	1.000	74.83	175848	81590	2572	1.00E-02	1.000	1.58E-02	1.000	36.93	2213	81790
2500	9.11E-03	1.000	2.48E-02	1.000	87.98	182302	81590	2573	9.84E-03	1.000	1.49E-02	1.000	33.91	4447	81790
2501	9.07E-03	0.999	2.69E-02	1.000	74.89	184719	81590	2574	9.84E-03	1.000	1.68E-02	0.985	40.05	11120	81790
2502	8.82E-03	0.998	2.72E-02	1.000	78.18	191134	81590	2575	9.93E-03	1.000	1.81E-02	1.000	37.65	13661	81790
2503	9.88E-03	0.998	2.70E-02	1.000	74.00	193553	81590	2576	9.3CE-03	1.000	1.48E-02	1.000	33.73	2U26	81790
2504	9.50E-03	1.000	2.44E-02	1.000	65.95	200008	81590	2577	9.58E-03	1.000	1.48E-02	1.000	33.91	72158	81790
2505	9.14E-03	1.000	2.47E-02	1.000	87.80	202425	81590	2578	9.09E-03	0.998	2.51E-02	1.000	66.47	24938	81790
2506	8.37E-03	0.999	2.54E-02	1.000	69.71	204641	81590	2579	9.82E-03	1.000	2.57E-02	1.000	67.61	31415	81790
2507	8.32E-03	1.000	2.43E-02	1.000	66.14	211253	81590	2580	1.00E-02	1.000	1.91E-02	1.000	44.88	33853	81790
2508	8.48E-03	1.000	2.33E-02	0.998	62.58	213708	81590	2581	1.01E-02	1.000	1.68E-02	1.000	36.16	40332	81790
2509	8.43E-03	0.999	1.92E-02	0.993	53.35	220124	81590	2582	9.63E-03	1.000	1.00E-02	0.998	19.17	45802	81790
2510	9.78E-03	1.000	1.93E-02	0.999	49.37	222539	81590	2583	9.58E-03	1.000	2.30E-02	1.000	58.44	52041	81790
2511	9.66E-03	1.000	2.15E-02	0.998	58.79	224954	81590	2584	9.63E-03	1.000	1.87E-02	1.000	48.19	54518	81790
2512	9.62E-03	1.000	2.70E-02	0.996	74.26	231409	81590	2585	9.29E-03	1.000	1.36E-02	1.000	31.85	80958	81790
2513	9.87E-03	1.000	2.78E-02	0.998	75.97	233825	81590	2586	9.53E-03	0.993	1.20E-02	1.000	26.82	83433	81790
2514	9.88E-03	1.000	3.11E-02	1.000	87.42	241	81590	2587	8.71E-03	1.000	1.36E-02	0.991	32.24	65812	81790
2515	9.55E-03	0.999	3.32E-02	0.994	94.40	2656	81590	2588	4.38E-03	0.977	2.21E-02	1.000	63.10	72354	81790
2516	9.98E-03	1.000	3.12E-02	1.000	87.45	5116	81590	2589							
2517	8.48E-03	0.994	2.86E-02	1.000	81.08	11536	81590	2590	7.4RE-03	1.000	1.01E-02	1.000	19.92	81843	81790
2518	9.90E-03	0.999	2.94E-02	1.000	81.72	13653	81590	2591	8.13E-03	1.000	1.15E-02	1.000	22.09	84416	81790
2519	9.80E-03	1.000	2.89E-02	1.000	73.85	20411	81590	2592	8.89E-03	0.964	2.58E-02	1.000	62.72	90847	81790
2520	9.32E-03	0.999	2.27E-02	1.000	66.95	22831	81590	2593	1.04E-02	0.978	1.29E-02	1.000	24.67	83119	81790
2521	9.79E-03	1.000	2.93E-02	1.000	81.60	25250	81590	2594	9.71E-03	1.000	1.29E-02	1.000	25.48	86744	81790
2522	9.90E-03	0.998	3.01E-02	1.000	83.81	31711	81590	2595	9.85E-03	1.000	1.22E-02	1.000	23.36	102211	81790
2523	9.45E-03	0.999	3.01E-02	1.000	84.71	34129	81590	2596	1.02E-02	0.987	1.28E-02	1.000	24.01	104637	81790
2524	1.08E-02	1.000	1.40E-02	1.000	31.53	40543	81590	2597	9.47E-03	1.000	1.44E-02	1.000	28.72	111104	81790
2525	9.20E-03	1.000	1.12E-02	1.000	24.03	42958	81590	2598	9.45E-03	1.000	2.41E-02	1.000	57.02	113631	81790
2526	9.19E-03	1.000	6.24E-03	0.979	14.66	45108	81590	2599	1.01E-02	1.000	1.80E-02	0.998	42.94	115668	81790
2527	8.88E-03	0.998	3.54E-03	0.986	-0.03	51018	81590	2600	9.82E-03	1.000	2.28E-02	0.988	53.22	122413	81790
2528	8.25E-03	1.000	4.25E-03	1.000	3.08	54229	81590	2601	1.00E-02	1.000	1.58E-02	1.000	32.71	124832	81790
2529	8.15E-03	0.970	4.22E-03	0.986	3.10	80643	81590	2602	9.77E-03	0.977	1.50E-02	1.000	31.27	131257	81790
2530	8.26E-03	0.991	4.21E-03	1.000	2.92	83068	81590	2603	9.88E-03	1.000	2.08E-02	0.988	48.84	133723	81790
2531								2604	1.01E-02	1.000	2.71E-02	1.000	65.02	140152	81790
2532								2605	1.06E-02	1.000	2.98E-02	0.988	72.36	142825	81790
2533								2606	2.28E-04	0.949	2.85E-02	1.000	82.58	146656	81790
2534	9.17E-03	0.999	3.08E-03	0.929	-1.90	82930	81590	2607	9.92E-03	0.986	2.75E-02	1.000	68.10	151457	81790
2535	8.56E-03	0.999	6.32E-03	0.916	9.31	86343	81590	2608	1.09E-02	1.000	3.61E-02	1.000	89.33	153600	81790
2536	8.97E-03	0.992	6.20E-03	1.000	8.41	91754	81590	2609	1.14E-02	1.000	2.18E-02	1.000	48.33	160303	81790
2537	8.49E-03	1.000	6.09E-03	1.000	8.64	94208	81590	2610	1.10E-02	1.000	1.82E-02	1.000	36.91	162875	81790
2538	8.54E-03	1.000	1.68E-02	1.000	42.26	100619	81590	2611	1.11E-02	1.000	1.93E-02	1.000	41.79	165101	81790
2539	9.06E-03	1.000	1.04E-02	0.998	22.36	103031	81590	2612	1.10E-02	1.000	3.32E-02	1.000	81.07	171430	81790
2540	8.56E-03	1.000	6.82E-03	0.999	10.88	106441	81590	2613	1.08E-02	1.000	3.20E-02	1.000	77.67	173757	81790
2541	8.79E-03	1.000	6.55E-03	1.000	9.78	111863	81590	2614	9.84E-03	0.987	1.87E-02	1.000	41.42	182000	81790
2542	8.72E-03	1.000	8.88E-03	0.958	10.83	114308	81590	2615	5.92E-05	0.934	1.82E-02	1.000	51.20	182827	81790
2543	8.50E-03	1.000	1.34E-02	1.000	32.11	120721	81590	2616	3.08E-04	0.915	2.35E-02	1.000	65.88	184800	81790
2544	8.66E-03	0.999	8.78E-03	1.000	10.85	123136	81590	2617	2.79E-04	0.977	2.04E-02	1.000	57.17	181329	81790
2545	8.48E-03	1.000	9.72E-03	0.9											

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 28 to Sept 1, 1990)**

Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/L/sec	Coef. Corr.	OUR 2 mg/L/sec	Coef. Corr.	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY
2629								2702							
2630								2703							
2631								2704							
2632								2705							
2633								2706							
2634								2707	7.05E-03	1.000	8.02E-03	1.000	13.77	84944	81990
2635								2707	6.36E-03	0.999	5.57E-03	0.998	8.02	91400	81990
2636								2708	6.00E-03	0.999	6.10E-03	0.998	8.09	93629	81990
2637								2708	6.36E-03	1.000	7.11E-03	1.000	12.10	100309	81990
2638								2710	6.35E-03	1.000	8.07E-03	0.998	9.35	104342	81990
2639								2711	6.17E-03	1.000	6.16E-03	1.000	9.77	110754	81990
2640								2712	5.88E-03	0.999	7.88E-03	1.000	14.12	113223	81990
2641								2713	8.22E-03	1.000	9.26E-03	0.999	15.79	115701	81990
2642								2714	8.67E-03	1.000	9.57E-03	1.000	16.14	122123	81990
2643								2715	8.13E-03	1.000	9.57E-03	1.000	16.73	124545	81990
2644								2716	8.33E-03	0.997	9.65E-03	1.000	18.74	131006	81990
2645								2717	7.28E-03	1.000	1.01E-02	1.000	18.92	133429	81990
2646								2718	8.66E-03	0.999	1.02E-02	1.000	17.88	135850	81990
2647								2719	8.18E-03	1.000	1.02E-02	1.000	18.28	142314	81990
2648								2720	8.03E-03	0.999	1.12E-02	1.000	21.24	144733	81990
2649	8.07E-03	0.999	8.32E-03	1.000	13.46	85444	81890	2721	9.22E-03	1.000	1.08E-02	1.000	19.16	151154	81990
2650	7.17E-03	0.999	5.98E-03	1.000	8.23	94209	81890	2722	9.15E-03	1.000	1.08E-02	0.999	19.29	153612	81990
2651	8.78E-03	1.000	7.39E-03	0.976	12.38	100647	81890	2723	9.28E-03	1.000	1.22E-02	1.000	22.30	160030	81990
2652	7.12E-03	1.000	8.19E-03	1.000	14.13	103128	81890	2724	9.18E-03	1.000	1.18E-02	1.000	21.70	162450	81990
2653								2725	9.32E-03	1.000	1.31E-02	1.000	24.82	164911	81990
2654								2726	9.32E-03	1.000	1.47E-02	0.999	29.15	171332	81990
2655	7.40E-03	0.997	5.84E-03	1.000	7.82	120921	81890	2727	9.21E-03	1.000	1.34E-02	1.000	25.71	173758	81990
2656	6.27E-03	1.000	9.24E-03	1.000	17.82	123345	81890	2728	9.21E-03	1.000	1.80E-02	0.997	37.94	180217	81990
2657	7.23E-03	1.000	9.17E-03	1.000	16.82	125809	81890	2729	9.43E-03	1.000	1.87E-02	0.999	34.33	182637	81990
2658	7.12E-03	1.000	9.77E-03	1.000	16.33	132232	81890	2730	9.29E-03	1.000	1.34E-02	1.000	25.83	186058	81990
2659	7.22E-03	1.000	1.01E-02	1.000	19.18	134654	81890	2731	8.71E-03	1.000	1.23E-02	1.000	23.26	191519	81990
2660	7.17E-03	1.000	9.71E-03	0.999	19.06	141118	81890	2732	9.04E-03	1.000	1.31E-02	1.000	25.08	193941	81990
2661	7.28E-03	1.000	1.00E-02	1.000	18.87	143539	81890	2733	9.30E-03	0.999	1.72E-02	1.000	23.90	200402	81990
2662	7.41E-03	1.000	9.79E-03	1.000	18.07	150002	81890	2734	9.08E-03	0.972	1.45E-02	0.998	28.15	202623	81990
2663	6.12E-03	0.999	1.08E-02	1.000	22.17	152427	81890	2735	8.99E-03	1.000	1.85E-02	1.000	34.14	205248	81990
2664	7.22E-03	1.000	1.13E-02	1.000	22.26	154850	81890	2736	8.82E-03	1.000	1.42E-02	0.999	26.22	211704	81990
2665	7.45E-03	1.000	1.52E-02	0.999	32.31	161313	81890	2737	8.75E-03	1.000	1.37E-02	1.000	27.10	214120	81990
2666	8.48E-03	0.995	1.47E-02	0.999	32.01	163740	81890	2738	1.03E-02	0.999	1.24E-02	1.000	22.03	220556	81990
2667	7.77E-03	1.000	1.34E-02	0.999	27.14	170205	81890	2739	1.00E-02	1.000	1.29E-02	1.000	23.30	223021	81990
2668	7.68E-03	1.000	1.86E-02	0.993	41.00	172630	81890	2740	1.02E-02	1.000	1.57E-02	0.944	30.66	225447	81990
2669	7.59E-03	1.000	1.69E-02	1.000	36.59	175051	81890	2741	1.01E-02	1.000	1.30E-02	1.000	23.67	231914	81990
2670	7.48E-03	0.998	1.73E-02	1.000	37.78	181515	81890	2742	8.78E-03	1.000	1.24E-02	0.999	22.56	234342	81990
2671	7.98E-03	0.998	1.54E-02	0.998	32.30	183938	81890	2743	9.84E-03	1.000	1.75E-02	0.998	36.87	809	82000
2672	7.66E-03	1.000	1.30E-02	0.999	26.19	190359	81890	2744	1.08E-02	0.998	1.25E-02	1.000	21.50	3236	82000
2673	7.57E-03	1.000	1.38E-02	0.999	26.47	192826	81890	2745	9.66E-03	0.998	1.25E-02	0.999	22.66	5707	82000
2674	8.04E-03	0.972	1.20E-02	1.000	23.23	195248	81890	2746	9.84E-03	1.000	1.29E-02	1.000	23.66	12134	82000
2675	7.67E-03	1.000	1.40E-02	0.999	26.86	201714	81890	2747	9.78E-03	1.000	1.29E-02	1.000	23.49	144065	82000
2676	6.97E-03	0.995	1.41E-02	0.999	26.82	204145	81890	2748	9.58E-03	1.000	1.32E-02	1.000	24.78	21033	82000
2677	7.64E-03	1.000	1.68E-02	1.000	36.90	210608	81890	2749	9.51E-03	1.000	1.25E-02	1.000	23.13	23503	82000
2678	7.99E-03	0.995	1.20E-02	0.999	23.43	213035	81890	2750	9.93E-03	1.000	1.25E-02	0.999	22.58	25032	82000
2679	7.58E-03	1.000	1.10E-02	1.000	21.17	215508	81890	2751	9.63E-03	1.000	1.21E-02	1.000	21.66	32401	82000
2680	8.49E-03	1.000	1.11E-02	1.000	20.50	221943	81890	2752	9.31E-03	1.000	1.19E-02	0.999	21.64	34833	IC2019
2681	8.48E-03	1.000	9.80E-05	0.907	16.98	224412	81890	2753	9.51E-03	1.000	1.19E-02	0.999	21.22	41304	82000
2682	8.37E-03	0.999	1.32E-02	0.999	26.15	230843	81890	2754	1.03E-02	0.997	1.18E-02	1.000	20.27	43734	82000
2683	7.30E-03	0.998	1.22E-02	1.000	24.44	233317	81890	2755	9.52E-03	0.998	1.04E-02	1.000	17.43	50203	82000
2684	8.68E-03	0.999	1.18E-02	1.000	21.94	236749	81890	2756	9.22E-03	1.000	1.13E-02	0.999	20.15	52632	82000
2685	8.68E-03	1.000	1.28E-02	1.000	24.78	2227	81890	2757	9.87E-03	1.000	1.07E-02	1.000	18.72	55104	82000
2686	8.23E-03	1.000	1.19E-02	1.000	22.82	4700	81890	2758	9.03E-03	1.000	1.04E-02	1.000	17.85	61534	82000
2687	8.43E-03	1.000	1.21E-02	1.000	23.22	11138	81890	2759	8.82E-03	1.000	9.74E-03	0.999	18.45	64007	82000
2688	9.36E-03	0.995	1.17E-02	1.000	21.06	13610	81890	2760	8.80E-03	1.000	9.98E-03	0.999	18.47	70438	82000
2689	8.75E-03	1.000	1.23E-02	1.000	23.38	20048	81890	2761	8.31E-03	1.000	9.81E-03	1.000	17.18	72908	82000
2690	8.74E-03	0.998	1.22E-02	1.000	22.93	22521	81890	2762							
2691	8.72E-03	1.000	1.24E-02	1.000	23.52	24983	81890	2763	8.42E-03	1.000	1.13E-02	1.000	27.34	82536	82000
2692	8.64E-03	1.000	1.18E-02	1.000	22.13	31423	81890	2764	8.27E-03	0.999	1.11E-02	1.000	26.97	85007	82000
2693	8.65E-03	0.999	1.15E-02	1.000	21.01	33802	81890	2765	8.87E-03	1.000	9.98E-03	0.999	28.17	100343	82000
2694	8.52E-03	0.997	1.12E-02	1.000	20.68	40345	81890	2766	8.41E-03	1.000	1.05E-02	0.997	77.21	102817	82000
2695	Note 32: Auto-sampler pump tube broken														
2696								2767	8.50E-03	1.000	1.05E-02	1.000	28.17	100343	82000
2697								2768	8.57E-03	1.000	1.31E-02	1.000	33.64	93907	82000
2698								2769	8.67E						

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 28 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 10 to Sept 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY
2775	8.40E-03	1.000	2.86E-02	1.000	80.81	131953	82190	2846	1.08E-02	1.000	2.30E-02	0.988	78.55	164825	82190
2776	9.50E-03	0.998	2.83E-02	1.000	78.05	134429	82190	2848	1.13E-02	1.000	2.16E-02	0.988	70.04	191251	82190
2777	8.82E-03	1.000	2.43E-02	1.000	72.27	140882	82190	2850	1.01E-02	1.000	2.34E-02	1.000	79.20	183724	82190
2778	8.83E-03	1.000	2.88E-02	1.000	80.44	143321	82190	2851	1.04E-02	0.988	2.15E-02	0.988	71.01	200154	82190
2779	9.12E-03	1.000	2.81E-02	1.000	77.83	145750	82190	2852	1.10E-02	1.000	2.03E-02	0.988	68.01	202822	82190
2780	9.07E-03	1.000	2.61E-02	1.000	77.88	152218	82190	2853	1.09E-02	1.000	1.85E-02	0.988	57.93	205051	82190
2781	9.00E-03	1.039	2.83E-02	1.000	78.38	154849	82190	2854	1.05E-02	0.988	2.40E-02	1.000	61.23	211522	82190
2782	9.00E-03	1.000	2.58E-02	1.000	78.93	161118	82190	2855	1.11E-02	0.982	2.03E-02	0.988	64.87	213850	82190
2783	8.89E-03	1.000	2.72E-02	1.000	81.87	159548	82190	2856	1.03E-02	0.988	1.95E-02	0.988	62.76	220421	82190
2784	9.49E-03	2.989	2.50E-02	1.000	78.47	170617	82190	2857	1.01E-02	1.000	2.03E-02	0.988	66.36	222852	82190
2785	9.02E-03	1.000	2.87E-02	1.000	79.98	172447	82190	2858	9.93E-03	1.000	2.17E-02	0.988	72.51	225325	82190
2786	9.94E-03	1.000	2.59E-02	1.000	75.84	174818	82190	2859	1.01E-02	1.000	2.02E-02	0.988	66.07	231755	82190
2787	9.76E-03	1.000	2.53E-02	1.000	74.18	181343	82190	2860	1.01E-02	0.979	2.29E-02	1.000	77.04	234227	82190
2788	9.91E-03	1.000	2.41E-02	1.000	69.85	183810	82190	2861	9.59E-03	0.988	2.07E-02	1.000	66.87	658	82290
2789	9.65E-03	1.000	2.48E-02	1.000	72.44	192327	82190	2862							
2790	9.82E-03	1.000	2.38E-02	1.000	68.89	192705	82190	2863	4.19E-03	1.000	4.98E-03	0.987	13.44	5637	82290
2791	9.09E-03	0.999	2.40E-02	1.000	70.40	195133	82190	2864	3.87E-03	0.988	5.87E-03	0.988	17.68	121111	82290
2792	9.54E-03	1.000	2.63E-02	1.000	77.87	201803	82190	2865	3.71E-03	0.999	4.48E-02	0.987	12.13	14541	82290
2793	9.89E-03	1.000	2.27E-02	1.000	64.92	204031	82190	2866	4.17E-03	0.997	4.85E-03	0.988	13.03	21000	82290
2794	1.02E-02	0.997	2.20E-02	1.000	64.07	210457	82190	2867	3.93E-03	0.998	6.12E-03	0.988	18.62	23425	82290
2795	9.55E-03	1.000	2.19E-02	1.000	62.84	212623	82190	2868	3.82E-03	1.000	5.30E-03	0.988	15.42	25463	82290
2796	9.39E-03	1.000	2.24E-02	1.000	64.58	215348	82190	2869	3.75E-03	0.988	7.83E-03	0.988	25.91	32220	82290
2797	1.04E-02	0.987	2.81E-02	1.000	75.96	221913	82190	2870	3.63E-03	0.988	6.28E-03	1.000	19.67	34747	82290
2798	9.59E-03	0.999	2.74E-02	1.000	81.58	224240	82190	2871	3.83E-03	1.000	6.13E-03	0.988	18.80	41208	82290
2799	1.12E-02	1.000	2.79E-02	1.000	81.20	230705	82190	2872	3.61E-03	0.988	6.94E-03	0.988	22.47	43637	82290
2800	1.08E-02	1.000	1.88E-02	1.000	50.28	231333	82190	2873	3.83E-03	1.000	6.03E-03	0.988	18.51	50102	82290
2801	1.04E-02	1.000	2.63E-02	1.000	78.53	235568	82190	2874	3.48E-02	1.000	8.74E-03	0.988	30.08	52530	82290
2802	1.08E-02	1.000	2.42E-02	1.000	68.08	2023	82190	2875	3.81E-03	1.000	7.58E-03	0.988	24.77	54052	82290
2803	9.04E-03	0.980	2.30E-02	1.000	67.09	4450	82190	2876	3.88E-03	1.000	6.82E-03	0.988	29.27	61421	82290
2804	1.04E-02	0.989	2.32E-02	1.000	65.98	10817	82190	2877	6.00E-03	1.000	9.36E-03	0.987	28.58	63848	82290
2805	9.72E-03	1.000	2.77E-02	1.000	82.45	13147	82190	2878	6.29E-03	1.000	9.04E-03	0.988	26.68	70007	82290
2806	1.18E-02	1.000	2.73E-02	1.000	78.08	15818	82190	2879	6.30E-03	1.000	9.08E-03	0.988	26.85	72733	82290
2807	1.11E-02	1.000	2.23E-02	1.000	61.70	22248	82190	2880	8.32E-03	1.000	7.52E-03	0.988	20.43	75203	82290
2808	1.00E-02	1.000	2.10E-02	1.000	58.72	24714	82190	2881							
2809	1.00E-02	1.000	2.09E-02	1.000	58.49	31140	82190	2882	5.89E-03	1.000	1.10E-02	0.987	36.75	83801	82290
2810	9.98E-03	0.999	1.81E-02	1.000	43.38	33607	82190	2883	6.01E-03	0.988	6.55E-03	0.970	18.85	90330	82290
2811	9.37E-03	1.000	1.82E-02	1.000	49.88	40038	82190	2884	5.38E-03	1.000	1.04E-02	0.988	33.57	92802	82290
2812	8.79E-03	1.000	1.85E-02	1.000	44.98	42504	82190	2885	5.81E-03	1.000	1.06E-02	0.988	34.73	95232	82290
2813	9.17E-03	1.000	1.45E-02	1.000	37.37	44932	82190	2886	6.04E-03	1.000	9.90E-03	0.988	30.61	101704	82290
2814	8.43E-03	1.000	1.45E-02	1.000	38.58	51401	82190	2887	6.01E-03	0.983	8.02E-03	0.988	22.98	104135	82290
2815	8.41E-03	1.000	1.18E-02	1.000	28.64	53827	82190	2888	4.23E-03	1.000	1.75E-02	1.000	61.41	110808	82290
2816	7.73E-03	0.984	1.09E-02	1.000	26.91	60254	82190	2889	7.26E-03	1.000	1.25E-02	0.982	38.19	113039	82290
2817	7.52E-03	1.000	0.77E-03	0.989	23.17	62722	82190	2890	6.48E-03	1.000	1.36E-02	1.000	44.81	115610	82290
2818	7.70E-03	1.000	1.85E-02	1.000	53.31	65150	82190	2891	6.74E-03	0.988	1.33E-02	0.988	43.47	121943	82290
2819	7.88E-03	1.000	2.00E-02	1.000	58.24	71619	82190	2892	6.85E-03	0.988	1.67E-02	1.000	57.26	124414	82290
2820	8.49E-03	1.000	1.72E-02	1.000	47.91	74051	82190	2893	6.87E-03	1.000	1.81E-02	0.988	56.02	130847	82290
2821								2894	6.79E-03	1.000	1.80E-02	1.000	54.53	133308	82290
2822	8.54E-03	1.000	9.12E-03	0.988	23.34	83832	82190	2895	7.48E-03	1.000	1.56E-02	0.988	51.15	136728	82290
2823	7.27E-03	1.000	8.62E-03	0.989	23.36	90302	82190	2896	8.87E-03	0.984	1.32E-02	0.988	38.51	142150	82290
2824	8.66E-03	1.000	1.09E-02	0.988	30.37	92731	82190	2897	7.00E-03	0.987	1.34E-02	0.988	44.15	144610	82290
2825	9.14E-03	1.000	1.10E-02	0.989	30.18	95158	82190	2898	7.51E-03	1.000	1.26E-02	0.988	38.26	151030	82290
2826	8.72E-03	1.000	1.07E-02	0.989	28.65	101824	82190	2899	7.10E-03	0.988	1.22E-02	0.988	38.13	153456	82290
2827	8.66E-03	1.000	2.14E-02	0.989	73.18	104057	82190	2900	7.33E-03	1.000	1.24E-02	0.988	38.85	156818	82290
2828	8.93E-03	1.000	1.25E-02	0.989	38.48	110529	82190	2901	8.88E-03	1.000	1.29E-02	0.988	38.18	182344	82290
2829	9.55E-03	1.000	1.36E-02	0.987	39.60	113005	82190	2902	8.71E-03	1.000	1.41E-02	0.987	43.38	164810	82290
2830	Note 33: Solenoid #3 leaked due to debris blocking valve							2903	8.87E-03	1.000	2.15E-02	1.000	73.48	171240	82290
2831								2904	8.91E-03	0.988	1.74E-02	0.987	58.77	173707	82290
2832								2905	9.32E-03	1.000	1.77E-02	0.988	57.04	180134	82290
2833								2906	9.49E-03	1.000	1.79E-02	0.988	57.68	182802	82290
2834								2907	9.04E-03	1.000	1.82E-02	0.988	51.82	186034	82290
2835								2908	8.89E-03	1.000	1.74E-02	0.988	57.10	181504	82290
2836								2909	9.21E-03	1.000	1.11E-02	0.988	30.48	183834	82290
2837								2910	9.46E-03	1.000	1.54E-02	0.988	49.25	200404	82290
2838								2911	9.42E-03	1.000	1.82E-02	0.988	64.85	202837	82290
2839															

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY
2921	1.10E-02	0.988	2.29E-02	0.988	75.88	3308	82380	2994	8.31E-03	0.988	5.30E-03	0.979	9.61	61531	82490
2922	1.05E-02	0.988	2.51E-02	1.000	88.59	5733	82380	2995	3.75E-03	0.982	3.33E-03	0.986	3.58	64004	82490
2923	1.05E-02	0.988	2.81E-02	0.988	88.52	12200	82380	2996	5.82E-03	0.982	4.15E-03	0.978	6.32	70435	82490
2924	1.08E-02	1.000	1.90E-02	0.991	80.40	14628	82380	2997	8.08E-03	0.985	4.15E-03	0.983	5.95	72908	82490
2925	1.05E-02	1.000	1.53E-02	0.988	45.43	21058	82380	2998	5.94E-03	0.986	4.45E-03	0.985	7.18	75335	82490
2926	9.64E-03	0.988	2.35E-02	1.000	80.46	23622	82380	2999	8.18E-03	1.000	9.43E-03	1.000	24.12	84926	82490
2927	1.02E-02	1.000	1.70E-02	0.988	52.78	25046	82380	3001	5.91E-03	1.000	9.30E-03	1.000	20.55	91348	82490
2928	1.03E-02	1.000	1.38E-02	0.995	38.81	32414	82380	3002	4.08E-03	1.000	7.89E-03	0.988	18.04	93857	82490
2929	9.42E-03	0.987	1.07E-02	0.988	28.19	34848	82380	3003	9.15E-03	1.000	9.13E-03	1.000	18.95	100227	82490
2930	9.75E-03	1.000	1.89E-02	0.988	81.44	41318	82380	3004	8.57E-03	1.000	8.80E-03	1.000	21.37	102644	82490
2931	8.88E-03	0.975	1.98E-02	1.000	88.62	43748	82380	3005	5.97E-03	0.988	8.58E-03	0.988	21.35	105104	82490
2932	9.23E-03	0.988	1.59E-02	0.988	48.80	50219	82380	3008	5.75E-03	0.988	7.70E-03	0.988	18.91	111318	82490
2933	8.83E-03	0.988	9.85E-03	0.988	25.03	52648	82380	3007	5.88E-03	0.988	7.62E-03	0.988	18.23	113638	82490
2934	9.01E-03	0.988	8.44E-03	0.988	18.77	55119	82380	3008	5.88E-03	1.000	7.84E-03	1.000	18.98	120404	82490
2935	8.19E-03	0.988	1.26E-02	0.987	38.22	61562	82380	3009	5.82E-03	0.988	8.12E-03	0.988	21.37	122628	82490
2936	8.62E-03	0.988	1.17E-02	0.987	33.74	64023	82380	3010	6.78E-03	1.000	6.73E-03	0.987	15.27	125244	82490
2937	8.77E-03	0.987	8.03E-03	0.988	18.52	70453	82380	3011	5.29E-03	0.989	7.38E-03	0.990	18.22	131710	82490
2938	8.61E-03	0.982	1.16E-02	1.000	33.58	72924	82380	3012	5.52E-03	0.989	7.54E-03	0.988	18.46	134132	82490
2939	8.61E-03	0.982	1.16E-02	1.000	33.58	72924	82380	3013	5.04E-03	0.988	6.59E-03	0.989	15.80	140547	82490
2940								3014	5.08E-03	1.000	5.75E-03	0.978	12.88	143008	82490
2941	7.90E-03	0.988	5.77E-03	0.973	10.40	83732	82380	3015	5.31E-03	0.988	7.14E-03	0.988	17.38	145425	82490
2942	6.28E-03	0.989	5.28E-03	0.981	8.84	90157	82380	3016	5.00E-03	0.989	6.88E-03	0.988	16.18	151842	82490
2943	7.42E-03	1.000	7.15E-03	0.988	14.48	92627	82380	3017	4.89E-03	1.000	7.14E-03	0.989	17.94	154305	82490
2944	7.98E-03	1.000	2.31E-02	1.000	69.07	95057	82380	3018	4.75E-03	0.989	6.84E-03	0.987	16.39	160722	82490
2945	7.34E-03	0.987	5.47E-03	0.977	8.78	101527	82380	3019							
2946	7.35E-03	0.988	8.32E-03	0.984	17.94	103658	82380	3020	3.20E-03	0.982	1.07E-02	1.000	33.58	171832	82490
2947	7.08E-03	0.988	7.01E-03	0.987	13.27	110427	82380	3021	6.84E-03	0.988	1.10E-02	1.000	28.57	174058	82490
2948	8.38E-03	0.988	7.31E-03	0.988	13.71	112658	82380	3022	5.58E-03	0.989	1.20E-02	1.000	33.73	180526	82490
2949	7.97E-03	0.988	6.98E-03	0.988	15.08	115327	82380	3023	5.48E-03	0.987	1.19E-02	1.000	33.77	182953	82490
2950	7.49E-03	0.988	6.80E-03	0.984	18.51	121800	82380	3024	6.09E-03	1.000	1.17E-02	1.000	31.94	185415	82490
2951	7.68E-03	0.988	9.43E-03	0.988	22.00	124231	82380	3025	6.03E-03	0.988	1.24E-02	1.000	34.53	191040	82490
2952	8.10E-03	0.988	1.50E-02	0.988	42.66	130701	82380	3026	5.88E-03	1.000	1.14E-02	0.988	31.39	194305	82490
2953	7.74E-03	0.988	1.34E-02	0.988	36.80	133130	82380	3027	6.02E-03	1.000	1.17E-02	1.000	31.99	200729	82490
2954	7.37E-03	0.988	9.23E-03	0.980	21.78	135603	82380	3028	5.25E-03	0.989	1.27E-02	1.000	35.97	203158	72490
2955	7.72E-03	0.988	1.08E-02	0.983	28.81	142034	82380	3029	6.04E-03	1.000	1.19E-02	1.000	32.71	205625	82490
2956	7.90E-03	0.988	9.08E-03	0.988	20.53	144503	82380	3030	5.85E-03	1.000	1.06E-02	1.000	28.31	212047	82490
2957	7.71E-03	0.988	7.53E-03	0.987	15.40	150832	82380	3031	5.88E-03	0.987	1.23E-02	1.000	34.72	214512	82490
2958	7.73E-03	0.988	6.68E-03	0.988	12.36	153407	82380	3032	5.70E-03	0.988	1.88E-02	0.984	57.48	220937	82490
2959	7.47E-03	0.988	7.19E-03	0.985	14.58	155830	82380	3033	6.20E-03	1.000	1.30E-02	1.000	36.58	223408	82490
2960	8.77E-03	0.988	9.42E-03	0.983	23.22	162301	82380	3034	5.73E-03	1.000	1.15E-02	1.000	31.78	225650	82490
2961	1.05E-02	1.000	8.08E-03	0.978	13.41	164734	82380	3035	6.08E-03	1.000	1.30E-02	0.988	36.70	222254	82490
2962	8.68E-03	0.988	6.04E-03	0.970	8.63	171210	82380	3036	8.41E-03	1.000	1.04E-02	1.000	27.28	234725	82490
2963	8.95E-03	0.988	5.29E-03	0.980	5.90	173641	82380	3037	6.19E-03	1.000	1.15E-02	1.000	31.27	1152	82580
2964	8.30E-03	0.973	7.52E-03	0.979	14.54	180111	82380	3038	8.32E-03	1.000	1.05E-02	1.000	27.44	3619	82580
2965	8.43E-03	0.988	5.17E-03	0.956	5.21	182542	82380	3039	6.04E-03	0.988	1.04E-02	1.000	27.43	10047	82580
2966	8.37E-03	0.988	6.38E-03	0.976	10.48	185010	82380	3040	6.03E-03	1.000	1.08E-02	1.000	26.38	12513	82580
2967	6.25E-03	0.988	7.87E-03	0.979	16.15	181438	82380	3041	5.88E-03	1.000	1.01E-02	1.000	26.78	14936	82580
2968	8.03E-03	0.988	4.75E-03	0.953	4.08	183611	82380	3042	8.00E-03	1.000	1.03E-02	1.000	27.45	21403	82580
2969	8.02E-03	0.988	7.21E-03	0.983	13.87	200340	82380	3043	5.43E-03	1.000	1.17E-02	1.000	32.93	23629	82580
2970	8.57E-03	0.987	6.55E-03	0.976	7.44	202807	82380	3044	8.22E-03	1.000	8.89E-03	1.000	25.81	30256	82580
2971	8.18E-03	0.987	4.31E-03	0.988	3.82	205238	82380	3045	6.13E-03	1.000	1.56E-02	0.986	46.04	32722	82580
2972	7.82E-03	0.987	7.58E-03	0.981	15.32	211702	82380	3046	6.02E-03	1.000	1.03E-02	1.000	27.17	36147	82580
2973	7.85E-03	0.987	4.82E-03	0.943	5.42	214131	82380	3047	6.10E-03	1.000	8.67E-03	1.000	25.01	41813	82580
2974	7.85E-03	0.988	4.01E-03	0.948	3.03	220802	82380	3048	5.81E-03	1.000	8.53E-03	1.000	24.94	44041	82580
2975	7.50E-03	0.988	3.33E-03	0.905	1.04	223029	82380	3049	5.85E-03	1.000	9.44E-03	1.000	24.58	50509	82580
2976	7.43E-03	0.988	6.54E-03	0.924	8.81	225458	82380	3050	5.93E-03	1.000	8.80E-03	1.001	22.58	52936	82580
2977	7.89E-03	0.987	2.85E-03	0.981	-1.27	231922	82380	3051	5.40E-03	1.000	8.06E-03	1.000	23.87	55407	82580
2978	7.28E-03	0.988	4.83E-03	0.984	7.00	234361	82380	3052	6.82E-03	1.000	9.00E-03	1.000	23.38	61836	82580
2979	7.97E-03	0.987	1.08E-03	0.958	-7.29	820	82490	3053	5.53E-03	1.000	8.98E-03	0.988	23.41	64308	82580
2980	7.88E-03	0.988	4.05E-03	0.948	3.38	3248	82490	3054	5.25E-03	1.000	1.00E-02	0.975	27.42	70743	82580
2981	7.15E-03	0.988	1.84E-03	0.728	-3.52	5717	82490	3055	5.28E-03	1.000	8.85E-03	1.000	23.33	73215	82580
2982	7.12E-03	0.982	6.38E-03	0.914	12.27	21242	82490	3056	4.98E-03						

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 26 to Sept. 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gHr	Time HHMMSS	Date MDDYY
3067	6.63E-03	1.000	1.02E-02	1.000	26.02	123348	82580	3140	6.92E-03	1.000	7.85E-03	0.988	18.30	190638	82680
3068	6.55E-03	1.000	9.91E-03	1.000	25.24	125814	82580	3141	6.61E-03	1.000	7.93E-03	1.000	18.11	183051	82680
3069	6.48E-03	1.000	1.02E-02	1.000	26.42	132238	82580	3142	6.49E-03	1.000	7.52E-03	0.988	17.72	186508	82680
3070	6.19E-03	1.000	1.03E-02	1.000	27.05	13/702	82580	3143	6.46E-03	1.000	7.81E-03	0.988	18.18	201824	82680
3071	6.44E-03	1.000	1.05E-02	1.000	27.42	141126	82580	3144	6.47E-03	1.000	7.80E-03	1.000	18.78	204342	82680
3072	6.68E-03	1.000	1.08E-02	1.000	27.48	143648	82580	3145	6.58E-03	1.000	8.40E-03	1.000	20.79	210758	82680
3073	6.60E-03	1.000	1.07E-02	1.000	28.01	150015	82580	3146	6.44E-03	1.000	8.28E-03	1.000	20.58	214838	82680
3074	6.28E-03	1.000	1.11E-02	1.000	29.68	152447	82580	3147	6.68E-03	1.000	8.80E-03	0.988	21.34	220864	82680
3075	6.43E-03	1.000	1.08E-02	1.000	26.53	154818	82580	3148	6.65E-03	1.000	8.54E-03	0.988	20.17	223408	82680
3076	6.58E-03	1.000	1.09E-02	1.000	28.49	161349	82580	3149	6.82E-03	1.000	8.18E-03	1.000	23.14	226423	82680
3077	6.34E-03	1.000	1.19E-02	1.000	32.38	163621	82580	3150	7.08E-03	1.000	8.22E-03	1.000	23.04	232238	82680
3078	6.50E-03	1.000	1.09E-02	1.000	28.64	170252	82580	3151	6.80E-03	1.000	8.56E-03	1.000	24.58	234851	82680
3079	6.43E-03	1.000	1.08E-02	1.000	28.41	172722	82580	3152	7.20E-03	1.000	1.07E-02	1.000	26.01	1107	82780
3080	6.59E-03	1.000	1.08E-02	1.000	28.41	175153	82580	3153	7.21E-03	1.000	1.96E-02	1.000	58.86	3622	82780
3081	6.58E-03	1.000	1.15E-02	1.000	30.70	181824	82580	3154	7.35E-03	1.000	1.97E-02	1.000	80.38	5837	82780
3082	6.71E-03	1.000	1.10E-02	1.000	28.95	184604	82580	3155	7.23E-03	1.000	1.84E-02	1.000	55.88	12363	82780
3083	6.80E-03	1.000	1.08E-02	1.000	27.98	190522	82580	3156	6.78E-03	1.000	1.28E-02	0.988	38.58	14808	82780
3084	6.60E-03	1.000	1.08E-02	0.999	27.67	192852	82580	3157	6.66E-03	1.000	1.25E-02	0.988	35.04	21225	82780
3085	6.56E-03	1.000	1.04E-02	1.000	27.03	195425	82580	3158	7.11E-03	1.000	1.13E-02	0.988	30.49	23642	82780
3086	6.63E-03	1.000	1.05E-02	1.000	27.10	201867	82580	3159	6.74E-03	1.000	1.15E-02	0.988	31.58	30059	82780
3087	6.55E-03	1.000	1.08E-02	0.989	27.58	204329	82580	3160	6.85E-03	1.000	1.05E-02	1.000	27.82	32515	82780
3088	6.64E-03	1.000	1.01E-02	0.986	25.86	212800	82580	3161	6.71E-03	1.000	1.03E-02	1.000	27.58	34093	82780
3089	6.92E-03	1.000	1.05E-02	1.000	26.58	215218	82580	3162	6.40E-03	1.000	1.08E-02	1.000	50.81	41383	82780
3090	6.81E-03	1.000	1.07E-02	1.000	27.58	221643	82580	3163	6.18E-03	1.000	1.01E-02	1.000	58.48	43811	82780
3091	7.08E-03	1.000	9.95E-03	1.000	24.65	224100	82580	3164	6.50E-03	1.000	8.03E-03	1.000	22.43	50231	82780
3092	6.87E-03	1.000	1.02E-02	1.000	25.83	230527	82580	3165	6.07E-03	1.000	8.92E-03	1.000	23.38	52653	82780
3093	7.02E-03	1.000	1.02E-02	1.000	25.71	232652	82580	3166	5.98E-03	1.000	1.08E-02	1.000	52.55	58114	82780
3094	6.54E-03	1.000	1.03E-02	1.000	28.47	236412	82580	3167	5.93E-03	1.000	8.12E-03	0.988	20.88	61538	82780
3095	6.75E-03	1.000	1.10E-02	1.000	28.75	1836	82680	3168	5.58E-03	1.000	7.93E-03	1.000	20.50	83687	82780
3096	6.75E-03	1.000	1.02E-02	1.000	28.01	4258	82680	3169	5.38E-03	1.000	1.38E-02	0.988	42.40	70418	82780
3097	6.85E-03	1.000	1.03E-02	1.000	28.49	10717	82680	3170	5.27E-03	1.000	7.38E-03	0.988	18.88	72840	82780
3098	6.87E-03	1.000	1.03E-02	1.000	28.30	13142	82680	3171							
3099	6.84E-03	1.000	1.10E-02	1.000	28.78	15008	82680	3172	6.07E-03	0.988	7.78E-03	1.000	21.81	82721	82780
3100	6.56E-03	1.000	1.04E-02	1.000	28.79	22329	82680	3173	6.29E-03	1.000	1.36E-02	1.000	44.82	85139	82780
3101	6.78E-03	1.000	1.03E-02	1.000	28.30	24452	82680	3174	6.00E-03	0.988	8.81E-03	1.000	28.20	81557	82780
3102	6.72E-03	1.000	9.98E-03	1.000	25.27	30617	82680	3175	6.31E-03	1.000	7.88E-03	0.988	21.00	94014	82780
3103	6.61E-03	1.000	1.01E-02	0.989	25.90	33341	82680	3176	6.27E-03	1.000	7.48E-03	1.000	20.38	100428	82780
3104	6.80E-03	1.000	9.78E-03	1.000	24.85	36805	82680	3177	5.81E-03	1.000	8.07E-03	1.000	23.36	102844	82780
3105	6.52E-03	1.000	9.88E-03	1.000	24.38	42230	82680	3178	6.18E-03	1.000	1.08E-02	1.000	57.87	106303	82780
3106	6.48E-03	1.000	9.81E-03	1.000	24.30	44867	82680	3179	6.54E-03	1.000	1.30E-02	1.000	42.32	111717	82780
3107	6.54E-03	1.000	9.52E-03	1.000	23.88	51122	82680	3180	6.20E-03	1.000	1.12E-02	1.000	36.56	114130	82780
3108	6.49E-03	1.000	9.37E-03	1.000	23.43	53547	82680	3181	6.32E-03	1.000	1.70E-02	1.000	58.27	120644	82780
3109	6.31E-03	1.000	8.88E-03	1.000	22.02	60013	82680	3182	6.25E-03	1.000	1.82E-02	1.000	64.28	123002	82780
3110	6.24E-03	1.000	8.88E-03	1.000	22.11	62438	82680	3183	6.43E-03	1.000	1.88E-02	1.000	58.23	125418	82780
3111	6.34E-03	1.000	8.77E-03	1.000	21.58	64808	82680	3184	6.41E-03	1.000	2.01E-02	1.000	71.84	131834	82780
3112	6.17E-03	1.000	8.37E-03	1.000	20.43	71334	82680	3185	7.14E-03	1.000	2.18E-02	1.000	77.88	134250	82780
3113								3186	7.20E-03	1.000	1.97E-02	1.000	68.73	140708	82780
3114								3187	7.11E-03	1.000	2.00E-02	1.000	70.36	143122	82780
3115	5.15E-03	0.988	7.07E-03	1.000	18.03	85825	82680	3188	7.00E-03	1.000	2.11E-02	1.000	74.88	146538	82780
3116	5.72E-03	1.000	6.82E-03	1.000	18.32	92347	82680	3189	7.29E-03	1.000	2.18E-02	1.000	77.70	151864	82780
3117	5.92E-03	1.000	7.78E-03	0.988	19.40	94808	82680	3190	7.47E-03	1.000	1.95E-02	1.000	67.51	154410	82780
3118	5.83E-03	1.000	8.98E-03	1.000	18.77	101232	82680	3191	7.48E-03	1.000	2.08E-02	1.000	71.81	160227	82780
3119	5.95E-03	1.000	7.40E-03	1.000	18.08	103686	82680	3192	7.59E-03	1.000	1.80E-02	1.000	85.13	163242	82780
3120	6.03E-03	1.000	7.81E-03	1.000	19.77	110117	82680	3193	7.48E-03	1.000	2.04E-02	1.000	71.20	165687	82780
3121	5.81E-03	1.000	7.22E-03	1.000	17.82	112538	82680	3194	7.54E-03	1.000	2.08E-02	1.000	72.85	172112	82780
3122	6.28E-03	1.000	7.45E-03	1.000	17.79	114868	82680	3195	7.48E-03	1.000	1.93E-02	1.000	88.88	174627	82780
3123	6.28E-03	1.000	8.04E-03	1.000	18.91	121417	82680	3196	7.37E-03	1.000	2.05E-02	1.000	71.94	180643	82780
3124	6.33E-03	1.000	8.24E-03	1.000	20.56	128363	82680	3197	7.48E-03	1.000	1.94E-02	1.000	87.21	183367	82780
3125	6.24E-03	1.000	8.87E-03	1.000	22.86	130250	82680	3198	7.29E-03	1.000	1.97E-02	1.000	88.53	188809	82780
3126	6.87E-03	1.000	8.62E-03	1.000	21.44	132704	82680	3199	7.32E-03	1.000	1.88E-02	1.000	86.24	192222	82780
3127	6.62E-03	1.000	8.98E-03	1.000	22.72	136121	82680	3200	6.88E-03	1.000	2.05E-02	1.000	72.47	194698	82780
3128	6.81E-03	1.000	8.53E-03	0.988	20.88	141528	82680	3201	7.64E-03	1.000					

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 29 to Sept 1, 1990)

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar**  
**Wastewater Treatment Plant**  
(June 29 to Sept 1, 1990)

Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gfr	Time HHMMSS	Date MDDYY	Test No.	OUR 1 mg/Lsec	Coef. Corr.	OUR 2 mg/Lsec	Coef. Corr.	SpOUR mg/gfr	Time HHMMSS	Date MDDYY
3213	4.87E-03	1.000	5.83E-03	1.000	16.31	10411	82880	3288	6.19E-03	1.000	6.28E-03	0.989	16.00	64203	82990
3214	4.94E-03	1.000	4.61E-03	0.988	11.60	12631	82880	3287	0.29E-03	1.000	0.52E-03	0.989	16.64	70817	82990
3215	4.78E-03	1.000	8.83E-03	0.988	28.70	15250	82880	3288	5.94E-03	1.000	7.83E-03	0.989	17.25	73027	82990
3218	4.89E-03	1.000	8.95E-03	0.989	28.62	21708	82880	3289	6.84E-03	1.000	9.88E-03	0.989	18.08	82508	82990
3217	4.87E-03	1.000	9.03E-03	0.989	29.31	24124	82880	3289	6.39E-03	1.000	8.58E-03	0.989	18.74	54923	82990
3218	4.83E-03	1.000	9.89E-03	0.989	33.24	30642	82880	3292	0.72E-03	1.000	1.52E-02	0.988	38.97	61326	82990
3219	4.72E-03	1.000	9.03E-03	0.989	29.22	33008	82880	3293	7.25E-03	1.000	8.54E-03	0.989	17.52	9373	82990
3220	4.53E-03	1.000	9.54E-03	0.989	31.61	35430	82880	3294	8.26E-03	1.000	1.94E-02	1.000	52.31	100145	82990
3221	4.50E-03	1.000	8.54E-03	1.000	27.44	41852	82880	3295	7.45E-03	1.000	1.94E-02	1.000	50.87	102553	82990
3222	4.39E-03	1.000	8.35E-03	0.989	28.98	44314	82880	3296	8.48E-04	0.988	9.58E-03	0.988	26.28	105000	82990
3223	4.41E-03	0.988	8.54E-03	0.988	31.81	50736	82880	3297	5.55E-03	1.000	1.74E-02	1.000	47.08	111400	82990
3224	4.49E-03	1.000	1.04E-02	1.000	36.38	53156	82880	3298	8.74E-03	0.988	1.06E-02	0.989	24.26	113812	82990
3225	4.45E-03	1.000	1.02E-02	0.989	34.25	55618	82880	3299	5.22E-03	0.988	1.89E-02	1.000	55.18	120219	82990
3226	4.12E-03	0.988	9.75E-03	0.988	33.15	82043	82880	3300	8.22E-03	0.987	1.00E-02	0.989	24.34	122826	82990
3227	4.16E-03	1.000	9.94E-03	1.000	33.88	84503	82880	3301	2.95E-03	0.981	1.03E-02	1.000	28.44	125031	82990
3228	4.17E-03	1.000	9.70E-03	0.988	32.85	70826	82880	3302	1.58E-04	0.983	1.18E-02	1.000	38.46	131437	82990
3229	4.05E-03	0.988	1.00E-02	0.988	34.32	73382	82880	3303	3.20E-03	0.983	1.35E-02	1.000	37.83	133842	82990
3230	4.04E-03	1.000	9.75E-03	1.000	33.28	75915	82880	3304	1.08E-04	0.987	1.95E-02	1.000	60.33	140248	82990
3231	5.03E-03	1.000	1.19E-02	1.000	30.71	82620	82880	3305	4.03E-03	0.986	1.18E-02	1.000	31.53	142848	82990
3232	3.51E-03	0.987	1.07E-02	1.000	28.83	85247	82880	3306	1.67E-04	0.985	1.58E-02	1.000	49.01	145048	82990
3233	4.26E-03	1.000	7.79E-03	0.989	18.85	91709	82880	3307	2.81E-04	0.988	1.84E-02	1.000	50.41	151449	82990
3234	4.14E-03	1.000	1.07E-02	1.000	28.03	94123	82880	3308	1.62E-04	0.984	1.50E-02	1.000	53.62	153852	82990
3235	4.30E-03	1.000	8.91E-03	1.000	22.32	100642	82880	3309	2.06E-03	0.982	1.74E-02	1.000	51.34	160256	82990
3236	4.36E-03	0.988	8.95E-03	1.000	22.36	102368	82880	3310	3.20E-04	0.471	1.87E-02	1.000	60.85	162657	82990
3237	4.87E-03	1.000	1.21E-02	1.000	31.88	105409	82880	3311	8.48E-03	0.989	2.31E-02	1.000	61.23	165022	82990
3238	4.73E-03	1.000	1.28E-02	1.000	34.27	111828	82880	3312	1.97E-04	0.900	2.28E-02	1.000	69.81	171419	82990
3239	5.31E-03	1.000	1.19E-02	1.000	30.37	114240	82880	3313	7.24E-04	0.705	2.45E-02	1.000	75.24	173820	82990
3240	4.31E-03	0.988	1.20E-02	1.000	31.97	120702	82880	3314	7.37E-06	0.58C	2.18E-02	1.000	68.82	180220	82990
3241	4.75E-03	1.000	1.13E-02	0.989	29.11	123116	82880	3315	0.71E-03	1.000	2.28E-02	1.000	62.59	182621	82990
3242	4.86E-03	1.000	1.02E-02	1.000	28.38	125335	82880	3316	2.14E-04	0.988	1.49E-02	1.000	45.85	185021	82990
3243	4.85E-03	1.000	1.27E-02	1.000	33.58	131850	82880	3317	1.65E-03	0.984	1.52E-02	1.000	45.27	191424	82990
3244	5.20E-03	1.000	1.42E-02	0.989	37.80	134404	82880	3318	8.33E-06	0.700	2.15E-02	1.000	68.63	193821	82990
3245	5.48E-03	1.000	1.32E-02	1.000	34.07	140818	82880	3319	1.74E-04	0.834	1.82E-02	1.000	58.29	202211	82990
3246	5.29E-03	1.000	1.32E-02	0.989	34.32	143235	82880	3320	2.54E-04	0.817	1.72E-02	1.000	53.21	202825	82990
3247	5.49E-03	1.000	1.24E-02	1.000	31.63	145683	82880	3321	3.5E-03	0.985	1.43E-02	1.000	39.80	206024	82990
3248	5.24E-03	1.000	1.41E-02	1.000	37.27	152109	82880	3322	2.54E-04	0.927	1.83E-02	1.000	56.36	211348	82990
3249	6.13E-03	0.988	1.44E-02	1.000	36.98	154625	82880	3323	4.58E-03	0.630	1.88E-02	1.000	45.90	213715	82990
3250	5.48E-03	1.000	1.42E-02	0.989	37.13	160336	82880	3324	2.65E-04	0.881	4.43E-04	0.981	1.05	220040	82990
3251	6.10E-03	1.000	1.29E-02	1.000	31.67	163364	82880	3325	7.28E-03	0.988	7.35E-03	0.988	13.78	224202	82990
3252	6.88E-03	1.000	1.65E-02	1.000	42.78	165804	82880	3326	1.53E-04	0.780	7.13E-04	0.924	2.02	224727	82990
3253	7.04E-03	1.000	1.43E-02	1.000	36.77	172218	82880	3327	3.80E-04	0.848	3.88E-04	0.983	0.87	231064	82990
3254	7.03E-03	1.000	1.45E-02	1.000	38.14	174634	82880	3328	1.80E-03	0.804	1.30E-04	0.705	-1.58	233418	82990
3255	6.84E-03	1.000	1.79E-02	1.000	47.85	181047	82880	3329	1.87E-03	0.948	7.72E-04	0.928	-0.08	236744	82990
3256	6.84E-03	1.000	1.83E-02	1.000	48.04	183600	82880	3330	9.10E-04	0.905	1.18E-03	0.800	2.53	2110	83080
3257	7.14E-03	1.000	1.77E-02	1.000	48.06	185811	82880	3331	3.51E-04	0.974	6.22E-04	0.980	1.49	4434	83080
3258	7.08E-03	1.000	1.87E-02	1.000	49.38	182323	82880	3332	2.54E-04	0.809	4.27E-04	0.932	1.01	10758	83080
3259	7.53E-03	1.000	1.92E-02	1.000	50.37	194734	82880	3333	1.53E-04	0.728	7.92E-06	0.981	0.08	13125	83080
3260	7.51E-03	1.000	1.80E-02	1.000	48.80	201145	82880	3334	3.95E-04	0.933	1.88E-04	0.810	0.02	15461	83080
3261	7.31E-03	1.000	1.75E-02	1.000	45.32	203568	82880	3335	5.21E-04	0.748	7.50E-04	0.938	1.68	21818	83080
3262	7.42E-03	1.000	1.70E-02	1.000	43.51	210008	82880	3336	3.90E-04	0.988	5.44E-04	0.987	1.19	25040	83080
3263	7.21E-03	1.000	1.72E-02	1.000	44.44	212416	82880	3337	5.30E-04	0.972	5.08E-04	0.791	0.81	31405	83080
3264	7.37E-03	1.000	1.58E-02	0.989	39.85	214826	82880	3338	1.80E-04	0.804	5.80E-04	0.970	1.54	33731	83080
3265	7.24E-03	1.000	1.86E-02	1.000	48.48	221238	82880	3339	4.10E-04	0.861	3.23E-04	0.882	0.48	40058	83080
3266	7.80E-03	1.000	1.72E-02	1.000	43.82	228848	82880	3340	3.20E-04	0.948	5.28E-04	0.983	1.23	42421	83080
3267	6.88E-03	1.000	1.76E-02	1.000	48.90	230208	82880	3341	3.34E-04	0.985	6.87E-04	0.986	1.72	44747	83080
3268	6.93E-03	1.000	1.78E-02	1.000	45.28	232619	82880	3342	2.97E-04	0.887	8.36E-04	0.980	-0.11	51112	83080
3269	7.70E-03	1.000	2.01E-02	1.000	52.87	236029	82880	3343	4.92E-05	0.281	6.16E-04	0.804	1.85	53437	83080
3270	7.73E-03	1.000	2.02E-02	1.000	52.86	1441	82880	3344	2.77E-04	0.818	6.32E-04	0.923	1.62	55803	83080
3271	7.88E-03	1.000	1.77E-02	1.000	48.49	3848	82880	3345	3.78E-04	0.901	5.10E-04	0.840	1.11	62128	83080
3272	7.88E-03	1.000	2.10E-02	1.000	55.48	10268	82880	3346	2.34E-04	0.806	1.90E-04	0.956	0.27	64454	83080
3273	8.15E-03	1.000	2.05E-02	1.000	53.38	12707	82880	3347	2.84E-04	0.918	2.89E-04	0.873	0.57	70820	

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 26 to Sept 1, 1990)**

**Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
Wastewater Treatment Plant  
(June 26 to Sept 1, 1990)**


Test No	OUR 1 mg/Lsec	Coef Corr	OUR 2 mg/Lsec	Coef Corr	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY	Test No	OUR 1 mg/Lsec	Coef Corr	OUR 2 mg/Lsec	Coef Corr	SpOUR mg/g/hr	Time HHMMSS	Date MDDYY
3350	7.05E-03	1.000	1.57E-02	0.999	38.00	121834	83080	3432	5.80E-03	1.000	5.25E-03	1.000	8.25	174642	83190
3360	7.15E-03	1.000	1.62E-02	1.000	37.44	124248	83080	3433	6.04E-03	1.000	1.25E-02	0.999	26.50	161117	83190
3361	7.33E-03	1.000	1.84E-02	0.999	43.37	130702	83080	3434	5.84E-03	1.000	1.05E-02	0.999	22.85	163654	83190
3362	7.33E-03	1.000	1.87E-02	1.000	38.64	133115	83080	3435	6.20E-03	0.999	1.42E-02	0.999	33.00	160029	83190
3363	7.38E-03	1.000	1.76E-02	0.999	41.19	135629	83080	3436	6.05E-03	0.999	1.11E-02	0.999	24.26	162458	83190
3364	7.49E-03	1.000	1.80E-02	0.999	42.07	141845	83080	3437	5.90E-03	1.000	1.40E-02	0.999	32.68	164825	83190
3365	7.66E-03	1.000	1.57E-02	0.999	35.42	144358	83080	3438	6.09E-03	1.000	9.88E-03	1.000	21.25	201367	83190
3366	7.14E-03	1.000	1.31E-02	0.999	28.91	150812	83080	3439	5.75E-03	1.000	1.47E-02	1.000	34.78	203828	83190
3367	7.38E-03	0.999	1.12E-02	0.999	23.10	153224	83080	3440	6.04E-03	1.000	1.03E-02	1.000	22.26	210301	83190
3368	7.39E-03	1.000	1.42E-02	0.999	31.67	155606	83080	3441	6.05E-03	1.000	5.80E-03	0.999	6.87	212726	83190
3369	7.08E-03	1.000	9.18E-03	1.000	17.85	162046	83080	3442	6.20E-03	1.000	5.41E-03	0.999	8.24	215148	83190
3370	7.30E-03	1.000	1.17E-02	0.999	24.75	164457	83080	3443	5.55E-03	1.000	5.52E-03	0.999	8.14	221613	83190
3371	7.23E-03	1.000	1.13E-02	0.999	23.73	170818	83080	3444	6.28E-03	1.000	5.82E-03	1.000	9.33	224038	83190
3372	6.87E-03	1.000	9.18E-03	0.999	18.25	175300	83080	3445	6.28E-03	1.000	5.33E-03	0.997	7.85	230602	83190
3373	6.88E-03	1.000	8.77E-03	0.999	11.33	175744	83080	3446	6.03E-03	1.000	5.08E-03	0.999	7.55	232928	83190
3374	6.82E-03	1.000	1.37E-02	0.999	31.05	182201	83080	3447	5.80E-03	1.000	4.79E-03	0.999	8.82	236381	83190
3375	7.00E-03	1.000	1.15E-02	0.999	24.43	184818	83080	3448	8.13E-03	0.999	5.01E-03	0.999	7.20	1817	80180
3376	6.70E-03	1.000	1.23E-02	0.999	27.02	191038	83080	3449	6.13E-03	1.000	6.88E-03	0.997	11.91	4240	80190
3377	6.71E-03	1.000	3.3E-02	0.999	28.98	193455	83080	3450	5.87E-03	1.000	5.42E-03	0.994	8.64	10702	80190
3378	2.98E-05	0.365	9.02E-01	0.999	25.32	195634	83080	3451	5.82E-03	1.000	5.70E-03	0.995	9.47	13129	80190
3379	2.28E-06	0.012	9.64E-03	1.000	27.12	202404	83080	3452	5.72E-03	1.000	6.11E-03	0.999	10.74	15556	80190
3380	6.04E-03	1.000	7.22E-03	0.999	13.51	204823	83080	3453	5.88E-03	1.000	5.84E-03	0.995	9.80	22025	80190
3381	1.77E-05	0.239	6.70E-03	0.999	18.82	212427	83080	3454	5.54E-03	1.000	5.69E-03	0.999	8.78	24452	80190
3382	1.53E-04	0.744	4.88E-03	0.999	13.57	213707	83080	3455	5.53E-03	1.000	5.71E-03	0.999	9.83	30623	80190
3383	6.83E-03	1.000	8.30E-03	0.994	15.87	220122	83080	3456	5.50E-03	1.000	6.18E-03	0.999	11.14	33366	80190
3384	1.68E-04	0.868	5.52E-03	1.000	15.35	225240	83080	3457	5.50E-03	0.999	5.41E-03	0.999	9.03	35824	80190
3385	5.98E-03	1.000	5.11E-03	0.999	7.88	224857	83080	3458	5.17E-03	1.000	5.55E-03	0.995	9.78	42255	80190
3386	6.42E-03	1.000	6.72E-03	1.000	11.68	231412	83080	3459	5.18E-03	0.999	5.77E-03	0.999	10.42	44730	80190
3387	6.46E-03	1.000	7.52E-03	0.999	13.87	233828	83080	3460	5.26E-03	1.000	8.18E-03	0.999	11.48	51208	80190
3388	2.91E-04	0.950	5.18E-03	0.999	14.24	244	83190	3461	5.17E-03	0.999	6.00E-03	0.997	11.05	53645	80190
3389	6.32E-03	1.000	5.64E-03	1.000	8.74	2659	83190	3462	4.98E-03	0.999	5.43E-03	0.997	9.87	80122	80190
3390	3.71E-03	0.993	5.43E-03	1.000	11.10	5115	83190	3463	4.72E-03	0.999	5.28E-03	0.997	9.53	62803	80190
3391	8.07E-03	1.000	8.99E-03	1.000	18.45	11538	83190	3464	4.55E-03	0.999	5.66E-03	0.999	10.80	85043	80190
3392	1.46E-04	0.885	9.45E-03	1.000	26.41	13653	83190	3465							
3393	6.47E-03	1.000	4.30E-03	1.000	4.82	20407	83190	3466	5.70E-03	1.000	4.62E-03	0.997	7.03	75826	80190
3394	5.62E-03	0.999	3.46E-03	0.998	3.42	22821	83190	3467	5.84E-03	1.000	5.12E-03	0.997	8.35	82052	80190
3395	5.84E-03	1.000	3.90E-03	0.994	4.38	25231	83190	3468	5.81E-03	1.000	4.77E-03	0.999	7.32	84618	80190
3396	5.49E-03	1.000	3.75E-03	1.000	4.37	31647	83190	3469	5.75E-03	1.000	4.99E-03	0.999	8.07	90838	80190
3397	5.40E-03	1.000	3.77E-03	0.999	4.54	34107	83190	3470	5.91E-03	1.000	5.22E-03	0.999	8.57	93401	80190
3398	5.42E-03	1.000	3.51E-03	0.997	3.78	40521	83190	3471	5.88E-03	1.000	5.38E-03	0.999	9.18	95822	80190
3399	5.05E-03	1.000	3.62E-03	0.999	4.51	42937	83190	3472	5.84E-03	1.000	4.86E-03	0.999	8.79	102241	80190
3400	4.84E-03	1.000	3.45E-03	0.999	4.27	45363	83190	3473	5.79E-03	1.000	6.07E-03	0.999	11.25	104856	80190
3401	4.29E-03	0.998	3.88E-03	0.999	8.03	51808	83190	3474	5.71E-03	1.000	5.15E-03	0.997	9.80	111118	80190
3402	4.08E-03	1.000	3.80E-03	0.999	5.43	54226	83190	3475	6.00E-03	0.999	4.83E-03	0.971	7.75	113634	80190
3403	4.02E-03	1.000	3.05E-03	0.999	4.07	60647	83190	3476	5.48E-03	0.999	5.52E-03	0.997	10.00	115980	80190
3404	4.31E-03	0.999	3.12E-03	1.001	3.92	63104	83190	3477	5.82E-03	0.999	5.29E-03	0.999	8.88	122411	80190
3405	4.00E-03	1.000	5.19E-03	0.999	4.29	65625	83190	3478	5.88E-03	0.999	5.87E-03	0.999	10.54	124827	80190
3406								3479	6.00E-03	0.999	5.31E-03	0.995	8.74	131240	80190
3407								3480	6.46E-03	1.000	5.66E-03	0.999	8.94	133864	80190
3408	4.65E-03	1.000	3.37E-03	0.999	4.26	80119	83190	3481	6.65E-03	1.000	6.65E-03	0.999	11.88	140108	80190
3409	4.79E-03	1.000	3.82E-03	0.997	4.81	82535	83190	3482	6.43E-03	1.000	5.66E-03	0.997	10.23	142622	80190
3410	4.88E-03	1.000	4.08E-03	0.999	5.94	84850	83190	3483	6.22E-03	0.999	6.31E-03	0.995	11.45	144936	80190
3411	4.88E-03	1.000	3.82E-03	0.999	5.78	91408	83190	3484	6.30E-03	1.000	6.26E-03	0.995	11.21	151351	80190
3412	4.75E-03	1.000	4.21E-03	0.999	8.50	93621	83190	3485	6.21E-03	1.000	5.99E-03	0.995	10.50	153807	80190
3413	4.54E-03	1.000	8.04E-03	1.000	17.51	100238	83190	3486	6.44E-03	0.999	5.93E-03	0.997	10.07	180224	80190
3414	4.74E-03	1.000	6.85E-03	0.997	13.93	123652	83190	3487	6.44E-03	0.999	6.00E-03	0.992	10.29	162642	80190
3415	5.05E-03	1.000	4.85E-03	0.999	8.50	105119	83190	3488	6.13E-03	1.000	5.88E-03	0.992	8.98	165056	80190
3416	5.73E-03	1.000	5.32E-03	0.999	8.51	111544	83190	3489	6.39E-03	1.000	6.07E-03	0.993	10.57	171518	80190
3417	5.83E-03	1.000	4.88E-03	0.997	7.39	114008	83190	3490	6.00E-03	0.999	5.88E-03	0.997	10.43	173808	80190
3418	5.48E-03	1.000	5.53E-03	0.999	9.38	120432	83190	3491	6.36E-03	1.000	5.80E-03	0.999	10.08	180364	80190
3419	5.71E-03	0.999	4.77E-03	0.999	9.99	128584	83190	3492	6.14E-03	1.000	5.88E-03	0.993	10.31	182814	80190
3420	5.40E-03	1.000	4.74E-03	0.999	7.27	125316	83190	3493	6.05E-03	1.000	5.26E-03	0.992	10.18	185234	80190
3421</td															

Specific Oxygen Uptake Rate (SpOUR) Monitoring at Gold Bar  
 Wastewater Treatment Plant  
 (June 28 to Sept 1, 1990)


Test No.	OUR 1 mg/L sec	Coef Corr	OUR 2 mg/L sec	Coef Corr	SpOUR mg/g hr	Time HHMMSS	Date MODYY
3505	0.66E-03	1.000	6.50E-03	0.996	11.78	234423	90190
3506	0.55E-03	0.999	5.60E-03	0.990	8.95	045	90290
3507	0.41E-03	0.989	6.23E-03	0.990	10.98	3304	90290
3508	0.31E-03	1.000	6.04E-03	0.997	10.53	5726	90290
3509	0.34E-03	1.000	6.18E-03	0.998	10.94	12143	90290
3510	0.54E-03	1.000	5.35E-03	0.985	8.18	14603	90290
3511	0.27E-03	0.999	6.22E-03	0.998	11.15	21024	90290
3512	0.12E-03	0.999	8.11E-03	0.998	10.99	23446	90290
3513	5.88E-03	1.000	3.80E-03	0.998	10.63	25810	90290
3514	5.88E-03	1.000	6.07E-03	0.998	11.38	32333	90290
3515	5.97E-03	0.999	5.87E-03	0.994	10.43	34756	90290
3516	5.88E-03	0.999	6.04E-03	0.992	11.08	41227	90290
3517	5.88E-03	0.999	5.48E-03	0.998	9.38	43861	90290
3518	5.58E-03	1.000	5.78E-03	0.997	10.65	50118	90290
3519	5.42E-03	1.000	6.01E-03	0.995	11.53	52545	90290
3520	5.55E-03	1.000	5.88E-03	0.998	10.38	56015	90290
3521	5.64E-03	0.999	5.87E-03	0.997	10.85	61446	90290
3522	5.48E-03	0.999	5.61E-03	0.998	10.29	63913	90290
3523	5.34E-03	0.999	5.27E-03	0.995	9.41	70344	90290
3524	5.14E-03	0.999	5.22E-03	0.997	9.49	72018	90290
3525	5.14E-03	0.999	5.22E-03	0.997	9.49	72618	90290

Appendix I. SpOUR Monitoring from June 28 to Sept. 1, 1990


# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant



# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




197


# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant




# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant



# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant



# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant



# Specific Oxygen Uptake Rate Monitoring at Gold Bar Wastewater Treatment Plant

